



The following documentation is an electronically-submitted vendor response to an advertised solicitation from the *West Virginia Purchasing Bulletin* within the Vendor Self-Service portal at *wvOASIS.gov*. As part of the State of West Virginia's procurement process, and to maintain the transparency of the bid-opening process, this documentation submitted online is publicly posted by the West Virginia Purchasing Division at *WVPurchasing.gov* with any other vendor responses to this solicitation submitted to the Purchasing Division in hard copy format.

Header @ 1

List View

General Information | [Contact](#) | [Default Values](#) | [Discount](#) | [Document Information](#) | [Clarification Request](#)

Procurement Folder: 1376222

SO Doc Code: CRFQ

Procurement Type: Central Purchase Order

SO Dept: 0305

Vendor ID: 000000207543

SO Doc ID: FOR2400000008

Legal Name: GEORGE L WILSON & CO OF WV INC

Published Date: 2/12/24

Alias/DBA:

Close Date: 2/28/24

Total Bid: \$84,520.00

Close Time: 13:30

Response Date: 02/28/2024

Status: Closed

Response Time: 11:38

Solicitation Description: EIGHT (8) 75 GALLON L-TYPE UTV FIRE SUPPRESSION SKID UNITS

Responded By User ID: glwvv1

Total of Header Attachments: 1

First Name: Bryan

Total of All Attachments: 1

Last Name: Carlin

Email: b.carlin@georgelwilson.co

Phone: 304-592-3217

Line	Comm Ln Desc	Qty	Unit Issue	Unit Price	Ln Total Or Contract Amount
1	EIGHT (8) 75 GALLON L-TYPE UTV FIRE SUPPRESSION SKID UNITS	8.00000	EA	10565.000000	84520.00

Comm Code	Manufacturer	Specification	Model #
46191600			

Commodity Line Comments: Spec Sheet is attached for this.

Extended Description:

EIGHT (8) 75 GALLON L-TYPE UTV FIRE SUPPRESSION SKID UNITS



NATIONAL FIRE FIGHTER CORP.

Date

75 Gallon Top Mount

Tank

75 Gallon Poly Tank with removable top. Furnished with bottom mount tabs and constructed of ½ inch UV-stabilized black polypropylene with a glossy finish.

Standard features:

- Stainless steel flanges
- 3 inch sight gauge
- .5 inch UV-stabilized black polypropylene
- Tank baffled to NFPA specifications
- 8 x 8 inch water fill tower with latch
- .5 inch full-poly top mounting pad

Platform

- Full length of skid is made of 2" x 1/8" wall aluminum box tubing including bracing at appropriate spacing for the skids dimensions.
- Component and plumbing platform is wrapped with diamond plate sheet

Pump

National Fire Fighter model Wick 1004H Pump. This pump has a detachable pump end and performance capabilities of 69 gpm and 100 psi.

Standard features:

- 10 HP 4-stroke Briggs & Stratton Engine
- Light weight, electric start
- Hand Primer

Control Panel

- Flush mount liquid filled pressure gauge 0-600 psi (LED backlight Standard)
- Electric primer button (waterpuppy only)
- Panel mounted primer valve
- Panel mounted by-pass valve (standard)
- 50 amp circuit breaker
- Low pressure cut out switch

-Panel light (standard)

Plumbing

Two Suctions: -1.5 inch tank to pump
-1.5 inch auxiliary suction (NH)

Two Discharges: -1 inch overboard discharge outlet (NPSH)
-1 inch live for hose reel discharge

Pump to Tank Fill: -1 inch to tank from pump (by-pass)

- All valves will be port brass ball valve
- All hard plumbing will be stainless steel
- All control valves will be accessed from rear of unit
- Flex hose installed between pump and plumbing to allow for quick pump end removal.
- All flex hose to be internally expanded style coupling (no bands)

Coxwell Electric Red Steel Hose Reel

- Low profile outlet riser 1 inch male NPT thread
- Full flow brass swivel joint
- 50 feet on 3/4 inch red rubber booster hose NPSH threads