



The following documentation is an electronically-submitted vendor response to an advertised solicitation from the *West Virginia Purchasing Bulletin* within the Vendor Self-Service portal at ***wvOASIS.gov***. As part of the State of West Virginia's procurement process, and to maintain the transparency of the bid-opening process, this documentation submitted online is publicly posted by the West Virginia Purchasing Division at ***WVPurchasing.gov*** with any other vendor responses to this solicitation submitted to the Purchasing Division in hard copy format.

Header 4

List View

General Information [Contact](#) [Default Values](#) [Discount](#) [Document Information](#) [Clarification Request](#)

Procurement Folder: 1777410

Procurement Type: Central Master Agreement

Vendor ID: VS0000045819

Legal Name: SWIPE RESOURCES LLC

Alias/DBA: HAMZA MASUD

Total Bid: \$0.00

Response Date: 11/13/2025

Response Time: 13:19

Responded By User ID: swiperesources

First Name: Hamza

Last Name: Masud

Email: hamza.masud@swiperesou

Phone: 7038706182

SO Doc Code: CRFQ

SO Dept: 0803

SO Doc ID: DOT2600000035

Published Date: 11/5/25

Close Date: 11/13/25

Close Time: 13:30

Status: Closed

Solicitation Description: Fabric Covered Building Roof Systems

Total of Header Attachments: 4

Total of All Attachments: 4



Department of Administration
Purchasing Division
2019 Washington Street East
Post Office Box 50130
Charleston, WV 25305-0130

State of West Virginia
Solicitation Response

Proc Folder: 1777410
Solicitation Description: Fabric Covered Building Roof Systems
Proc Type: Central Master Agreement

Solicitation Closes	Solicitation Response	Version
2025-11-13 13:30	SR 0803 ESR11132500000003130	1

VENDOR
VS0000045819
SWIPE RESOURCES LLC

Solicitation Number: CRFQ 0803 DOT2600000035
Total Bid: 0
Response Date: 2025-11-13
Response Time: 13:19:32
Comments:

FOR INFORMATION CONTACT THE BUYER
John W Estep
304-558-2566
john.w.estep@wv.gov

Vendor
Signature X **FEIN#** **DATE**

All offers subject to all terms and conditions contained in this solicitation

Line	Comm Ln Desc	Qty	Unit Issue	Unit Price	Ln Total Or Contract Amount
1	Fabric Covered Building Roof System Size 40' x 70' One Door	0.00000	EA	0.000000	0.00

Comm Code	Manufacturer	Specification	Model #
72121200			

Commodity Line Comments: See Pricing Sheet

Extended Description:

SEE ATTACHED PRICING PAGE - ATTACHMENT A, FOR ACTUAL COST

Line	Comm Ln Desc	Qty	Unit Issue	Unit Price	Ln Total Or Contract Amount
2	Fabric Covered Building Roof System Size 54' x 100' One Door	0.00000	EA	0.000000	0.00

Comm Code	Manufacturer	Specification	Model #
72121200			

Commodity Line Comments: See Pricing Sheet

Extended Description:

SEE ATTACHED PRICING PAGE - ATTACHMENT A, FOR ACTUAL COST

Line	Comm Ln Desc	Qty	Unit Issue	Unit Price	Ln Total Or Contract Amount
3	Fabric Covered Building Roof System Size 72' x 100' One Door	0.00000	EA	0.000000	0.00

Comm Code	Manufacturer	Specification	Model #
72121200			

Commodity Line Comments: See Pricing Sheet

Extended Description:

SEE ATTACHED PRICING PAGE - ATTACHMENT A, FOR ACTUAL COST

Line	Comm Ln Desc	Qty	Unit Issue	Unit Price	Ln Total Or Contract Amount
4	Fabric Covered Building Roof System Size 72' x 140' One Door	0.00000	EA	0.000000	0.00

Comm Code	Manufacturer	Specification	Model #
72121200			

Commodity Line Comments: See Pricing Sheet

Extended Description:

SEE ATTACHED PRICING PAGE - ATTACHMENT A, FOR ACTUAL COST

Line	Comm Ln Desc	Qty	Unit Issue	Unit Price	Ln Total Or Contract Amount
5	Fabric Covered Building Roof System Size 72' x 140' Two Door	0.00000	EA	0.000000	0.00

Comm Code	Manufacturer	Specification	Model #
72121200			

Commodity Line Comments: See Pricing Sheet

Extended Description:

SEE ATTACHED PRICING PAGE - ATTACHMENT A, FOR ACTUAL COST

PRICING PAGE - ATTACHMENT A (ATT A)
Fabric Covered Building Roof Systems

VENDOR INSTRUCTIONS:

Please provide a bid price for all sizes of Fabric Covered Building Roof Systems, including all components of the building roof system materials, warranty, technical expert, and delivery FOB to any designated WVDOH site statewide.

Failure to bid all Contract Items shall result in the disqualification of the Vendor's bid. A contract will be awarded to the Vendor who provides all Contract Items meeting the required specifications for the lowest overall total cost of all Contract Items listed below.

VENDOR : _____Swipe Resources LLC_____

Contract Item #	Estimated Qty:	Description:	Unit of Measure:	Unit Price:	Extended Total:
1	1	Fabric Covered Building Roof System Size 40' x 70' - one door (2800 Sq Ft)	Each	\$ 27,750.00	\$ 27,750.00
2	5	Fabric Covered Building Roof System Size 54' x 100' - one door (5400 Sq Ft)	Each	\$ 67,500.00	\$ 337,500.00
3	3	Fabric Covered Building Roof System Size 72' x 100' - one door (7200 Sq Ft)	Each	\$ 89,100.00	\$ 267,300.00
4	1	Fabric Covered Building Roof System Size 72' x 140' - one door (10,800 Sq Ft)	Each	\$ 110,400.00	\$ 110,400.00
5	1	Fabric Covered Building Roof System Size 72' x 140' - two doors (10,800 Sq Ft)	Each	\$ 110,400.00	\$ 110,400.00
GRAND TOTAL					\$ 853,350.00

*Estimated quantities listed in this Solicitation are statewide approximations only. It is understood and agreed that the contract shall cover the quantities actually ordered for delivery during the term of the contract, whether more or less than the quantities shown. There is no guarantee of purchase of any items on this Pricing Page.



Department of Administration
Purchasing Division
2019 Washington Street East
Post Office Box 50130
Charleston, WV 25305-0130

State of West Virginia
Centralized Request for Quote
Building Supply

Proc Folder: 1777410

Doc Description: Fabric Covered Building Roof Systems

Reason for Modification:

ADDENDUM NO_3
Vendor Questions and responses

Proc Type: Central Master Agreement

Date Issued	Solicitation Closes	Solicitation No	Version
2025-11-05	2025-11-13 13:30	CRFQ 0803 DOT2600000035	4

BID RECEIVING LOCATION

BID CLERK
DEPARTMENT OF ADMINISTRATION
PURCHASING DIVISION
2019 WASHINGTON ST E
CHARLESTON WV 25305
US

VENDOR

Vendor Customer Code:

Vendor Name :

Address :

Street :

City :

State :

Country :

Zip :

Principal Contact :

Vendor Contact Phone:

Extension:

FOR INFORMATION CONTACT THE BUYER

John W Estep
304-558-2566
john.w.estep@wv.gov

**Vendor
Signature X**

FEIN#

DATE

All offers subject to all terms and conditions contained in this solicitation

ADDITIONAL INFORMATION

ADDENDUM NO_3

Addendum No_3 issued to publish and distribute the attached information to the Vendor Community

REQUEST FOR QUOTATION:

The West Virginia Purchasing Division is soliciting bids on behalf of the West Virginia Division of Highways to establish an open-end contract for *Fabric Covered Roof Systems, for WVDOH salt shed building sites throughout the state of West Virginia. Per the Bid Requirements, Specifications, Terms and Conditions attached to this solicitation.*

INVOICE TO		SHIP TO	
VARIOUS AGENCY LOCATIONS AS INDICATED BY ORDER		STATE OF WEST VIRGINIA VARIOUS LOCATIONS AS INDICATED BY ORDER	
No City US	WV	No City US	WV

Line	Comm Ln Desc	Qty	Unit Issue	Unit Price	Total Price
1	Fabric Covered Building Roof System Size 40' x 70' One Door	0.00000	EA		

Comm Code	Manufacturer	Specification	Model #
72121200			

Extended Description:

SEE ATTACHED PRICING PAGE - ATTACHMENT A, FOR ACTUAL COST

INVOICE TO		SHIP TO	
VARIOUS AGENCY LOCATIONS AS INDICATED BY ORDER		STATE OF WEST VIRGINIA VARIOUS LOCATIONS AS INDICATED BY ORDER	
No City US	WV	No City US	WV

Line	Comm Ln Desc	Qty	Unit Issue	Unit Price	Total Price
2	Fabric Covered Building Roof System Size 54' x 100' One Door	0.00000	EA		

Comm Code	Manufacturer	Specification	Model #
72121200			

Extended Description:

SEE ATTACHED PRICING PAGE - ATTACHMENT A, FOR ACTUAL COST

INVOICE TO				SHIP TO			
VARIOUS AGENCY LOCATIONS AS INDICATED BY ORDER				STATE OF WEST VIRGINIA VARIOUS LOCATIONS AS INDICATED BY ORDER			
No City		WV		No City		WV	
US				US			

Line	Comm Ln Desc	Qty	Unit Issue	Unit Price	Total Price
3	Fabric Covered Building Roof System Size 72' x 100' One Door	0.00000	EA		

Comm Code	Manufacturer	Specification	Model #
72121200			

Extended Description:
SEE ATTACHED PRICING PAGE - ATTACHMENT A, FOR ACTUAL COST

INVOICE TO				SHIP TO			
VARIOUS AGENCY LOCATIONS AS INDICATED BY ORDER				STATE OF WEST VIRGINIA VARIOUS LOCATIONS AS INDICATED BY ORDER			
No City		WV		No City		WV	
US				US			

Line	Comm Ln Desc	Qty	Unit Issue	Unit Price	Total Price
4	Fabric Covered Building Roof System Size 72' x 140' One Door	0.00000	EA		

Comm Code	Manufacturer	Specification	Model #
72121200			

Extended Description:
SEE ATTACHED PRICING PAGE - ATTACHMENT A, FOR ACTUAL COST

INVOICE TO				SHIP TO			
VARIOUS AGENCY LOCATIONS AS INDICATED BY ORDER				STATE OF WEST VIRGINIA VARIOUS LOCATIONS AS INDICATED BY ORDER			
No City		WV		No City		WV	
US				US			

Line	Comm Ln Desc	Qty	Unit Issue	Unit Price	Total Price
5	Fabric Covered Building Roof System Size 72' x 140' Two Door	0.00000	EA		

Comm Code	Manufacturer	Specification	Model #
72121200			

Extended Description:
SEE ATTACHED PRICING PAGE - ATTACHMENT A, FOR ACTUAL COST

SCHEDULE OF EVENTS		
<u>Line</u>	<u>Event</u>	<u>Event Date</u>
1	Tech Questions due by 10:00am	2025-10-28

SOLICITATION NUMBER: CRFQ DOT2600000035

Addendum Number: 3

The purpose of this addendum is to modify the solicitation identified as CRFQ DOT2600000035 ("Solicitation") to reflect the change(s) identified and described below.

Applicable Addendum Category:

- ☐ Modify bid opening date and time
- ☐ Modify specifications of product or service being sought
- ☒ Attachment of vendor questions and responses
- ☐ Attachment of pre-bid sign-in sheet
- ☐ Correction of error
- ☐ Other

Additional Documentation:

Vendor Questions and Responses

Bid Opening remains 11/13/2025 @ 1:30 PM

Terms and Conditions:

1. All provisions of the Solicitation and other addenda not modified herein shall remain in full force and effect.
2. Vendor should acknowledge receipt of all addenda issued for this Solicitation by completing an Addendum Acknowledgment, a copy of which is included herewith. Failure to acknowledge addenda may result in bid disqualification. The addendum acknowledgement should be submitted with the bid to expedite document processing.

CRFQ DOT2600000035 Fabric Covered Building Roof Systems

Responses to Questions from Vendors

Question 1

3.2.1. These sizes are custom widths, which we can fabricate. However, standard production truss widths are 40', 50', 60', 70', 80', etc., and can be produced more economically than 54' or 72' widths as the fabrication facility and engineering have already been set up for these sizes. Can we quote shelters 50x100, 60x100 and 70x100 in lieu of 54'W and 72'W?

Response 1

No, because these are often replacements for existing structures, we need the sizes indicated in 3.2.1 of the specifications.

Question 2

2) 3.2.1. requires Contractor to include price of tools required for installation. Is Customer's crew performing the installation? Define "specialty tools" as it applies to this paragraph. Contractor can provide a list of typical tools required for installation has no way of knowing what tools the Customer's crew has on hand.

Response 2

Specialty tools are devices designed for specific purposes, often to perform a task that standard tools cannot.

Question 3

3) 3.2.1. paragraph indicates that Contractor is not performing the installation, but only providing a "technical expert" during installation by Others. Please confirm.

Response 3

Yes, see section 3.2.1 of the specifications.

Question 4

4) 3.2.1.1. Confirm that customer requires the shelter to be ASCE7 Risk Category II.

Response 4

Yes, buildings must meet ASCE 7-22 on "Minimum Design Loads for Buildings and Other Structures."

Question 5

5) 3.2.1.1.2. What does this mean regarding wall thickness? The specified fabric is 23 mil HDPE architectural fabric. Is this shelter set upon a concrete stem wall? From 3.2.1.1.2, is this shelter set atop a 12" thick concrete stem wall? If yes, how high is the wall?

Response 5

Yes, the concrete wall is a minimum of 12" width and 13' high. See sections 3.2.1.1.1 and 3.2.1.1.2 of the specifications.

Question 6

6) 3.2.2.10. Accordion Folding Doors are not designed for industrial/commercial use lasting more than a year or two. A steel, non-insulated coil-style Rolling Service Door is designed to meet the rigors of industrial/commercial use. Contractor recommends deleting the AFD requirement and replacing it with RSD. There is no warranty on Accordion Fold Fabric Doors.

Response 6

Doors are Fold Fabric doors to keep out the elements. The WVDOH has found that metal doors do not meet our needs. The warranty is for the industrial cover as per section 3.2.3.5 of the specifications.

Question 7

7) 3.2.3. The fabric specified is a well-known offering from this fabric mill. The mill also offers a higher quality option but it is only available in white translucent. It provides better light transmissivity for a brighter interior. Is the Customer interested in this option?

Response 7

As per section 3.2 of the specifications, contract items must meet or exceed the mandatory requirements.

Question 8

8) 3.2.3.3. AL flat bar is a fine product, but for a salt storage facility, there is a bespoke PVC termination bar that serves the same purpose and is better aligned with the intended functioning of these shelters. Okay to use the PVC termination bar?

Response 8

No, see section 3.2 of the specifications.

Question 9

9) 3.2.3.6. Typical warranty coverage for Tension Fabric Structures is pro-rated, to cover untimely failures of the fabric or frame materials. The solicitation appears to be asking for a 100% warranty for any reason for 15 years, with no cost to the state. Is this correct?

Response 9

Yes, see section 3.2.3.5. and 3.2.3.6 of the specifications.

Question 10

10) 3.2.4.1. is titled "Sample Shop Drawings" but further indicates that Contractor is asked to provide the engineering details and fully completed proprietary design information before any contract is awarded. Is this correct?

Response 10

Yes, per 3.2.4.1 vendor sample shop drawings with complete information on the five requested systems should be submitted with the Vendor's bid. Vendor sample shop drawings shall indicate pertinent criteria, reaction and other information required for fabrication installation and as required by codes. The sample shop drawings shall identify the construction and in-place loads for consideration with the roof system building design.

Question 11

11) 3.2.5.3. Where and how often are these meetings to be held? How long are these meetings? Can representation be accomplished remotely?

Response 11

There will be 2 meetings for every order. The first meeting will happen when the order is placed and that can be attended remotely. The second will be at the time of build and will require a technical expert to be on site for the build.

Question 12

12) 3.2.1. These sizes are custom widths. Standard truss widths are 40', 50', 60', 70', 80', and can be produced more economically than 54' or 72' widths. Can we quote shelters 50x100, 60x100 and 70x100 in lieu of 54'W and 72'W?

Response 12

No, see section 3.2.1 of the specifications.

Question 13

13) 4.2. What is the “labor” described in this part, which Contractor must include in pricing (fabrication or installation, or something else)?

Response 13

The wording in section 4.2 indicates that the vendors bid price includes any and all expenses to vendor including the vendors technical expert and delivery. No additional charges outside the bid prices will be permitted.

Question 14

14) 5.2. Shelter items can remain with Contractor for a short period of time if there is some delay for a specific ADO, but Contractor cannot store materials for a lengthy period. Will the Customer arrange timely delivery of materials to the ADO project site, or provide storage if delivery is delayed?

Response 14

Delays will be kept to a minimum to the extent possible. For unseen circumstances, however, the vendor will retain materials until WVDOH is prepared for delivery.

Question 15

15) 5.4. What are the payment terms (e.g. Net 10, etc.)?

Response 15

Please review sections 14 and 15 of the terms and conditions. The State of West Virginia does not observe net 10.

Question 16

16) 6.2. Delivery Time. The Tension Fabric Structures described in this solicitation are not off-the-shelf items. While certain raw materials are maintained in stock, the shelter truss profiles are semi-custom products and fabricated upon receipt of an order from Customer. Absent a preplanned delivery schedule, the production timing for a single ad hoc order will be governed by raw material supply (fabric & steel), current structure production queue, and the galvanizer's production queue. It is unlikely that an ad hoc order can be fulfilled to point of delivery within 30 days. Contractor undertakes to fulfill every order promptly. Absent a preplanned order commitment, will customer agree to modify the 30-day requirement?

Response 16

Order deliveries may be modified on a case-by-case basis at the discretion of the ordering district engineer or their designee; however the intention of this contract is that orders be filled in 30 days. Vendors should only bid if they can manufacture product within this timeframe.

Question 17

17) 6.4. Confirming that the Customer wants a delivery price factored in for each SKU that would cover a delivery anywhere in the state? As written, it appears that Contractor must assume delivery to the most expensive location and apply that freight cost for every SKU. Contractor must also estimate the future cost of freight in a commodity market and add that margin to the cost for every SKU. Does this describe the Customer's expectation?

Response 17

Yes, see section 3.2.1 of the specifications.

Question 18

18) 6.6. Custom-made shelters cannot be returned. Customer is advised to work with Contractor to ensure that an ordered shelter meets the Customer's requirements prior to ordering. Once *fabricated, the Customer is responsible for payment.*

Response 18

All materials purchased by WVDOH are subject to sections 6.5 and 6.6 of the contract specifications.

Question 19

19) 8.2. Tension Fabric Structures are semi- or completely custom designed and fabricated to meet each customers' needs. They are not off-the-shelf items and are not stocked in a warehouse. Designs are finalized or created (semi-custom or completely custom) at time of order. This specification is not reasonable absent a preplanned production schedule/purchase commitment from the Customer. Contractor works to timely fulfill all customer orders and communication improves that experience. Contractor maintains a supply of raw materials based upon current *customer purchase orders and past experience with Tension Fabric Structures market volume.* This specification seems to be boilerplate language for Contract Items that would reasonably be stocked by a vendor (e.g., traffic cones). Please confirm that this specification is not required.

Response 19

Responsible vendors are expected to provide the contract items requested in the timeframes requested. This is an open-end contract. As per section 8.2 of the contract specifications. Vendor must carry sufficient inventory of the Contract Items being offered to fulfill its obligations under this Contract. By signing its bid, Vendor certifies that it can supply the Contract Items contained in its bid response.

ADDENDUM ACKNOWLEDGEMENT FORM
SOLICITATION NO.: CRFQ DOT2600000035

Instructions: Please acknowledge receipt of all addenda issued with this solicitation by completing this addendum acknowledgment form. Check the box next to each addendum received and sign below. Failure to acknowledge the addenda may result in bid disqualification.

Acknowledgment: I hereby acknowledge receipt of the following addenda and have made the necessary revisions to my proposal, plans and/or specification, etc.

Addendum Numbers Received:

(Check the box next to each addendum received)

☐ Addendum No. 1	☐ Addendum No. 6
☐ Addendum No. 2	☐ Addendum No. 7
☒ Addendum No. 3	☐ Addendum No. 8
☐ Addendum No. 4	☐ Addendum No. 9
☐ Addendum No. 5	☐ Addendum No. 10

I understand that failure to confirm the receipt of the addenda may be cause for rejection of this bid. I further understand that that any verbal representation made or assumed to be made during any oral discussion held between Vendor's representatives and any state personnel is not binding. Only the information issued in writing and added to the specifications by an official addendum is binding.

Swipe Resources LLC

Company


Authorized Signature

11/13/2025

Date

NOTE: This addendum acknowledgement should be submitted with the bid to expedite document processing.



Department of Administration
Purchasing Division
2019 Washington Street East
Post Office Box 50130
Charleston, WV 25305-0130

State of West Virginia
Centralized Request for Quote
Building Supply

Proc Folder: 1777410

Doc Description: Fabric Covered Building Roof Systems

Reason for Modification:

ADDENDUM NO_2
Bid Opening move to 11/13/25 @
1:30pm

Proc Type: Central Master Agreement

Date Issued	Solicitation Closes	Solicitation No	Version
2025-11-04	2025-11-13 13:30	CRFQ 0803 DOT2600000035	3

BID RECEIVING LOCATION

BID CLERK
DEPARTMENT OF ADMINISTRATION
PURCHASING DIVISION
2019 WASHINGTON ST E
CHARLESTON WV 25305
US

VENDOR

Vendor Customer Code:

Vendor Name :

Address :

Street :

City :

State :

Country :

Zip :

Principal Contact :

Vendor Contact Phone:

Extension:

FOR INFORMATION CONTACT THE BUYER

John W Estep
304-558-2566
john.w.estep@wv.gov

Vendor
Signature X

FEIN#

DATE

All offers subject to all terms and conditions contained in this solicitation

ADDITIONAL INFORMATION**ADDENDUM NO_2**

Addendum No_2 issued to publish and distribute the attached information to the Vendor Community

REQUEST FOR QUOTATION:

The West Virginia Purchasing Division is soliciting bids on behalf of the West Virginia Division of Highways to establish an open-end contract for *Fabric Covered Roof Systems, for WVDOH salt shed building sites throughout the state of West Virginia. Per the Bid Requirements, Specifications, Terms and Conditions attached to this solicitation.*

INVOICE TO		SHIP TO	
VARIOUS AGENCY LOCATIONS AS INDICATED BY ORDER		STATE OF WEST VIRGINIA VARIOUS LOCATIONS AS INDICATED BY ORDER	
No City US	WV	No City US	WV

Line	Comm Ln Desc	Qty	Unit Issue	Unit Price	Total Price
1	Fabric Covered Building Roof System Size 40' x 70' One Door	0.00000	EA		

Comm Code	Manufacturer	Specification	Model #
72121200			

Extended Description:

SEE ATTACHED PRICING PAGE - ATTACHMENT A, FOR ACTUAL COST

INVOICE TO		SHIP TO	
VARIOUS AGENCY LOCATIONS AS INDICATED BY ORDER		STATE OF WEST VIRGINIA VARIOUS LOCATIONS AS INDICATED BY ORDER	
No City US	WV	No City US	WV

Line	Comm Ln Desc	Qty	Unit Issue	Unit Price	Total Price
2	Fabric Covered Building Roof System Size 54' x 100' One Door	0.00000	EA		

Comm Code	Manufacturer	Specification	Model #
72121200			

Extended Description:

SEE ATTACHED PRICING PAGE - ATTACHMENT A, FOR ACTUAL COST

INVOICE TO				SHIP TO			
VARIOUS AGENCY LOCATIONS AS INDICATED BY ORDER				STATE OF WEST VIRGINIA VARIOUS LOCATIONS AS INDICATED BY ORDER			
No City		WV		No City		WV	
US				US			

Line	Comm Ln Desc	Qty	Unit Issue	Unit Price	Total Price
3	Fabric Covered Building Roof System Size 72' x 100' One Door	0.00000	EA		

Comm Code	Manufacturer	Specification	Model #
72121200			

Extended Description:
SEE ATTACHED PRICING PAGE - ATTACHMENT A, FOR ACTUAL COST

INVOICE TO				SHIP TO			
VARIOUS AGENCY LOCATIONS AS INDICATED BY ORDER				STATE OF WEST VIRGINIA VARIOUS LOCATIONS AS INDICATED BY ORDER			
No City		WV		No City		WV	
US				US			

Line	Comm Ln Desc	Qty	Unit Issue	Unit Price	Total Price
4	Fabric Covered Building Roof System Size 72' x 140' One Door	0.00000	EA		

Comm Code	Manufacturer	Specification	Model #
72121200			

Extended Description:
SEE ATTACHED PRICING PAGE - ATTACHMENT A, FOR ACTUAL COST

INVOICE TO		SHIP TO	
VARIOUS AGENCY LOCATIONS		STATE OF WEST VIRGINIA	
AS INDICATED BY ORDER		VARIOUS LOCATIONS AS INDICATED BY ORDER	
No City	WV	No City	WV
US		US	

Line	Comm Ln Desc	Qty	Unit Issue	Unit Price	Total Price
5	Fabric Covered Building Roof System Size 72' x 140' Two Door	0.00000	EA		

Comm Code	Manufacturer	Specification	Model #
72121200			

Extended Description:
SEE ATTACHED PRICING PAGE - ATTACHMENT A, FOR ACTUAL COST

SCHEDULE OF EVENTS

<u>Line</u>	<u>Event</u>	<u>Event Date</u>
1	Tech Questions due by 10:00am	2025-10-28

SOLICITATION NUMBER: CRFQ DOT2600000035

Addendum Number: 2

The purpose of this addendum is to modify the solicitation identified as CRFQ DOT2600000035 ("Solicitation") to reflect the change(s) identified and described below.

Applicable Addendum Category:

- ☒ [X] Modify bid opening date and time
- ☐ [] Modify specifications of product or service being sought
- ☐ [] Attachment of vendor questions and responses
- ☐ [] Attachment of pre-bid sign-in sheet
- ☐ [] Correction of error
- ☐ [] Other

Additional Documentation:

Bid Opening Moves to 11/13/2025 @ 1:30 PM

Terms and Conditions:

1. All provisions of the Solicitation and other addenda not modified herein shall remain in full force and effect.
2. Vendor should acknowledge receipt of all addenda issued for this Solicitation by completing an Addendum Acknowledgment, a copy of which is included herewith. Failure to acknowledge addenda may result in bid disqualification. The addendum acknowledgement should be submitted with the bid to expedite document processing.

ADDENDUM ACKNOWLEDGEMENT FORM
SOLICITATION NO.: CRFQ DOT2600000035

Instructions: Please acknowledge receipt of all addenda issued with this solicitation by completing this addendum acknowledgment form. Check the box next to each addendum received and sign below. Failure to acknowledge the addenda may result in bid disqualification.

Acknowledgment: I hereby acknowledge receipt of the following addenda and have made the necessary revisions to my proposal, plans and/or specification, etc.

Addendum Numbers Received:

(Check the box next to each addendum received)

☐ Addendum No. 1	☐ Addendum No. 6
☒ Addendum No. 2	☐ Addendum No. 7
☐ Addendum No. 3	☐ Addendum No. 8
☐ Addendum No. 4	☐ Addendum No. 9
☐ Addendum No. 5	☐ Addendum No. 10

I understand that failure to confirm the receipt of the addenda may be cause for rejection of this bid. I further understand that that any verbal representation made or assumed to be made during any oral discussion held between Vendor's representatives and any state personnel is not binding. Only the information issued in writing and added to the specifications by an official addendum is binding.

Swipe Resources LLC

Company



Authorized Signature

11/13/2025

Date

NOTE: This addendum acknowledgment should be submitted with the bid to expedite document processing.



Department of Administration
Purchasing Division
2019 Washington Street East
Post Office Box 50130
Charleston, WV 25305-0130

State of West Virginia
Centralized Request for Quote
Building Supply

Proc Folder: 1777410

Doc Description: Fabric Covered Building Roof Systems

Reason for Modification:

ADDENDUM NO_1
Vendor Questions and Responses

Proc Type: Central Master Agreement

Date Issued	Solicitation Closes	Solicitation No	Version
2025-10-31	2025-11-06 13:30	CRFQ 0803 DOT2600000035	2

BID RECEIVING LOCATION

BID CLERK
DEPARTMENT OF ADMINISTRATION
PURCHASING DIVISION
2019 WASHINGTON ST E
CHARLESTON WV 25305
US

VENDOR

Vendor Customer Code:

Vendor Name :

Address :

Street :

City :

State :

Country :

Zip :

Principal Contact :

Vendor Contact Phone:

Extension:

FOR INFORMATION CONTACT THE BUYER

John W Estep
304-558-2566
john.w.estep@wv.gov

**Vendor
Signature X**

FEIN#

DATE

All offers subject to all terms and conditions contained in this solicitation

ADDITIONAL INFORMATION**ADDENDUM NO_1**

Addendum No_1 issued to publish and distribute the attached information to the Vendor Community

REQUEST FOR QUOTATION:

The West Virginia Purchasing Division is soliciting bids on behalf of the West Virginia Division of Highways to establish an open-end contract for *Fabric Covered Roof Systems, for WVDOH salt shed building sites throughout the state of West Virginia. Per the Bid Requirements, Specifications, Terms and Conditions attached to this solicitation.*

INVOICE TO		SHIP TO	
VARIOUS AGENCY LOCATIONS AS INDICATED BY ORDER		STATE OF WEST VIRGINIA VARIOUS LOCATIONS AS INDICATED BY ORDER	
No City	WV	No City	WV
US		US	

Line	Comm Ln Desc	Qty	Unit Issue	Unit Price	Total Price
1	Fabric Covered Building Roof System Size 40' x 70' One Door	0.00000	EA		

Comm Code	Manufacturer	Specification	Model #
72121200			

Extended Description:

SEE ATTACHED PRICING PAGE - ATTACHMENT A, FOR ACTUAL COST

INVOICE TO		SHIP TO	
VARIOUS AGENCY LOCATIONS AS INDICATED BY ORDER		STATE OF WEST VIRGINIA VARIOUS LOCATIONS AS INDICATED BY ORDER	
No City	WV	No City	WV
US		US	

Line	Comm Ln Desc	Qty	Unit Issue	Unit Price	Total Price
2	Fabric Covered Building Roof System Size 54' x 100' One Door	0.00000	EA		

Comm Code	Manufacturer	Specification	Model #
72121200			

Extended Description:

SEE ATTACHED PRICING PAGE - ATTACHMENT A, FOR ACTUAL COST

INVOICE TO				SHIP TO			
VARIOUS AGENCY LOCATIONS AS INDICATED BY ORDER				STATE OF WEST VIRGINIA VARIOUS LOCATIONS AS INDICATED BY ORDER			
No City		WV		No City		WV	
US				US			

Line	Comm Ln Desc	Qty	Unit Issue	Unit Price	Total Price
3	Fabric Covered Building Roof System Size 72' x 100' One Door	0.00000	EA		

Comm Code	Manufacturer	Specification	Model #
72121200			

Extended Description:
SEE ATTACHED PRICING PAGE - ATTACHMENT A, FOR ACTUAL COST

INVOICE TO				SHIP TO			
VARIOUS AGENCY LOCATIONS AS INDICATED BY ORDER				STATE OF WEST VIRGINIA VARIOUS LOCATIONS AS INDICATED BY ORDER			
No City		WV		No City		WV	
US				US			

Line	Comm Ln Desc	Qty	Unit Issue	Unit Price	Total Price
4	Fabric Covered Building Roof System Size 72' x 140' One Door	0.00000	EA		

Comm Code	Manufacturer	Specification	Model #
72121200			

Extended Description:
SEE ATTACHED PRICING PAGE - ATTACHMENT A, FOR ACTUAL COST

INVOICE TO				SHIP TO			
VARIOUS AGENCY LOCATIONS				STATE OF WEST VIRGINIA			
AS INDICATED BY ORDER				VARIOUS LOCATIONS AS INDICATED BY ORDER			
No City		WV		No City		WV	
US				US			

Line	Comm Ln Desc	Qty	Unit Issue	Unit Price	Total Price
5	Fabric Covered Building Roof System Size 72' x 140' Two Door	0.00000	EA		

Comm Code	Manufacturer	Specification	Model #
72121200			

Extended Description:
SEE ATTACHED PRICING PAGE - ATTACHMENT A, FOR ACTUAL COST

SCHEDULE OF EVENTS

<u>Line</u>	<u>Event</u>	<u>Event Date</u>
1	Tech Questions due by 10:00am	2025-10-28

SOLICITATION NUMBER: CRFQ DOT2600000035

Addendum Number: 1

The purpose of this addendum is to modify the solicitation identified as CRFQ DOT2600000035 (“Solicitation”) to reflect the change(s) identified and described below.

Applicable Addendum Category:

- ☐ Modify bid opening date and time
- ☐ Modify specifications of product or service being sought
- ☒ Attachment of vendor questions and responses
- ☐ Attachment of pre-bid sign-in sheet
- ☐ Correction of error
- ☐ Other

Additional Documentation:

Vendor Questions and responses

Bid Opening remains 11/06/2025 @ 1:30 PM

Terms and Conditions:

1. All provisions of the Solicitation and other addenda not modified herein shall remain in full force and effect.
2. Vendor should acknowledge receipt of all addenda issued for this Solicitation by completing an Addendum Acknowledgment, a copy of which is included herewith. Failure to acknowledge addenda may result in bid disqualification. The addendum acknowledgement should be submitted with the bid to expedite document processing.

CRFQ DOT2600000035 Fabric Covered Building Roof Systems

Responses to Questions from Vendors

Question 1

Are we to assume 10' concrete wall height for the foundations in order to achieve 13' clearance height?

Response 1

Please see section 3.2.1.1.1 in the specs

Question 2

Are the minimum interior clearance required at the apex of the buildings from finish floor to bottom of truss?

Response 2

Please see section 3.2.1.1.3 in the specs

ADDENDUM ACKNOWLEDGEMENT FORM
SOLICITATION NO.: CRFQ DOT2600000035

Instructions: Please acknowledge receipt of all addenda issued with this solicitation by completing this addendum acknowledgment form. Check the box next to each addendum received and sign below. Failure to acknowledge the addenda may result in bid disqualification.

Acknowledgment: I hereby acknowledge receipt of the following addenda and have made the necessary revisions to my proposal, plans and/or specification, etc.

Addendum Numbers Received:

(Check the box next to each addendum received)

☒ Addendum No. 1	☐ Addendum No. 6
☐ Addendum No. 2	☐ Addendum No. 7
☐ Addendum No. 3	☐ Addendum No. 8
☐ Addendum No. 4	☐ Addendum No. 9
☐ Addendum No. 5	☐ Addendum No. 10

I understand that failure to confirm the receipt of the addenda may be cause for rejection of this bid. I further understand that that any verbal representation made or assumed to be made during any oral discussion held between Vendor's representatives and any state personnel is not binding. Only the information issued in writing and added to the specifications by an official addendum is binding.

Swipe Resources LLC

Company



Authorized Signature

11/13/2025

Date

NOTE: This addendum acknowledgement should be submitted with the bid to expedite document processing.