



State of West Virginia
 Department of Administration
 Purchasing Division
 2019 Washington Street East
 Post Office Box 50130
 Charleston, WV 25305-0130

Request for Quotation

RFQ NUMBER
09900259

PAGE
1

ADDRESS CORRESPONDENCE TO ATTENTION OF
MICHAEL AUSTIN 304-558-2402

VENDOR

*523114545 800-344-4510
 RIGHT EQUIPMENT
 PO BOX 118

 CLOVERDALE VA 24077

SHIP TO


DIVISION OF HIGHWAYS
 DISTRICT NINE

 103 1/2 CHURCH STREET
 LEWISBURG, WV
 24901 304-647-7457

DATE PRINTED	TERMS OF SALE	SHIP VIA	F.O.B	FREIGHT TERMS
05/07/2009				

BID OPENING DATE: **05/20/2009** BID OPENING TIME **01:30PM**

LINE	QUANTITY	UOP	CAT NO	ITEM NUMBER	UNIT PRICE	AMOUNT
0001	1	EA		890-16	\$28,545.00	\$28,545.00
<p>WATER TREATMENT SYSTEM</p> <p>TO PROVIDE WATER TREATMENT SYSTEM WLP-20AB-0M10 MANUFACTURER MI-T-M CORPORATION OR EQUAL FOR THE WEST VIRGINIA DIVISION OF HIGHWAYS PER THE ATTACHED SPECIFICATIONS.</p> <p>THE MODEL/BRAND/SPECIFICATIONS NAMED HEREIN ESTABLISH THE ACCEPTABLE LEVEL OF QUALITY ONLY AND ARE NOT INTENDED TO REFLECT A PREFERENCE OR FAVOR ANY PARTICULAR BRAND OR VENDOR. VENDORS WHO ARE BIDDING ALTERNATES SHOULD SO STATE AND INCLUDE PERTINENT LITERATURE AND SPECIFICATIONS. FAILURE TO PROVIDE INFORMATION FOR ANY ALTERNATES MAY BE GROUNDS FOR REJECTION OF THE BID. THE STATE RESERVES THE RIGHT TO WAIVE MINOR IRREGULARITIES IN BIDS OR SPECIFICATIONS IN ACCORDANCE WITH SECTION 148-1-4(F) OF THE WEST VIRGINIA LEGISLATIVE RULES AND REGULATIONS.</p> <p>EXHIBIT 10</p> <p>REQUISITION NO.:</p> <p>ADDENDUM ACKNOWLEDGEMENT</p> <p>I HEREBY ACKNOWLEDGE RECEIPT OF THE FOLLOWING CHECKED ADDENDUM(S) AND HAVE MADE THE NECESSARY REVISIONS TO MY PROPOSAL, PLANS AND/OR SPECIFICATION, ETC.</p> <p>ADDENDUM NO.'S:</p>						



SEE REVERSE SIDE FOR TERMS AND CONDITIONS		
SIGNATURE	TELEPHONE	DATE
TITLE	FEIN	ADDRESS CHANGES TO BE NOTED ABOVE

WHEN RESPONDING TO RFQ, INSERT NAME AND ADDRESS IN SPACE ABOVE LABELED 'VENDOR'

**GENERAL TERMS & CONDITIONS
REQUEST FOR QUOTATION (RFQ) AND REQUEST FOR PROPOSAL (RFP)**

1. Awards will be made in the best interest of the State of West Virginia.
2. The State may accept or reject in part, or in whole, any bid.
3. All quotations are governed by the *West Virginia Code* and the *Legislative Rules* of the Purchasing Division.
4. Prior to any award, the apparent successful vendor must be properly registered with the Purchasing Division and have paid the required \$125 fee.
5. All services performed or goods delivered under State Purchase Order/Contracts are to be continued for the term of the Purchase Order/Contracts, contingent upon funds being appropriated by the Legislature or otherwise being made available. In the event funds are not appropriated or otherwise available for these services or goods, this Purchase Order/Contract becomes void and of no effect after June 30.
6. Payment may only be made after the delivery and acceptance of goods or services.
7. Interest may be paid for late payment in accordance with the *West Virginia Code*.
8. Vendor preference will be granted upon written request in accordance with the *West Virginia Code*.
9. The State of West Virginia is exempt from federal and state taxes and will not pay or reimburse such taxes.
10. The Director of Purchasing may cancel any Purchase Order/Contract upon 30 days written notice to the seller.
11. The laws of the State of West Virginia and the *Legislative Rules* of the Purchasing Division shall govern all rights and duties under the Contract, including without limitation the validity of this Purchase Order/Contract.
12. Any reference to automatic renewal is hereby deleted. The Contract may be renewed only upon mutual written agreement of the parties.
13. **BANKRUPTCY:** In the event the vendor/contractor files for bankruptcy protection, this Contract may be deemed null and void, and terminated without further order.
14. **HIPAA BUSINESS ASSOCIATE ADDENDUM:** The West Virginia State Government HIPAA Business Associate Addendum (BAA), approved by the Attorney General, and available online at the Purchasing Division's web site (<http://www.state.wv.us/admin/purchase/vrc/hipaa.htm>) is hereby made part of the agreement. Provided that, the Agency meets the definition of a Cover Entity (45 CFR §160.103) and will be disclosing Protected Health Information (45 CFR §160.103) to the vendor.
15. **WEST VIRGINIA ALCOHOL & DRUG-FREE WORKPLACE ACT:** If this Contract constitutes a public improvement construction contract as set forth in Article 1D, Chapter 21 of the West Virginia Code ("The West Virginia Alcohol and Drug-Free Workplace Act"), then the following language shall hereby become part of this Contract: "The contractor and its subcontractors shall implement and maintain a written drug-free workplace policy in compliance with the West Virginia Alcohol and Drug-Free Workplace Act, as set forth in Article 1D, Chapter 21 of the West Virginia Code. The contractor and its subcontractors shall provide a sworn statement in writing, under the penalties of perjury, that they maintain a valid drug-free work place policy in compliance with the West Virginia and Drug-Free Workplace Act. It is understood and agreed that this Contract shall be cancelled by the awarding authority if the Contractor: 1) Fails to implement its drug-free workplace policy; 2) Fails to provide information regarding implementation of the contractor's drug-free workplace policy at the request of the public authority; or 3) Provides to the public authority false information regarding the contractor's drug-free workplace policy."

INSTRUCTIONS TO BIDDERS

1. Use the quotation forms provided by the Purchasing Division.
2. **SPECIFICATIONS:** Items offered must be in compliance with the specifications. Any deviation from the specifications must be clearly indicated by the bidder. Alternates offered by the bidder as **EQUAL** to the specifications must be clearly defined. A bidder offering an alternate should attach complete specifications and literature to the bid. The Purchasing Division may waive minor deviations to specifications.
3. Complete all sections of the quotation form.
4. Unit prices shall prevail in case of discrepancy.
5. All quotations are considered F.O.B. destination unless alternate shipping terms are clearly identified in the quotation.
6. **BID SUBMISSION:** All quotations must be delivered by the bidder to the office listed below prior to the date and time of the bid opening. Failure of the bidder to deliver the quotations on time will result in bid disqualifications: Department of Administration, Purchasing Division, 2019 Washington Street East, P.O. Box 50130, Charleston, WV 25305-0130



State of West Virginia
 Department of Administration
 Purchasing Division
 2019 Washington Street East
 Post Office Box 50130
 Charleston, WV 25305-0130

Request for Quotation

RFQ NUMBER
09900259

PAGE
3

ADDRESS CORRESPONDENCE TO ATTENTION OF
MICHAEL AUSTIN 304-558-2402

VENDOR

*523114545 800-344-4510
 RIGHT EQUIPMENT
 PO BOX 118

 CLOVERDALE VA 24077

SHIP TO

DIVISION OF HIGHWAYS
 DISTRICT NINE

 103 1/2 CHURCH STREET
 LEWISBURG, WV
 24901 304-647-7457

DATE PRINTED	TERMS OF SALE	SHIP VIA	F.O.B.	FREIGHT TERMS
05/07/2009				

BID OPENING DATE: **05/20/2009** BID OPENING TIME **01:30PM**

LINE	QUANTITY	UOP	CAT NO.	ITEM NUMBER	UNIT PRICE	AMOUNT
<p>A SIGNED BID MUST BE SUBMITTED TO:</p> <p>DEPARTMENT OF ADMINISTRATION PURCHASING DIVISION BUILDING 15 2019 WASHINGTON STREET, EAST CHARLESTON, WV 25305-0130</p> <p>THE BID SHOULD CONTAIN THIS INFORMATION ON THE FACE OF THE ENVELOPE OR THE BID MAY NOT BE CONSIDERED:</p> <p>SEALED BID</p> <p>BUYER: 33</p> <p>RFQ. NO.: 09900259</p> <p>BID OPENING DATE: ----- <i>05/20/2009</i></p> <p>BID OPENING TIME: ----- <i>01:30PM</i></p> <p>PLEASE PROVIDE A FAX NUMBER IN CASE IT IS NECESSARY TO CONTACT YOU REGARDING YOUR BID:</p> <p>----- <i>540-992-5955</i></p> <p>CONTACT PERSON (PLEASE PRINT CLEARLY):</p> <p>----- <i>Edward C Spangler</i></p>						

SEE REVERSE SIDE FOR TERMS AND CONDITIONS		
SIGNATURE	TELEPHONE	DATE
TITLE	FEIN	ADDRESS CHANGES TO BE NOTED ABOVE

WHEN RESPONDING TO RFQ, INSERT NAME AND ADDRESS IN SPACE ABOVE LABELED 'VENDOR'



State of West Virginia
 Department of Administration
 Purchasing Division
 2019 Washington Street East
 Post Office Box 50130
 Charleston, WV 25305-0130

Request for Quotation

RFQ NUMBER
09900259

PAGE
2

ADDRESS CORRESPONDENCE TO ATTENTION OF
MICHAEL AUSTIN 304-558-2402

VENDOR

*523114545 800-344-4510
 RIGHT EQUIPMENT
 PO BOX 118
 CLOVERDALE VA 24077

SHIP TO

DIVISION OF HIGHWAYS
 DISTRICT NINE
 103 1/2 CHURCH STREET
 LEWISBURG, WV
 24901 304-647-7457

DATE PRINTED	TERMS OF SALE	SHIP VIA	FOB	FREIGHT TERMS
05/07/2009				

BID OPENING DATE: **05/20/2009** BID OPENING TIME **01:30PM**

LINE	QUANTITY	UOP	CAT NO	ITEM NUMBER	UNIT PRICE	AMOUNT
	NO. 1					
	NO. 2					
	NO. 3					
	NO. 4					
	NO. 5					
<p>I UNDERSTAND THAT FAILURE TO CONFIRM THE RECEIPT OF THE ADDENDUM(S) MAY BE CAUSE FOR REJECTION OF BIDS.</p> <p>VENDOR MUST CLEARLY UNDERSTAND THAT ANY VERBAL REPRESENTATION MADE OR ASSUMED TO BE MADE DURING ANY ORAL DISCUSSION HELD BETWEEN VENDOR'S REPRESENTATIVES AND ANY STATE PERSONNEL IS NOT BINDING. ONLY THE INFORMATION ISSUED IN WRITING AND ADDED TO THE SPECIFICATIONS BY AN OFFICIAL ADDENDUM IS BINDING.</p> <p style="text-align: center;"> <i>Edward C. Spangh</i> SIGNATURE <i>Right Equipment</i> COMPANY <i>05/11/09</i> DATE </p>						
REV. 11/96						
NOTICE						

SEE REVERSE SIDE FOR TERMS AND CONDITIONS

SIGNATURE	TELEPHONE	DATE
TITLE	FEIN	ADDRESS CHANGES TO BE NOTED ABOVE

WHEN RESPONDING TO RFQ, INSERT NAME AND ADDRESS IN SPACE ABOVE LABELED 'VENDOR'



State of West Virginia
 Department of Administration
 Purchasing Division
 2019 Washington Street East
 Post Office Box 50130
 Charleston, WV 25305-0130

Request for Quotation

RFQ NUMBER
09900259

PAGE
4

ADDRESS CORRESPONDENCE TO ATTENTION OF:
MICHAEL AUSTIN 304-558-2402

VENDOR

*523114545 800-344-4510
 RIGHT EQUIPMENT
 PO BOX 118
 CLOVERDALE VA 24077

SHIP TO

DIVISION OF HIGHWAYS
 DISTRICT NINE
 103 1/2 CHURCH STREET
 LEWISBURG, WV
 24901 304-647-7457

DATE PRINTED	TERMS OF SALE	SHIP VIA	F.O.B.	FREIGHT TERMS
05/07/2009				

BID OPENING DATE: **05/20/2009** BID OPENING TIME **01:30PM**

LINE	QUANTITY	UOP	CAT NO	ITEM NUMBER	UNIT PRICE	AMOUNT
***** THIS IS THE END OF RFQ 09900259 ***** TOTAL:						<u>\$28,545.00</u>

SEE REVERSE SIDE FOR TERMS AND CONDITIONS

SIGNATURE	TELEPHONE	DATE
TITLE	FEIN	ADDRESS CHANGES TO BE NOTED ABOVE

WHEN RESPONDING TO RFQ, INSERT NAME AND ADDRESS IN SPACE ABOVE LABELED 'VENDOR'

Item No.	Quantity	Description	Unit Price	Amount
		<p>THE WATER TREATMENT SYSTEM WILL BE DESIGNED TO TREAT AND RECYCLE VEHICLE AND EQUIPMENT WASH-WATER ORIGINATING FROM A PRESSURE WASHER, STEAM CLEANER. THE WATER TREATMENT SYSTEM WILL BE MOUNTED ON A 5' BY 8' POLY SKID AND WILL INCLUDE AN INLINE STRAINER PUMP FOR FEEDING TO THE TREATMENT SYSTEM. THE WATER TREATMENT SYSTEM WILL BE NO HIGHER THAN 52". THIS SYSTEM WILL INCLUDE A CORONA DISCHARGE OZONE GENERATOR AND AUTOMATED ORP AND PH CONTROL SYSTEMS FOR BACTERIA CONTROL, A STAINLESS STEEL TANK WITH ASLOPED BOTTOM FOR EASY SLUDGE REMOVAL, A COALESCING PACK FOR OIL REMOVAL, A MULTIMEDIA FILTER WITH 20 MICRON FILTERING CAPABILITY AND AN ACTIVATED CARBON FILTER. THIS SYSTEM WILL BE EQUIPPED TO BACK WASH AUTOMATICALLY USING TIMERS. THIS SYSTEM WILL BE EQUIPPED WITH MANUFACTURER RECOMMENDED AIR COMPRESSOR FOR USE WITH THE AUTO BACK WASH SYSTEM. THIS SYSTEM WILL BE COMPLETE WITH SATER LEVEL CONTROL FLOATS. ALL OF THE EQUIPMENT IN THIS SECTION SHALL BE SUPPLIED BY A SINGLE SUPPLIER AS A PACKAGED SYSTEM. THIS SYSTEM SHALL BE A WLP-20AB-OM10 ADVANCED WASH-WATER RECYCLE SYSTEM AS MANUFACTURED BY MI-T-M CORP.</p>		
		<p style="text-align: center;">PERFORMANCE:</p> <p>THE WASH-WATER TREATMENT SYSTEM SHALL BE CAPABLE OF TREATING AND RECYCLING PRESSURE WASHER OR STEAM CLEANER WATER GENERATED FROM THE CLEANING OF VEHICLES, MACHINERY OR EQUIPMENT. THIS SYSTEM WILL:</p> <ol style="list-style-type: none"> 1. TREAT THE WATER WITH UP TO 24 GRAMS PER DAY OF OZONE 2. USE A 30 DEGREE SLOPED TANK TO CAPTURE SETTLING SOLIDS 3. REMOVE FROM THE WATER ALL PHYSICAL PARTICLES DOWN TO 20 MICRONS 4. REMOVE FROM THE WATER ALL FREE IOL DROPLETS, 1 MICRON AND LARGER (WITH THE USE OF PROPER DETERGENTS) 5. REMOVE FROM THE WATER TRACE AMOUNTS OF A WIDE RANGE OF ORGANICS, SUCH AS: GASOLINE, DIESEL FUEL, HERBICIDES, PESTICIDES. 6. PROCESS WATER UP TO 20 GALLONS PER MINUTE 7. BE CAPABLE OF AUTOMATICALLY ADJUSTING THE PH LEVEL OF THE WATER 8. BE CAPABLE OF AUTOMATICALLY TREATING THE WATER WITH A SANITIZING SOLUTION AND SUSTAINING A GIVEN LEVEL OF SANITIZER, AS MEASURED IN MILLIVOLTS. 		

Item No.	Quantity	Description	Unit Price	Amount
		<p>1. ELECTRICAL REQUIREMENTS. SYSTEM WILL BE FULLY OPERATIONAL BY THE USE OF A 230 VOLT, SINGLE PHASE, 18 AMP POWER SOURCE.</p> <p>2. AIR REQUIREMENTS. SYSTEM REQUIRES 100 PSI FOR SUTO BACKWASH CAPABILITY.</p> <p>3. POLY SKID. SYSTEM WILL BE PRE-PACKAGED, READY TO INSTALL, AND MOUNTED ON A 5' BY 8' POLY SKID. POLY SKID WILL BE ASSEMBLED WITH STAINLESS STEEL FASTENERS. POLY SKID SHALL HAVE FORKLIFT CAVITIES IN ALL FOUR SIDES FOR EASY TRANSPORT AND PLACEMENT OF THE SYSTEM.</p> <p>4. OZONE GENERATOR. OZONE GENERATOR WILL USE CORONA DISCHARGE TECHNOLOGY TO PROVIDE UP TO 24 GRAMS PER DAY OF OZONE TO BE INJECTED INTO WASTEWATER</p> <p>5. WATER/OIL/SOLIDS SEPARATOR. THE SYSTEM WILL CONTAIN A STAINLESS STEEL TANK, AT LEAST 2.7 MM THICK, WITH 3 CHAMBERS SEPARTATED BY DOUBLE BAFFLES AND A 30 DEGREE SLOPED BOTTOM FOR SLUDGE SETTLING. THE TANK AND THE OIL COALESCING PACK WILL CONSTITUTE APPROXIMATELY 625 SQUARE FEET OF OIL COALESCING SURFACE AREA. THE TANK WILL ALSO PROVIDE AN OIL SKIMMING PORT LEADING TO AN ATTACHED OIL DECANter, FOR EASY HANDLING AND DISPOSAL OF THE OIL.</p> <p>6. CANTROL PANEL. CONTROL PANEL WILL BE CONSTRUED OF A NEMA 4 HOUSING. CONVENIENTLY DISPLAYED ON THE CONTROL PANEL WILL BE CONTROLS FOR THE SYSTEM'S POWER, FILTER PUMP, TRANSFER PUMP, SUMP PUMP, BACKWASHING, DIGITAL PH CONTROL SYSTEM AND DIGITAL ORP CONTROL SYSTEM.</p> <p>7. MULTIMEDIA FILTER. MULTIMEDIA FILTER WILL CONSIST OF A CUSTOM MIX OF A MEDIA CAPABLE OF FILTERING DOWN PARTICULATES TO 20 MICRONS.</p> <p>8. CARBON FILTER. SYSTEM WILL CONTAIN A BACKWASHABLE FILTER CONTAINING GRANULAR ACTIVATED CARBON, UP TO 220 POUNDS DEGASSED.</p> <p>9. PRESSURIZED CONTAINER. SYSTEM WILL CONTAIN A PRESSURIZED FILTERED WATER CONTAINER THAT WILL PROVIDE BETWEEN 30 AND 50 PSI TREATED WATER AT UP TO 20 GALLONS PER MINUTE.</p> <p>10. HOSE CONNECTION PANEL. SYSTEM WILL HAVE A CONNECTION PANEL WHICH WILL CONTAIN CONNECTION POINTS FOR 1.) OUTLET TO PRESSURE WASHER, 2) FRESH WATER INLET, 3) RINSE WATER OUTLET, 4) RAIN WATER OVERFLOW OUTLET.</p>		

Item No.	Quantity	Description	Unit Price	Amount
		<p>PRICE IS TO INCLUDE DELIVERY TO MUDDLETY</p> <p>PRICE IS TO INCLUDE ONE YEAR PARTS AND LABOR</p> <p>0980-PM4683B-812-064</p> <p>US 19 approximately 6 miles North of Summersville, WV from US 19/WV 55 interchange go West 0.05 miles road ends at complex.</p>		

VENDOR PREFERENCE CERTIFICATE

Certification and application* is hereby made for Preference in accordance with West Virginia Code, §5A-3-37. (Does not apply to construction contracts). West Virginia Code, §5A-3-37, provides an opportunity for qualifying vendors to request (at the time of bid) preference for their residency status. Such preference is an evaluation method only and will be applied only to the cost bid in accordance with the West Virginia Code. This certificate for application is to be used to request such preference. The Purchasing Division will make the determination of the Resident Vendor Preference, if applicable.

- 1. Application is made for 2.5% resident vendor preference for the reason checked: Bidder is an individual resident vendor and has resided continuously in West Virginia for four (4) years immediately preceding the date of this certification; or, Bidder is a partnership, association or corporation resident vendor and has maintained its headquarters or principal place of business continuously in West Virginia for four (4) years immediately preceding the date of this certification; or 80% of the ownership interest of Bidder is held by another individual, partnership, association or corporation resident vendor who has maintained its headquarters or principal place of business continuously in West Virginia for four (4) years immediately preceding the date of this certification; or, Bidder is a nonresident vendor which has an affiliate or subsidiary which employs a minimum of one hundred state residents and which has maintained its headquarters or principal place of business within West Virginia continuously for the four (4) years immediately preceding the date of this certification; or,
2. Application is made for 2.5% resident vendor preference for the reason checked: Bidder is a resident vendor who certifies that, during the life of the contract, on average at least 75% of the employees working on the project being bid are residents of West Virginia who have resided in the state continuously for the two years immediately preceding submission of this bid; or,
3. Application is made for 2.5% resident vendor preference for the reason checked: Bidder is a nonresident vendor employing a minimum of one hundred state residents or is a nonresident vendor with an affiliate or subsidiary which maintains its headquarters or principal place of business within West Virginia employing a minimum of one hundred state residents who certifies that, during the life of the contract, on average at least 75% of the employees or Bidder's affiliate's or subsidiary's employees are residents of West Virginia who have resided in the state continuously for the two years immediately preceding submission of this bid; or,
4. Application is made for 5% resident vendor preference for the reason checked: Bidder meets either the requirement of both subdivisions (1) and (2) or subdivision (1) and (3) as stated above; or,
5. Application is made for 3.5% resident vendor preference who is a veteran for the reason checked: Bidder is an individual resident vendor who is a veteran of the United States armed forces, the reserves or the National Guard and has resided in West Virginia continuously for the four years immediately preceding the date on which the bid is submitted; or,
6. Application is made for 3.5% resident vendor preference who is a veteran for the reason checked: Bidder is a resident vendor who is a veteran of the United States armed forces, the reserves or the National Guard, if, for purposes of producing or distributing the commodities or completing the project which is the subject of the vendor's bid and continuously over the entire term of the project, on average at least seventy-five percent of the vendor's employees are residents of West Virginia who have resided in the state continuously for the two immediately preceding years.

Bidder understands if the Secretary of Revenue determines that a Bidder receiving preference has failed to continue to meet the requirements for such preference, the Secretary may order the Director of Purchasing to: (a) reject the bid; or (b) assess a penalty against such Bidder in an amount not to exceed 5% of the bid amount and that such penalty will be paid to the contracting agency or deducted from any unpaid balance on the contract or purchase order.

By submission of this certificate, Bidder agrees to disclose any reasonably requested information to the Purchasing Division and authorizes the Department of Revenue to disclose to the Director of Purchasing appropriate information verifying that Bidder has paid the required business taxes, provided that such information does not contain the amounts of taxes paid nor any other information deemed by the Tax Commissioner to be confidential.

Under penalty of law for false swearing (West Virginia Code, §61-5-3), Bidder hereby certifies that this certificate is true and accurate in all respects; and that if a contract is issued to Bidder and if anything contained within this certificate changes during the term of the contract, Bidder will notify the Purchasing Division in writing immediately.

Bidder: N/A Signed:
Date: Title:

*Check any combination of preference consideration(s) indicated above, which you are entitled to receive.

STATE OF WEST VIRGINIA
Purchasing Division**PURCHASING AFFIDAVIT****VENDOR OWING A DEBT TO THE STATE:**

West Virginia Code §5A-3-10a provides that: No contract or renewal of any contract may be awarded by the state or any of its political subdivisions to any vendor or prospective vendor when the vendor or prospective vendor or a related party to the vendor or prospective vendor is a debtor and the debt owed is an amount greater than one thousand dollars in the aggregate.

PUBLIC IMPROVEMENT CONTRACTS & DRUG-FREE WORKPLACE ACT:

If this is a solicitation for a public improvement construction contract, the vendor, by its signature below, affirms that it has a written plan for a drug-free workplace policy in compliance with Article 1D, Chapter 21 of the *West Virginia Code*. The vendor **must** make said affirmation with its bid submission. Further, public improvement construction contract may not be awarded to a vendor who does not have a written plan for a drug-free workplace policy in compliance with Article 1D, Chapter 21 of the *West Virginia Code* and who has not submitted that plan to the appropriate contracting authority in timely fashion. For a vendor who is a subcontractor, compliance with Section 5, Article 1D, Chapter 21 of the *West Virginia Code* may take place before their work on the public improvement is begun.

ANTITRUST:

In submitting a bid to any agency for the state of West Virginia, the bidder offers and agrees that if the bid is accepted the bidder will convey, sell, assign or transfer to the state of West Virginia all rights, title and interest in and to all causes of action it may now or hereafter acquire under the antitrust laws of the United States and the state of West Virginia for price fixing and/or unreasonable restraints of trade relating to the particular commodities or services purchased or acquired by the state of West Virginia. Such assignment shall be made and become effective at the time the purchasing agency tenders the initial payment to the bidder.

I certify that this bid is made without prior understanding, agreement, or connection with any corporation, firm, limited liability company, partnership or person or entity submitting a bid for the same materials, supplies, equipment or services and is in all respects fair and without collusion or fraud. I further certify that I am authorized to sign the certification on behalf of the bidder or this bid.

LICENSING:


Vendors must be licensed and in good standing in accordance with any and all state and local laws and requirements by any state or local agency of West Virginia, including, but not limited to, the West Virginia Secretary of State's Office, the West Virginia Tax Department, West Virginia Insurance Commission, or any other state agencies or political subdivision. Furthermore, the vendor must provide all necessary releases to obtain information to enable the Director or spending unit to verify that the vendor is licensed and in good standing with the above entities.

CONFIDENTIALITY:

The vendor agrees that he or she will not disclose to anyone, directly or indirectly, any such personally identifiable information or other confidential information gained from the agency, unless the individual who is the subject of the information consents to the disclosure in writing or the disclosure is made pursuant to the agency's policies, procedures and rules. Vendor further agrees to comply with the Confidentiality Policies and Information Security Accountability Requirements, set forth in <http://www.state.wv.us/admin/purchase/privacy/noticeConfidentiality.pdf>.



Under penalty of law for false swearing (*West Virginia Code* §61-5-3), it is hereby certified that the vendor affirms and acknowledges the information in this affidavit and is in compliance with the requirements as stated.

Vendor's Name: RIGHT Equipment
Authorized Signature: Edward C. Spangher Sec-Tre Date: 5-11-09



NEMA-4 rated corrosion-proof control panel for safe and reliable operation.

Hose connectors are designed for easy accessibility and quick installation; the connectors are clearly marked.




Filter pumps are easily accessible.

WLP Series recycle systems combine enhanced design with state-of-the-art technology to offer:

- Quality recycled wash-water without common odor problems.
- Easy operation and maintenance.
- Poly skid is constructed of hardened polymer to be non-corrosive. It can also be easily lifted and moved with a forklift from all four sides.

Auto backwash retro-fit kits available on page 32




WLP-20AB-0M10

Model #	Flow Rate	Media Filter	Cartridge Filter	Carbon Filter (Degassed)	Power Requirements	Air Required	Dimensions L x W x H	Shipping Weight
WLP-08-0M10	0-8 GPM	Custom Mix 350 lbs.	120 sq.ft.	170 lbs.	230V, 1Ø, 15 amps	-	6' x 5' x 52"	1,475 lbs.
WLP-20-0M10	0-20 GPM	Custom Mix 525 lbs.	450 sq.ft.	220 lbs.	230V, 1Ø, 18 amps	-	8' x 5' x 52"	2,050 lbs.
WLP-20AB-0M10*	0-20 GPM	Custom Mix 525 lbs.	-	220 lbs.	230V, 1Ø, 18 amps	60-100 PSI	8' x 5' x 52"	2,050 lbs.
WLP-30-0M10	0-30 GPM	Custom Mix 525 lbs.	450 sq.ft.	220 lbs.	230V, 1Ø, 25 amps	-	8' x 5' x 52"	2,100 lbs.
WLP-40-0M10	0-40 GPM	Custom Mix 900 lbs.	600 sq.ft.	300 lbs.	230V, 1Ø, 35 amps	-	(2) 8' x 5' x 60"	3,000 lbs.
WLP-40AB-0M10*	0-40 GPM	Custom Mix 900 lbs.	-	300 lbs.	230V, 1Ø, 35 amps	60-100 PSI	7' x 9' x 60"	3,100 lbs.

*Includes auto backwash

CLEANING EQUIPMENT & SERVICES, INC. *per Edouard*
 2036 LEE HIGHWAY SOUTH
 P. O. BOX 118
 CLOVERDALE, VA 24077
 (800) 344-4510
 FAX 540-992-5955



Recommended Mi-T-M Air Compressor AC1-HE02-05M1 for use with the auto backwash. Consult your Mi-T-M Authorized Dealer for specifications.

OK ✓

MARTIN

Product Specification

Product Category: Wash-water Treatment System

Model Number: WLP-20AB-0M10

Manufacturer: Mi-T-M Corporation, 8650 Enterprise Drive, Peosta, IA 52068, Phone: 800-367-6486.

Water Treatment System

1.0 General Description

The Water Treatment System will be designed to treat and recycle vehicle and equipment wash-water originating from a pressure washer, steam cleaner. The water treatment system will be mounted on a 5' by 8' poly skid and will include an inline strainer pump for feeding to the treatment system. The water treatment system will be no higher than 52". The water treatment system will include a corona discharge ozone generator and automated ORP and pH control systems for bacteria control, a stainless steel tank with a sloped bottom for easy sludge removal, a coalescing pack for oil removal, a multimedia filter with 20 micron filtering capability and an activated carbon filter. The water treatment system will be equipped to back wash automatically using timers. The water treatment system will be complete with water level control floats. All of the equipment in this section shall be supplied by a single supplier as a packaged system. The water treatment system shall be a WLP-20AB-0M10 Advanced Wash-Water Recycle System as manufactured by Mi-T-M Corporation, 8650 Enterprise Drive, Peosta, IA 52068, phone: 1-800-367-6486.

2.0 Performance

General. The wash-water treatment system shall be capable of treating and recycling pressure washer or steam cleaner water generated from the cleaning of vehicles, machinery or equipment. The water treatment system will:

- 2.1. Treat the water with up to 24 grams per day of ozone
- 2.2. Use a 30 degree sloped tank to capture settling solids
- 2.3. Remove from the water all physical particles down to 20 microns
- 2.4. Remove from the water all free oil droplets, 1 micron and larger (with the use of proper detergents)
- 2.5. Remove from the water trace amounts of a wide range of organics, such as; gasoline, diesel fuel, herbicides, pesticides
- 2.6. Process water up to 20 gallons per minute
- 2.7. Be capable of automatically adjusting the pH level of the water
- 2.8. Be capable of automatically treating the water with a sanitizing solution and sustaining a given level of sanitizer, as measured in millivolts.
- 2.9. Backwash filters automatically to reduce labor.

CLEANING EQUIPMENT & SERVICES, INC. *Right Equip.*
2036 LEE HIGHWAY SOUTH
P. O. BOX 118
CLOVERDALE, VA 24077
(800) 344-4510
FAX 540-992-5955

3.0 Equipment Description

- 3.1 **Electrical Requirements.** The system will be fully operational by the use of a 230 volt, single phase, 18 amp power source.
- 3.2 **Air Requirements.** The system requires 100 psi for auto backwash capability.
- 3.3 **Poly Skid.** The Water Treatment System will be pre-packaged, ready to install, and mounted on a 5' by 8' poly skid. The poly skid will be assembled with stainless steel fasteners. The poly skid shall have forklift cavities in all four sides for easy transport and placement of the system.
- 3.4 **Ozone Generator.** The ozone generator will use corona discharge technology to provide up to 24 grams per day of ozone to be injected into the wastewater.
- 3.5 **Water/Oil/Solids Separator.** The system will contain a stainless steel tank, at least 2.7 mm thick, with 3 chambers separated by double baffles and a 30 degree sloped bottom for sludge settling. The tank and the oil coalescing pack will constitute approximately 625 square feet of oil coalescing surface area. The tank will also provide an oil skimming port leading to an attached oil decanter, for easy handling and disposal of the oil.
- 3.6 **Control Panel.** The control panel will be constructed of a NEMA 4 housing. Conveniently displayed on the control panel will be controls for the system's power, filter pump, transfer pump, sump pump, backwashing, digital pH control system and digital ORP control system.
- 3.7 **Multimedia Filter.** The multimedia filter will consist of a custom mix of media capable of filtering down particulates to 20 microns.
- 3.8 **Carbon Filter.** The system will contain a backwashable filter containing granular activated carbon, up to 220 pounds degassed.
- 3.9 **Pressurized Container.** The system will contain a pressurized filtered water container that will provide between 30 and 50 psi treated water at up to 20 gallons per minute.
- 3.10 **Hose Connection Panel.** The system will have a connection panel which will contain connection points for: 1) outlet to pressure washer, 2) fresh water inlet, 3) rinse water outlet, 4) rain water overflow outlet.