



State of West Virginia
 Department of Administration
 Purchasing Division
 2019 Washington Street East
 Post Office Box 50130
 Charleston, WV 25305-0130

Request for Quotation

RFQ NUMBER
DEP13007

PAGE
1

ADDRESS CORRESPONDENCE TO ATTENTION OF
**CHUCK BOWMAN
 304-558-2157**

VENDOR

RFQ COPY
 TYPE NAME/ADDRESS HERE

SHIP TO

**ENVIRONMENTAL PROTECTION
 DEPT. OF
 OFFICE OF SPECIAL RECLAMATION
 601 57TH STREET SE
 CHARLESTON, WV
 25304 304-926-0499**

DATE PRINTED	TERMS OF SALE	SHIP VIA	F.O.B.	FREIGHT TERMS
11/14/2007				

BID OPENING DATE: **11/28/2007** BID OPENING TIME **01:30PM**

LINE	QUANTITY	UOP	CAT. NO.	ITEM NUMBER	UNIT PRICE	AMOUNT
				***** ADDENDUM NO. 2 *****		
				ADDENDUM ISSUED TO THE COAL X, INC. RECLAMATION PROJECT TO DISTRIBUTE THE PRE-BID SIGN-IN SHEETS AND THE Q/A RESULTING FROM THE 10/17/07 PRE-BID MEETING.		
				PLEASE SEE THE ATTACHED FOUR(4) PAGES.		
				BID DATE AND OPENING TIME REMAIN 11/28/07 AT 1:30 PM.		
				***** NO OTHER CHANGES *****		
0001	1	JB		962-73		
				RECLAMATION: RESTORATION OF LAND		

SEE REVERSE SIDE FOR TERMS AND CONDITIONS

SIGNATURE	TELEPHONE	DATE
TITLE	FEIN	ADDRESS CHANGES TO BE NOTED ABOVE

WHEN RESPONDING TO RFQ, INSERT NAME AND ADDRESS IN SPACE ABOVE LABELED 'VENDOR'

**GENERAL TERMS & CONDITIONS
REQUEST FOR QUOTATION (RFQ) AND REQUEST FOR PROPOSAL (RFP)**


1. Awards will be made in the best interest of the State of West Virginia.
2. The State may accept or reject in part, or in whole, any bid.
3. All quotations are governed by the *West Virginia Code* and the *Legislative Rules* of the Purchasing Division.
4. Prior to any award, the apparent successful vendor must be properly registered with the Purchasing Division and have paid the required \$125.00 registration fee.
5. All services performed or goods delivered under State Purchase Orders/Contracts are to be continued for the term of the Purchase Order/Contract, contingent upon funds being appropriated by the Legislature or otherwise being made available. In the event funds are not appropriated or otherwise available for these services or goods, this Purchase Order/Contract becomes void and of no effect after June 30.
6. Payment may only be made after the delivery and acceptance of goods or services.
7. Interest may be paid for late payment in accordance with the *West Virginia Code*.
8. Vendor preference will be granted upon written request in accordance with the *West Virginia Code*.
9. The State of West Virginia is exempt from federal and state taxes and will not pay or reimburse such taxes.
10. The Director of Purchasing may cancel any Purchase Order/Contract upon 30 days written notice to the seller.
11. The laws of the State of West Virginia and the *Legislative Rules* of the Purchasing Division shall govern all rights and duties under the Contract, including without limitation the validity of this Purchase Order/Contract.
12. Any reference to automatic renewal is hereby deleted. The Contract may be renewed only upon mutual written agreement of the parties.
13. **BANKRUPTCY:** In the event the vendor/contractor files for bankruptcy protection, this Contract may be deemed null and void, and terminated without further order.
14. **HIPAA Business Associate Addendum -** The West Virginia State Government HIPAA Business Associate Addendum (BAA), approved by the Attorney General, and available online at the Purchasing Division's web site (<http://www.state.wv.us/admin/purchase/vrc/hipaa.htm>) is hereby made part of the agreement. Provided that, the Agency meets the definition of a Covered Entity (45 CFR §160.103) and will be disclosing Protected Health Information (45 CFR §160.103) to the vendor.

INSTRUCTIONS TO BIDDERS

1. Use the quotation forms provided by the Purchasing Division.
2. **SPECIFICATIONS:** Items offered must be in compliance with the specifications. Any deviation from the specifications must be clearly indicated by the bidder. Alternates offered by the bidder as **EQUAL** to the specifications must be clearly defined. A bidder offering an alternate should attach complete specifications and literature to the bid. The Purchasing Division may waive minor deviations to specifications.
3. Complete all sections of the quotation form.
4. Unit prices shall prevail in cases of discrepancy.
5. All quotations are considered F.O.B. destination unless alternate shipping terms are clearly identified in the quotation.
6. **BID SUBMISSION:** All quotations must be delivered by the bidder to the office listed below prior to the date and time of the bid opening. Failure of the bidder to deliver the quotations on time will result in bid disqualifications.

SIGNED BID TO:

Department of Administration
Purchasing Division
2019 Washington Street East
Post Office Box 50130
Charleston, WV 25305-0130



Pre-Bid Conference SIGN IN SHEET

(Please print legibly)

Carl X 40-396

Request for Proposal No: DEP 13007

Date: 10/17/07

<u>Representative & Firm Name</u>	<u>Mailing Address</u>	<u>Telephone & Fax Number</u> <u>Email Address</u>
EX. <u>Chuck Bowman</u> Chuck Bowman WV State Purchasing Division	<u>PO Box 50130</u> <u>2019 Washington Street East</u> <u>Charleston, WV 25305</u>	T: <u>604-558-2157</u> F: <u>304-558-4115</u> Email: <u>cbowman@wvadmin.gov</u>
1. <u>Kevin O Bradford</u> Kevin Bradford Pineville Paving & Excavation	<u>P.O. Box 1290</u> <u>Pineville, WV 24874</u>	T: <u>304-732-8303</u> F: <u>304-732-7855</u> Email: <u>KDBPPE@AOL.COM</u>
2. <u>Joe Tucker</u> Ulton Const. Co. Inc.	<u>P.O. Box 39</u> <u>DUNNAX W.V.</u> <u>25064</u>	T: <u>304-744-4627</u> F: <u>304-744-4626</u> Email: <u>UCCI@EARTH2.NET</u>
3. <u>Doug Vincent</u> Doug Vincent Breakaway Inc.	<u>1075 Old Turnpike Rd</u> <u>Sutton, WV 26601</u>	T: <u>765-5317</u> F: <u>765-5389</u> Email: <u>BREAKAWAY-INC@NET.EON.NET</u>
4. <u>Mary Long</u> Gary Long McCurt & Son Const.	<u>270 Centralia Rd</u> <u>Sutton WV 26601</u>	T: <u>304 765-5288</u> F: <u>304 765-5293</u> Email:
5. <u>David H Bowman</u> DAVID H. BOWMAN GREEN MOUNTAIN COMPANY	<u>511 50th STREET</u> <u>Charleston WV</u> <u>25304</u>	T: <u>304-925-0253</u> F: <u>304 925 9230</u> Email: <u>Jody May @ AOL Com</u>
6. <u>Randy J Carpenter</u> Randy Carpenter Carpenter Reclamation	<u>PO Box 13015</u> <u>Sissonville, WV</u> <u>25350</u>	T: <u>304-984-1115</u> F: <u>984-2270</u> Email: <u>Rcarpnb2@aol.com</u>
7. <u>Robert Barnes</u> Robert Barnes Barnes EXC. INC.	<u>P.O. Box 13384</u> <u>Sissonville</u> <u>WV 25360</u>	T: <u>304-984-1725</u> F: <u>304-984-0074</u> Email:
<u>GEORGE FRESHOUR</u> George Freshour EAGLE EXCAVATION INC	<u>P.O. BOX 218</u> <u>KENNA</u> <u>WV 25248</u>	T: <u>(304) 372-4378</u> F: <u>(304) 372-4378</u> Email: <u>NONE</u>
8. <u>Mick Jones</u> Michael J Jones Barnett Const & Supplies	<u>PO. Box 9046</u> <u>Barnett WV</u> <u>25030</u>	T: <u>304 548-7004</u> F: <u>548-7133</u> Email: <u>barnett.const.@yahoo.com</u>

Please PRINT legibly. All information is essential to contact attendees in a timely manner. If possible, please provide a company business card.

**Pre-Bid Conference
SIGN IN SHEET**

003

Call X 40-376 (Please print legibly)

Request for Proposal No: DEP 13007

Date: 10/17/07

Representative & Firm
Name

Mailing Address

Telephone & Fax Number
Email Address

EX: Chuck Bowman
Chuck Bowman
WV State Purchasing Division

PO Box 50130
2019 Washington Street, East
Charleston, WV 25305

T: 304-558-2157
F: 304-558-4115
Email: cbowman@wvadmin.gov

1. LANCE E. SCHULTZ
HYDROTECH RECLAMATION
B & B TRANSIT
THOMPSON PUM

900 PINEGROVE RD.
SUNNERCO, WV 25567

T: 304-751-0576
F: 304-204-0083
Email: schultzlance@aol.com

2. Buz Tharp
Mtn. Enterprises

PO BOX 1779
PRESTONSPRING, KY

T: 606 874-9892
F: 77 874-8045
Email: btharp@mountain
companies.com

*Ad
Assess
W Supplier*

3. _____

T: _____
F: _____
Email: _____

4. _____

T: _____
F: _____
Email: _____

5. _____

T: _____
F: _____
Email: _____

6. _____

T: _____
F: _____
Email: _____

7. _____

T: _____
F: _____
Email: _____

8. _____

T: _____
F: _____
Email: _____

9. _____

T: _____
F: _____
Email: _____

Please PRINT legibly. All information is essential to contact attendees in a timely manner.
If possible, please provide a company business card.

The following questions were asked during the Pre-bid conference held on October 17, 2007, @ 10:00 am. The responses to these questions are also provided.

- 1) Q. Are 'as built' required when construction is complete?
A. Yes, as per the technical specifications under "Construction Stakeout."
- 2) Q. Do you have any wingwalls on this job?
A. Yes, as per the typical drawings provided in the bid package.
- 3) Q. Do we build wingwalls to pipe size?
A. Wingwalls are to be built according to the typical drawings provided in the bid package.
- 4) Q. Where does the berm go? Does it go on the outside? (As it pertains to the Site 1 Hatfield / McCoy trail regrade.)
A. Yes, as it is shown on the typical drawing in the bid package.
- 5) Q. Do you anticipate having to hammer rock to obtain grade? (As it pertains to Site 1 Hatfield / McCoy trail regrade.)
A. No, the trail surface is to be regraded with existing material to drain water away from the mine site. Filter fabric and stone will be placed on trail surface according to detail shown in bid package.
- 6) Q. Do we have to add stone to road? (Pertaining to the main access road that runs by sites 1 & 2.)
A. No, the old permit road has a rock base and only needs to be maintained so that equipment and supplies can get into work areas.
- 7) Q. What is the estimate for this job?
A. Just under \$590,000.
- 8) Q. Do we place the (drop inlet) box in front of mine seal? (Pertaining to site 1 at the mine seal.)
A. Yes, and extend the mine seal pipe directly into the box as it is shown in typical drawing.
- 9) Q. Does the road (access road to mine seal) get stone?
A. Yes, as listed in the scope of work and shown in typical drawings.
- 10) Q. Is the stone for the road (access road to mine seal) a bid item?
A. Yes, it is included in bid item for access road.
- 11) Q. Does line (6" HDPE DR17 pipe) go across the hollow? (Pertaining to Site 1 where the mine water conveyance pipe will be placed at intersection with trapezoidal channel #1.)
A. Yes, the line will be laid under the grouted riprap trapezoidal channel and across the hollow prior to turning down the hollow as it is shown on the drawings included in your bid package.

- 12) Q. Is there a 90° connection in the pipe (6" HDPE DR 17) or does it sweep around the curve? (Pertaining to the same location as in question 11.)
A. We prefer that the pipe sweep around the curve as shown in the typical drawing enclosed in your bid package.
- 13) Q. Are we standing at the head of Pond 4? (Site2 treatment site)
A. Yes, as shown on the typical drawings provided.
- 14) Q. About clearing this site (Site 2 treatment site), what do we do with trees and stumps? Do we wind row or burn them?
A. As of the last meeting with the property owner, he did not want the timber, but in case he changes his mind, we will wind row the trees where there would be easy access in case he wants to sell the trees. The stumps will be disposed of properly.
- 15) Q. Do you anticipate filling area of pond(s)? (Site 2 treatment site)
A. Yes, raw water pond area will require some fill and excavation of other ponds should provide fill material as well as other possible borrow area adjacent to site. Construction stakeout is critical on this area to assure proper flow through treatment system.
- 16) Q. Do you have elevations for starting and ending points? (Site 2 treatment site)
A. Yes, we ran elevations for our design to confirm that we could make the system work, but these elevations are in our field notes only and started from an assumed elevation. You will be required to complete the construction stakeout prior to and during construction to ensure proper system functioning. That is why we require construction stakeout and why we feel that it is important.
- 17) Q. Did you core drill for depth of rock? (Site 2 treatment site)
A. No, we did not have that capability.
- 18) Q. Can we "shoot" on this site if we need to? (Site 2 treatment site)
A. Yes, if needed.
- 19) Q. The (4100 linear feet of 6" HDPE DR17) pipe gets buried or laid on top of the ground?
A. It gets buried to 24" as shown in the typical drawings.
- 20) Q. Do you have a size on the pond? (Site 3 wetlands area)
A. No, the wetland will be constructed to the size of the pre-existing wetland area as you see here on the ground.