



LEGEND

- CHR — EXISTING CHILLED WATER RETURN TO REMAIN
- CHS — EXISTING CHILLED WATER SUPPLY TO REMAIN
- EXISTING CONDENSING WATER RETURN TO BE REMOVED
- EXISTING CONDENSING WATER SUPPLY TO BE REMOVED
- EXISTING CHILLED WATER RETURN TO BE REMOVED.
- EXISTING CHILLED WATER SUPPLY TO BE REMOVED.
- EXISTING EQUIPMENT AND RELATED PIPING, DUCTWORK, ETC. TO BE REMOVED/SALVAGED.
- EXISTING EQUIPMENT TO REMAIN. SOME PIPING FROM SYSTEM MAY BE REMOVED AND CAPPED. SALVAGE REMOVED PORTION OF PIPE.
- KEY NOTE
- STOP POINT OF DEMOLITION WORK ON SYSTEM
- EXISTING WALL TO REMAIN

PLAN NOTES:

- | | | | |
|--|--|--|--|
| <p>1. CARRIER MOD. # DG6162CE WATER CHILLER TO BE REMOVED.</p> <p>2. CARRIER MOD. # DG6162CE WATER CHILLER TO BE REMOVED.</p> <p>3. CUTLER-HAMMERCONTROL CABINET TO BE REMOVED.</p> <p>4. CUTLER-HAMMERCONTROL CABINET TO BE REMOVED.</p> <p>5. EXISTING MCC TO REMAIN</p> <p>6. MARATHON ELECTRIC CHILLER PUMP MOD. # 5KXA326AN223V TO BE REMOVED</p> | <p>7. GENERAL ELECTRIC CHILLER PUMP MOD. # 5KXA326AN223V TO BE REMOVED</p> <p>8. CHWS PIPE TO BE CUT AND CAPPED</p> <p>9. MARATHON ELECTRIC CHILLER MOTOR W/PUMP MOD. # DF145TTDR7927ACW TO BE REMOVED</p> <p>DAYTON CHILLER MOTOR W/PUMP MOD # 3N657A TO BE REMOVED</p> <p>10. ELECTRIC WATER HEATER PATTERSON KELLEY CO. MOD. # 144B1-16B TO BE REMOVED</p> <p>11. CTWS PIPE TO BE REMOVED AT WALL</p> | <p>12. CHWR/CHWS PIPE TO BE REMOVED</p> <p>13. TRANE 60 TON CHILLER MOD. # CRHE600C3AOPOR2C2BO TO BE REMOVED</p> <p>14. CTWS PIPE TO BE CUT AND CAPPED AT SUPPORTS(near wall)</p> <p>15. CHWR PIPE TO BE CUT AND CAP AT VALVE.</p> <p>16. GENERAL ELECTRIC CHILLER PUMP MOD. # 5KXA326AN223V TO BE REMOVED.</p> <p>17. MARATHON ELECTRIC CHILLER PUMP MOD. # EC256TTDR7060DBW TO BE REMOVED.</p> | <p>18. DISCONNECT POWER & REMOVE CONDUIT & CABLE BETWEEN CHILLER & CONTROL CAB.</p> <p>19. DISCONNECT POWER & REMOVE CONDUIT & WIRING BETWEEN EQUIPMENT & MCC.</p> <p>20. EXISTING CHILLER WATER PUMPS TO REMAIN.</p> <p>21. DISCONNECT ELECTRICAL POWER TO NEAREST POWER PANEL</p> <p>22. DISCONNECT & REMOVE EXISTING CONTROL.</p> |
|--|--|--|--|

STATE OF WEST VIRGINIA
 DEPARTMENT OF
 ADMINISTRATION
 GENERAL SERVICES DIVISION
 CHARLESTON, WEST VIRGINIA

LOCATION:
WEST VIRGINIA STATE CAPITOL

BUILDING:
BUILDING 1

PROJECT:
EQUIPMENT REMOVAL

DRAWING TITLE: CHILLER REMOVAL			DRAWING NO: EQ-B1-BR
DRAWN BY: BMG	SCALE: NONE	DATE: 05/21/07	CAD PATH SEQUENCE: 123456789
Drawing Approved By: Scott Mason			