



- A. 3'-0" X 3'-0" ROOF HATCH W/ INSULATED COVER & WALLS.
- B. 2 3"x5"x1/4" L.L.V. EA. MAY AROUND ROOF OPENING. WELD IN PLACE TO CARRY ROOF DECK. PROVIDE TREATED 2x6 CONT. BLOCKING AT PERIMETER TO SUPPORT HATCH. INSTALL 4" CANT STRIP ABOVE INSULATION.
- C. 3-1/2" LIGHT GAGE METAL FRAMING WITH 3/8" PAINTED DRYWALL AROUND THREE SIDES OF HATCH OPENING. RETURN DRYWALL UP OUTSIDE EDGE TO SUPPORT CEILING TRIM.
- D. CONSTRUCT LADDER WITH 3/8" STEEL PLATE SIDE BARS AND 1" ϕ PIPE RUNGS. SUPPORT WITH 3/8" BENT PLATE SUPPORTS WELDED TO LADDER AND ANCHORED TO WALL WITH 1/2" DIA. EXPANSION ANCHOR BOLTS.
- E. EXISTING "ACT" CEILING TO REMAIN. CUT OUT GRID AS REQUIRED AND PROVIDE MATCHING EDGE STRIPS AT ACCESS WALL.

BUILDING 15

HATCH DETAIL