

Swanke Hayden Connell Ltd.
Swanke Hayden Connell & Partners, LLP
295 Lafayette Street, New York, New York 10012
Phone 212 225 9696, Fax 212 219 0059

Structural Engineer:


CAS Structural Engineering, Inc.
P.O. Box 469
Alum Creek, WV 25003

Metal Conservator:

Keilick Conservation, LLC
319 10th Road
Oreland PA 19073

This is a violation of the law to alter this document in hard copy or electronic format (the "document") in any way. Use or modifications to this document is at the sole risk and liability of the user. The user shall to the fullest extent of the law hold SWACK harmless from any claims, liabilities or damages including legal fees that may be incurred as a result of any unauthorized or improper use or modification of this document.

Key Plan





No.	Date:	Revision:
-	06-08-07	ISSUED FOR BID
-	07-05-07	ISSUED FOR RE-BID
△	09-27-07	ADDENDUM #4

STATE OF WEST VIRGINIA
DEPARTMENT OF ADMINISTRATION
DIVISION OF GENERAL SERVICES
CHARLESTON, WEST VIRGINIA

LOCATION: Charleston, West Virginia
SUBJECT: West Virginia State Capitol
PROJECT: Masonry Cleaning & Repair Project

ISSUING NO.: A-501
DATE: 06-08-07
SCALE: AS NOTED



3 FULL SCALE
SE 03: SEALANT REPLACEMENT AT VERTICAL CORNER CRACK

EXISTING CONSTRUCTION TO REMAIN
SEALANT DEPTH (AT MIPPOINT)
JOINT WIDTH
REMOVE EXISTING SEALANT AND/OR MORTAR AS INDICATED IN DETAIL PO 02
BACKER ROD
EXISTING SOUND MORTAR

SEALANT DEPTH & BACKER ROD DIAMETER SHALL BE BASED ON THE FOLLOWING TABLE:

JOINT WIDTH	3/8"	1/2"	5/8"	3/4"	7/8"	1"	1 1/4"	1 1/2"
SEALANT DEPTH	1/4"	1/4"	1/4"	1/4"-3/8"	3/8"-1/2"	3/8"-1/2"	3/8"-1/2"	1/2"
BACKER ROD DIAMETER	3/8"	1/2"	5/8"	3/4"	1"	1 1/4"	1 1/4"	2"

