



State of West Virginia
 Department of Administration
 Purchasing Division
 2019 Washington Street East
 Post Office Box 50130
 Charleston, WV 25305-0130

Request for Quotation

RFQ NUMBER
 DEP14606

PAGE
 1

ADDRESS CORRESPONDENCE TO ATTENTION OF:
 CHUCK BOWMAN
 304-558-2157

VENDOR

RFQ COPY
 TYPE NAME/ADDRESS HERE

SHIP TO

ENVIRONMENTAL PROTECTION
 DEPARTMENT OF
 OFFICE OF AML&R
 601 57TH STREET SE
 CHARLESTON, WV
 25304 304-926-0499

DATE PRINTED	TERMS OF SALE	SHIP VIA	F.O.B.	FREIGHT TERMS
04/27/2009				

BID OPENING DATE: 05/12/2009 BID OPENING TIME 01:30PM

LINE	QUANTITY	UOP	CAT NO.	ITEM NUMBER	UNIT PRICE	AMOUNT
				ADDENDUM NO. 1		
				ADDENDUM ISSUED FOR THE PAINT CREEK WATERSHED RESTORATION PROJECT TO DISTRIBUTE THE SIGN-IN SHEETS, THE Q/A, THE REVISED SPECIFICATIONS, AND A REVISED DETAIL DRAWING RESULTING FROM THE 04/08/09 MANDATORY PRE-BID MEETING.		
				BID OPENING DATE & TIME ARE EXTENDED FROM 05/07/09 TO 05/12/09 AT 1:30 PM.		
				***** NO OTHER CHANGES *****		
001	1	JB		962-73		
				RECLAMATION: RESTORATION OF LAND & OTHER PROPERTIES		
				***** THIS IS THE END OF RFQ DEP14606 ***** TOTAL: _____		

SEE REVERSE SIDE FOR TERMS AND CONDITIONS

SIGNATURE	TELEPHONE	DATE
TITLE	FEIN	ADDRESS CHANGES TO BE NOTED ABOVE

WHEN RESPONDING TO RFQ, INSERT NAME AND ADDRESS IN SPACE ABOVE LABELED 'VENDOR'

GENERAL TERMS & CONDITIONS
REQUEST FOR QUOTATION (RFQ) AND REQUEST FOR PROPOSAL (RFP)

1. Awards will be made in the best interest of the State of West Virginia.
2. The State may accept or reject in part, or in whole, any bid.
3. All quotations are governed by the *West Virginia Code* and the *Legislative Rules* of the Purchasing Division.
4. Prior to any award, the apparent successful vendor must be properly registered with the Purchasing Division and have paid the required \$125 fee.
5. All services performed or goods delivered under State Purchase Order/Contracts are to be continued for the term of the Purchase Order/Contracts, contingent upon funds being appropriated by the Legislature or otherwise being made available. In the event funds are not appropriated or otherwise available for these services or goods, this Purchase Order/Contract becomes void and of no effect after June 30.
6. Payment may only be made after the delivery and acceptance of goods or services.
7. Interest may be paid for late payment in accordance with the *West Virginia Code*.
8. Vendor preference will be granted upon written request in accordance with the *West Virginia Code*.
9. The State of West Virginia is exempt from federal and state taxes and will not pay or reimburse such taxes.
10. The Director of Purchasing may cancel any Purchase Order/Contract upon 30 days written notice to the seller.
11. The laws of the State of West Virginia and the *Legislative Rules* of the Purchasing Division shall govern all rights and duties under the Contract, including without limitation the validity of this Purchase Order/Contract.
12. Any reference to automatic renewal is hereby deleted. The Contract may be renewed only upon mutual written agreement of the parties.
13. **BANKRUPTCY:** In the event the vendor/contractor files for bankruptcy protection, this Contract may be deemed null and void, and terminated without further order.
14. **HIPAA BUSINESS ASSOCIATE ADDENDUM:** The West Virginia State Government HIPAA Business Associate Addendum (BAA), approved by the Attorney General, and available online at the Purchasing Division's web site (<http://www.state.wv.us/admin/purchase/vrc/hipaa.htm>) is hereby made part of the agreement. Provided that, the Agency meets the definition of a Cover Entity (45 CFR §160.103) and will be disclosing Protected Health Information (45 CFR §160.103) to the vendor.
15. **WEST VIRGINIA ALCOHOL & DRUG-FREE WORKPLACE ACT:** If this Contract constitutes a public improvement construction contract as set forth in Article 1D, Chapter 21 of the West Virginia Code ("The West Virginia Alcohol and Drug-Free Workplace Act"), then the following language shall hereby become part of this Contract: "The contractor and its subcontractors shall implement and maintain a written drug-free workplace policy in compliance with the West Virginia Alcohol and Drug-Free Workplace Act, as set forth in Article 1D, Chapter 21 of the West Virginia Code. The contractor and its subcontractors shall provide a sworn statement in writing, under the penalties of perjury, that they maintain a valid drug-free work place policy in compliance with the West Virginia and Drug-Free Workplace Act. It is understood and agreed that this Contract shall be cancelled by the awarding authority if the Contractor: 1) Fails to implement its drug-free workplace policy; 2) Fails to provide information regarding implementation of the contractor's drug-free workplace policy at the request of the public authority; or 3) Provides to the public authority false information regarding the contractor's drug-free workplace policy."

INSTRUCTIONS TO BIDDERS

1. Use the quotation forms provided by the Purchasing Division.
2. **SPECIFICATIONS:** Items offered must be in compliance with the specifications. Any deviation from the specifications must be clearly indicated by the bidder. Alternates offered by the bidder as **EQUAL** to the specifications must be clearly defined. A bidder offering an alternate should attach complete specifications and literature to the bid. The Purchasing Division may waive minor deviations to specifications.
3. Complete all sections of the quotation form.
4. Unit prices shall prevail in case of discrepancy.
5. All quotations are considered F.O.B. destination unless alternate shipping terms are clearly identified in the quotation.
6. **BID SUBMISSION:** All quotations must be delivered by the bidder to the office listed below prior to the date and time of the bid opening. Failure of the bidder to deliver the quotations on time will result in bid disqualifications: Department of Administration, Purchasing Division, 2019 Washington Street East, P.O. Box 50130, Charleston, WV 25305-0130

MANDATORY PRE-BID SIGN-IN ATTENDANCE SHEET

PRINT LEGIBLY

RFQ # : DEP14606 Bid Date: 5/7/09
 Project: Paint Creek Watershed Restoration Pre-Bid Date: 4/8/09

Name : Doug Vincent
 Company: BREAKAWAY INC
 Address: 105 Old Turnpike Rd
Sutton WV 26601
 Phone #: 765-5317
 Fax #: 765-5389
 Email : _____

Name : George Caldwell
 Company: Courty Eng
 Address: P.O. Box 5589
BECKLEY, WV 25801
GEORGE@SUDORNLINKMAIL.COM
 Phone#: _____
 Fax #: _____
 Email : _____

Name : GEORGE FRESHOUR
 Company: EAGLE EXCAVATION INC.
 Address: P.O. BOX 218
KENNA, WV
25248
 Phone #: (304) 372-4378
 Fax #: (304) 372-4378
 Email : ADAM

Name : Bob Cow Terbury
 Company: BTB TRANSIT
 Address: 316 NEW RIVER DRIVE
Becky WVA 25801
 Phone#: 678-9388 - 255-2505
 Fax #: _____
 Email : Bob_Cowterbury@gmail.com

Name : Robert Barnes
 Company: Barnes Exc. Inc.
 Address: P.O. Box 13384
Sissonville
WV. 25360
 Phone #: 304-984-1725
 Fax #: 304-984-0074
 Email : none

Name : Adrian Hoosier
 Company: Carter Development Inc
 Address: 500-B Justice Park
Site 3
Hurricane WV 25560
 Phone#: 304-757-4500
 Fax #: " " 4501
 Email : DAH@Hoosierfirm.com

Name : Mike Jenkins
 Company: AQUA Fix Sys. Inc.
 Address: 301 MAPLE LANE
Kingwood WV 26537
 Phone #: 304-329-1056
 Fax #: 304-329-1217
 Email : mjj@aquafix.com

Name : Harrison C Bowman
 Company: Green Mountain Co.
 Address: 511 50th St.
Charleston, WV, 25304
 Phone#: 304-925-0253
 Fax #: 304-925-9230
 Email : Jody May @Aol.com

MANDATORY PRE-BID SIGN-IN ATTENDANCE SHEET

PRINT LEGIBLY

RFQ # : DEP 14606
Project: Paint Creek Watershed Restoration

Bid Date: 5/7/09
Pre-Bid Date: 4/8/09

Name : Shamuel C. Nazzari, Jr
Company: HAZARD EX. & TRUCKING CO
Address: P.O. Box 398
Kimball, W.VA 24853
Phone #: 304/585-7060
Fax #: 585-7062
Email : shazzar@citilink.net

Name : Roger L. Collins Jr
Company: Collins Building & Contracting Inc
Address: 2406 - Corby - Corra Rd
Flatwoods, WV
26021
Phone #: 304-765-3521
Fax #: 304-765-3521
Email : _____

Name : Randy Carpenter
Company: Carpenter Reclamation
Address: P.O. Box 13015
Seasonville, WV
25360
Phone #: 304-984-1115
Fax #: 984-2770
Email : _____

Name : Eugene A. McKnight
Company: The McKnight Co.
Address: 315 - 7th St
Roanoke, WV 25962
Phone #: 304-438-5215
Fax #: 304-438-5215
Email : _____

Name : DON STAMM
Company: LIME DOZER CONSULTANTS
Address: 190 B, MAIN ST. STATE MVV
P.O. Box 2184 CHS. 26301
Chiefton
Phone #: 304-669-5616
Fax #: 304-792-1037
Email : STAMM3@Verizon.net

Name : Dale Thayer
Company: Thayer Const Co Inc
Address: PO Box 13279 Charlotte
WV 25360
Phone #: 304 984 2299
Fax #: 304 984 2334
Email : _____

Name : Michael Patrick
Company: Tom Pat Const.
Address: 518 Johnson Ave
Briarport WV
26330
Phone #: 304-844-0051
Fax #: _____
Email : Tompat Construction + Verizon
.NET

Name : _____
Company: _____
Address: _____
Phone #: _____
Fax #: _____
Email : _____

Req # DEP14606
Paint Creek Watershed Restoration
Addendum #1

REVISIONS TO SPECIFICATIONS

Special Provision III – Scope of Work – Delete “Construction of limestone doser and placement of hydrated lime;” Add “Construction of limestone doser and placement of calcium oxide;”

Specification 8.2.5 Calcium Oxide – Add: “ The calcium oxide (CaO) shall be pulverized and shall consist of a purity of a minimum of 95% CaO.

Add Specification 8.2.6 –“ Random Backfill: Random backfill shall be as specified in Section 604.8 of the WVDOT Standard Specifications for Roads and Bridges. The backfill considered for use must first be visually approved by the WVDEP.” (See attached detail drawing).

Specification 8.3.3 Feed Line/Cleanouts – Add: The feedline shall be bedded and backfilled as according to the details shown on the attached drawings and as approved by the WVDEP. The random material backfill shall be placed in loose lifts not exceeding twelve (12) inches and each lift compacted. Compaction of the material shall not be to less than 90% of maximum dry density as determined in accordance with ASTM D-698. The Contractor shall use special care in placing and compacting backfill maaterial to avoid damaging pipe. Frequency of density tests shall be one test per lift or as requested by the WVDEP.”

Specification 8.3.1 – Dosing unit/ Silo – Add: “The dosing unit must be capable of dispensing various treatment products. The dosing unit shall not require an electrical supply to function properly.”

DRAWINGS

See attached drawing.

Req # DEP14606
Paint Creek Watershed Restoration
Addendum #1

QUESTIONS AND ANSWERS

Questions asked at the Spring Branch (Limestone Sand Dump) Site

Q: Is there an excavation yardage for this job?

A: No, there is no pay item for excavation. Excavation is considered incidental to items requiring excavation activities.

Q: How far back does the excavation have to go?

A: The proposed excavation is shown on the drawings.

Q: Basically are you making room for a tandem truck?

A: The Contractor will be responsible for the initial placement of limestone sand for this project as outlined in the construction specifications and shown on the drawings. The size of the truck that will be used to dump limestone sand in the future will be under a separate contract.

Q: Is this site in Fayette or Kanawha County?

A: The Spring Branch (Limestone Sand Dump) Site is in Fayette County. The Tenmile Fork (Doser) Site is in Kanawha County as shown on the drawings.

Q: Does the limestone sand have to come out of Germany Valley?

A: The source must supply limestone sand that meets the required specifications.

Q: How much of the road gets stoned?

A: The outline of the proposed stone placement is shown on the drawings.

Q: Is this the only site that requires a PLC Permit?

A: No, both sites require a PLC Permit.

Q: Does the PLC permit have restrictions on working in streams for certain months?

A: Yes. The Contractor will be responsible for finding out those restrictions.

Req # DEP14606
Paint Creek Watershed Restoration
Addendum #1

Q: Does the stone on the road have to be sandstone?

A: No. The only requirement for road stone is 1 ½" crusher run meeting the construction specifications and details shown on the drawings.

Questions asked at the Ten Mile Fork (Doser) Site

Q: Is the HPDE feed line fused?

A: Yes.

Q: What size is the feed line?

A: The line is 4" diameter HDPE as outlined in the construction specifications and shown on the drawings.

Q: The Contractor is to allow the doser unit to work for one week before the WVDEP will approve installation. Does that relieve the Contractor of his 1 year warranty period?

A: No.

Q: Is Aquafix an approved equal?

A: An Aquafix doser will be considered an approved equal, however, no additional payment will be paid to the Contractor for any modifications or changes in order to accommodate placement of the Aquafix doser. Example: Concrete pad may need to be modified, side walls of storage tank may be modified, etc.

Q: The feed line is to be beneath the side stream?

A: Yes. The feed line crosses the side stream as shown on the drawings.

Q: Is the feed line going to be on a constant grade?

A: The grade will be as shown on the drawings.

Req # DEP14606
Paint Creek Watershed Restoration
Addendum #1

Questions asked at the intake unit area

Q: Has anybody ever tested this soil to see what is under here?

A: No. Drilling or testing was not performed.

Q: Can we dig a hole and find out?

A: The Contractors must obtain landowners permission to perform any excavation or drilling activities.


Q: What type material goes around the feedline?

A: See the attached drawing.

Q: Is the feedline 4" plastic?

A: The feedline is 4" high density polyethylene as outlined in the specifications.

Req # DEP14606
Paint Creek Watershed Restoration
Addendum #1



PIPE BEDDING DETAIL

N.T.S.