



State of West Virginia
 Department of Administration
 Purchasing Division
 2019 Washington Street East
 Post Office Box 50130
 Charleston, WV 25305-0130

Request for Quotation

RFQ NUMBER
 DEFK10003

PAGE
 1

ADDRESS CORRESPONDENCE TO ATTENTION OF:
 JOHN ABBOTT
 304-558-2544

VENDOR

RFQ COPY
 TYPE NAME/ADDRESS HERE

SHIP TO

DIV ENGINEERING & FACILITIES
 NATIONAL GUARD ARMORY
 240 ARMY ROAD
 KINGWOOD, WV
 26537 341-6368

DATE PRINTED	TERMS OF SALE	SHIP VIA	F.O.B.	FREIGHT TERMS
09/09/2009				

BID OPENING DATE: 09/17/2009 BID OPENING TIME: 01:30PM

LINE	QUANTITY	UOP	CAT. NO.	ITEM NUMBER	UNIT PRICE	AMOUNT
ADDENDUM #04						
THIS ADDENDUM IS ISSUED TO CLARIFY THE SPECIFICATIONS, PREVIOUS ADDENDUMS, AND OTHER ISSUES AS SPECIFIED IN THE ATTACHED DOCUMENTATION.						
NO ADDITIONAL QUESTIONS WILL BE ACCEPTED.						
NO ADDITIONAL ADDENDUMS ARE ANTICIPATED TO BE ISSUED.						
0001	1	LS		968-20		
BUILDING CONSTRUCTION						
***** THIS IS THE END OF RFQ DEFK10003 ***** TOTAL:						

SEE REVERSE SIDE FOR TERMS AND CONDITIONS

SIGNATURE	TELEPHONE	DATE
TITLE	FEIN	ADDRESS CHANGES TO BE NOTED ABOVE

WHEN RESPONDING TO RFQ, INSERT NAME AND ADDRESS IN SPACE ABOVE LABELED 'VENDOR'

**GENERAL TERMS & CONDITIONS
REQUEST FOR QUOTATION (RFQ) AND REQUEST FOR PROPOSAL (RFP)**

1. Awards will be made in the best interest of the State of West Virginia.
2. The State may accept or reject in part, or in whole, any bid.
3. All quotations are governed by the *West Virginia Code* and the *Legislative Rules* of the Purchasing Division.
4. Prior to any award, the apparent successful vendor must be properly registered with the Purchasing Division and have paid the required \$125 fee.
5. All services performed or goods delivered under State Purchase Order/Contracts are to be continued for the term of the Purchase Order/Contracts, contingent upon funds being appropriated by the Legislature or otherwise being made available. In the event funds are not appropriated or otherwise available for these services or goods, this Purchase Order/Contract becomes void and of no effect after June 30.
6. Payment may only be made after the delivery and acceptance of goods or services.
7. Interest may be paid for late payment in accordance with the *West Virginia Code*.
8. Vendor preference will be granted upon written request in accordance with the *West Virginia Code*.
9. The State of West Virginia is exempt from federal and state taxes and will not pay or reimburse such taxes.
10. The Director of Purchasing may cancel any Purchase Order/Contract upon 30 days written notice to the seller.
11. The laws of the State of West Virginia and the *Legislative Rules* of the Purchasing Division shall govern all rights and duties under the Contract, including without limitation the validity of this Purchase Order/Contract.
12. Any reference to automatic renewal is hereby deleted. The Contract may be renewed only upon mutual written agreement of the parties.
13. **BANKRUPTCY:** In the event the vendor/contractor files for bankruptcy protection, the State may deem this contract null and void, and terminate such contract without further order.
14. **HIPAA BUSINESS ASSOCIATE ADDENDUM:** The West Virginia State Government HIPAA Business Associate Addendum (BAA), approved by the Attorney General, and available online at the Purchasing Division's web site (<http://www.state.wv.us/admin/purchase/vrc/hipaa.htm>) is hereby made part of the agreement. Provided that, the Agency meets the definition of a Cover Entity (45 CFR §160.103) and will be disclosing Protected Health Information (45 CFR §160.103) to the vendor.
15. **WEST VIRGINIA ALCOHOL & DRUG-FREE WORKPLACE ACT:** If this Contract constitutes a public improvement construction contract as set forth in Article 1D, Chapter 21 of the West Virginia Code ("The West Virginia Alcohol and Drug-Free Workplace Act"), then the following language shall hereby become part of this Contract: "The contractor and its subcontractors shall implement and maintain a written drug-free workplace policy in compliance with the West Virginia Alcohol and Drug-Free Workplace Act, as set forth in Article 1D, Chapter 21 of the West Virginia Code. The contractor and its subcontractors shall provide a sworn statement in writing, under the penalties of perjury, that they maintain a valid drug-free work place policy in compliance with the West Virginia and Drug-Free Workplace Act. It is understood and agreed that this Contract shall be cancelled by the awarding authority if the Contractor: 1) Fails to implement its drug-free workplace policy; 2) Fails to provide information regarding implementation of the contractor's drug-free workplace policy at the request of the public authority; or 3) Provides to the public authority false information regarding the contractor's drug-free workplace policy."

INSTRUCTIONS TO BIDDERS

1. Use the quotation forms provided by the Purchasing Division.
2. **SPECIFICATIONS:** Items offered must be in compliance with the specifications. Any deviation from the specifications must be clearly indicated by the bidder. Alternates offered by the bidder as **EQUAL** to the specifications must be clearly defined. A bidder offering an alternate should attach complete specifications and literature to the bid. The Purchasing Division may waive minor deviations to specifications.
3. Complete all sections of the quotation form.
4. Unit prices shall prevail in case of discrepancy.
5. All quotations are considered F.O.B. destination unless alternate shipping terms are clearly identified in the quotation.
6. **BID SUBMISSION:** All quotations must be delivered by the bidder to the office listed below prior to the date and time of the bid opening. Failure of the bidder to deliver the quotations on time will result in bid disqualifications: Department of Administration, Purchasing Division, 2019 Washington Street East, P.O. Box 50130, Charleston, WV 25305-0130

September 9, 2009

ADDENDUM NO. 4

RE: Joint Interagency Training and Education Center #540105A
West Virginia Army National Guard
Camp Dawson, West Virginia

TO: Prospective Bidders

FROM: AECOM Design

This Addendum forms a part of the Contract Documents and modifies the original Bidding Documents.

ATTACH THIS ADDENDUM TO THE FRONT COVER OF THE PROJECT MANUAL AND ACKNOWLEDGE RECEIPT OF THIS ADDENDUM IN THE SPACE PROVIDED ON THE BID FORM.

A. CLARIFICATIONS

1. Refer to Drawing G060:

The "Base Bid" items A-M on sheet G060 are included to group major site design features by location. These items do not correspond to the Bid Form. For bidding purposes refer to Bid Forms Section I, II, & III.

2. Refer to Drawings B-S122 through B-S124c

What is "NW" Concrete Topping?

NW concrete topping is normal weight concrete topping.

Issues with live load specifications. As currently stated could create camber (ceiling) issues. Should be "Private Rooms and Corridors serving them 40 psf", Should be "Public Rooms and Corridors serving them 100 psf".

Sheet B-S001: The Live Loads shall be as follows:

Private Rooms and Corridors serving them.....40 psf

Public Rooms and Corridors serving them.....100 psf

In several areas plank spans are too long for 8" plank. For instance in Quad A there is area which spans 32'-10" (33'-4"). That area is questionable, especially if loading requirements remains the same. In Quad C Lounge area span is 33'-11". That will not work with 8". 10" plank will be required or break up span.

10" Precast Hollow Core Plank with 2" Normal Weight Concrete Topping shall be used at the following areas: Rooms 1007, 1008, 1009, 1010, 1016, 1017, 1018, 1019, 1095, 1096, 1097, 1098, 1104, 1105, 1106, 1107, 1133, 1148, 2007, 2008, 2009, 2010, 2016, 2017, 2018, 2019, 2098, 2099, 2100, 2101, 2107, 2108, 2109, 2110, 2143, 2158, 3007, 3008, 3009, 3010, 3016, 3017, 3018, 3019, 3100, 3101, 3102, 3103, 3109, 3110, 3111, 3112, 3145, 3160 and adjacent corridors.

What is the purpose of (2) #5 cont. in grouted cores? Sec. 5/S521. As far as we can see this is an unnecessary expensive overkill. We plan on excluding this detail.

The detail on 5/B-S521 has been revised to (1) #5 continuous in a grouted core in Addendum #1. This additional reinforcement is required to meet the peripheral tie requirements of the UFC 4-023-03, Jan. 2005; Design of Buildings to Resist Progressive Collapse.

END OF ADDENDUM