

## SOLE SOURCE DETERMINATION

The Purchasing Division has been requested to approve a sole source purchase for the commodity or service described below. Pursuant to West Virginia Code 5A-3-10c, the Purchasing Division is attempting to determine whether the commodity or service is a sole source procurement. If you believe your company meets the required experience and qualification criteria stated below, please e-mail the Purchasing Division Buyer at [Shelly.I.Murray@wv.gov](mailto:Shelly.I.Murray@wv.gov) with a copy to [Charles.A.Bowmanjr@wv.gov](mailto:Charles.A.Bowmanjr@wv.gov) to express your interest in the project. Please forward any and all information that will support your company's compliance with required qualification and eligibility criteria along with any other pertinent information relative to this project to the Purchasing Division no later than May 14, 2010.

**Requisition Number:** DRS100571

---

**Department/Agency:** Division of Rehabilitation Services

**Detailed Description of Project:** To provide an upgrade to an existing SimplexGrinnell Fire Alarm System in Building C of the WVDRS Complex located at Institute, WV. Upgrade includes parts, labor, system checkout with Fire Marshall and elevator inspectors, and one year warranty. Labor and materials to be provided:

(qty), part number, description: (1) 4009-9201, NAC Extender 120VAC, IDNET; (4) 2081-9288, Battery 12.7AZ; (28) 4099-9001, Manual Station-Single Action; (87) 4098-9714, Photo Sensor; (21) 4098-9733, Heat Sensor; (108) 4098-9832, SSD Adapter Plate; (10) 4098-9756, Duct Sensor Housing-4-Wire; (10) 2098-9797, Sampling tube 49"; (10) 2098-9806, Remote Test Station; (28) 4908-9127, Horn/Strobe Mc Red;(14) 4906-9101, Strobe MC Red; (42) 4905-9937, Skirt, Horn/Strobe Red; (10) 4090-9001, Supervised IAM; (1) 454727ARE, 14/2CSol OAS FPLP Red 1000'RL; (1) 454717ARE, 18/2C SOL OAS CMP/FPLP Red;(1) DPFA, DP Fire Alarm; (1) OPIM, OP Installation Materials; (32) DSGN Lab, Design Labor; (24) CAD Lab, Cad Labor; (40) Comm Lab, Commissioning Labor;

**Proposed Sole Source Vendor:** SimplexGrinnell

**Specific Eligibility Criteria:** Must be able to provide compatible software and hardware to upgrade an existing SimplexGrinnell fire alarm system.

**Specific Qualification Criteria:** Vendor must be an authorized seller and installer of Simplex Grinnell Fire Alarm Systems. 30 Day Installation upon receipt of P.O., Technical Support for Fire Marshall walkthrough, Ability to do changes as requested by the Fire Marshall or Elevator Inspectors to meet required code. Vendor must provide copy of Contractor's License, Public Liability Insurance Certificate, and be in compliance with WV Workers' Comp requirements.