



NOTES:

1. CONDUIT WILL BE SCHEDULE 40 PVC 2" DIAMETER.
2. HV - HIGH VOLTAGE (TO BE CENTER OF COLUMN)
3. LV - LOW VOLTAGE
4. ALL MEASUREMENTS MUST BE FIELD VERIFIED BY CONTRACTOR.