



State of West Virginia  
 Department of Administration  
 Purchasing Division  
 2019 Washington Street East  
 Post Office Box 50130  
 Charleston, WV 25305-0130

# Request for Quotation

RFQ NUMBER  
**DEP15306**

PAGE  
**1**

ADDRESS CORRESPONDENCE TO ATTENTION OF:  
**CHUCK BOWMAN**  
**304-558-2157**

**RFQ COPY**  
**TYPE NAME/ADDRESS HERE**

VENDOR

SHIP TO

**ENVIRONMENTAL PROTECTION**  
**DEPARTMENT OF**  
**OFFICE OF AML&R**  
**601 57TH STREET SE**  
**CHARLESTON, WV**  
**25304**                      **304-926-0499**

DATE PRINTED	TERMS OF SALE	SHIP VIA	F.O.B.	FREIGHT TERMS
03/14/2011				

BID OPENING DATE: **04/05/2011**                      BID OPENING TIME **01:30PM**

LINE	QUANTITY	UOP	CAT NO	ITEM NUMBER	UNIT PRICE	AMOUNT
<p>***** ADDENDUM NO. 1 *****</p> <p>ADDENDUM ISSUED FOR THE CHAUNCEY (MILLER) DRAINAGE PROJECT TO DISTRIBUTE THE PRE-BID SIGN-IN SHEETS, THE SPECIFICATION REVISIONS, Q/A, REVISED DRAWING, AND BORING LOGS AS A RESULT OF THE MANDATORY PRE-BID MEETING OF 03/03/2011.</p> <p>BID OPENING DATE &amp; TIME REMAIN UNCHANGED AS 04/05/2011 AT 1:30 PM.</p> <p>***** NO OTHER CHANGES *****</p>						
0001	1	JB		962-73		
<p>RECLAMATION: RESTORATION OF LAND &amp; OTHER PROPERTIES</p>						
<p>***** THIS IS THE END OF RFQ DEP15306 ***** TOTAL: _____</p>						

SEE REVERSE SIDE FOR TERMS AND CONDITIONS

SIGNATURE	TELEPHONE	DATE
-----------	-----------	------

TITLE	FEIN	ADDRESS CHANGES TO BE NOTED ABOVE
-------	------	-----------------------------------

WHEN RESPONDING TO RFQ, INSERT NAME AND ADDRESS IN SPACE ABOVE LABELED 'VENDOR'

## GENERAL TERMS & CONDITIONS REQUEST FOR QUOTATION (RFQ) AND REQUEST FOR PROPOSAL (RFP)

1. Awards will be made in the best interest of the State of West Virginia.
2. The State may accept or reject in part, or in whole, any bid.
3. Prior to any award, the apparent successful vendor must be properly registered with the Purchasing Division and have paid the required \$125 fee.
4. All services performed or goods delivered under State Purchase Order/Contracts are to be continued for the term of the Purchase Order/Contracts, contingent upon funds being appropriated by the Legislature or otherwise being made available. In the event funds are not appropriated or otherwise available for these services or goods this Purchase Order/Contract becomes void and of no effect after June 30.
5. Payment may only be made after the delivery and acceptance of goods or services.
6. Interest may be paid for late payment in accordance with the *West Virginia Code*.
7. Vendor preference will be granted upon written request in accordance with the *West Virginia Code*.
8. The State of West Virginia is exempt from federal and state taxes and will not pay or reimburse such taxes.
9. The Director of Purchasing may cancel any Purchase Order/Contract upon 30 days written notice to the seller.
10. The laws of the State of West Virginia and the *Legislative Rules* of the Purchasing Division shall govern the purchasing process.
11. Any reference to automatic renewal is hereby deleted. The Contract may be renewed only upon mutual written agreement of the parties.
12. **BANKRUPTCY:** In the event the vendor/contractor files for bankruptcy protection, the State may deem this contract null and void, and terminate such contract without further order.
13. **HIPAA BUSINESS ASSOCIATE ADDENDUM:** The West Virginia State Government HIPAA Business Associate Addendum (BAA), approved by the Attorney General, is available online at [www.state.wv.us/admin/purchase/vrc/hipaa.htm](http://www.state.wv.us/admin/purchase/vrc/hipaa.htm) and is hereby made part of the agreement. Provided that the Agency meets the definition of a Cover Entity (45 CFR §160.103) and will be disclosing Protected Health Information (45 CFR §160.103) to the vendor.
14. **CONFIDENTIALITY:** The vendor agrees that he or she will not disclose to anyone, directly or indirectly, any such personally identifiable information or other confidential information gained from the agency, unless the individual who is the subject of the information consents to the disclosure in writing or the disclosure is made pursuant to the agency's policies, procedures, and rules. Vendor further agrees to comply with the Confidentiality Policies and Information Security Accountability Requirements, set forth in <http://www.state.wv.us/admin/purchase/privacy/noticeConfidentiality.pdf>.
15. **LICENSING:** Vendors must be licensed and in good standing in accordance with any and all state and local laws and requirements by any state or local agency of West Virginia, including, but not limited to, the West Virginia Secretary of State's Office, the West Virginia Tax Department, and the West Virginia Insurance Commission. The vendor must provide all necessary releases to obtain information to enable the director or spending unit to verify that the vendor is licensed and in good standing with the above entities.
16. **ANTITRUST:** In submitting a bid to any agency for the State of West Virginia, the bidder offers and agrees that if the bid is accepted the bidder will convey, sell, assign or transfer to the State of West Virginia all rights, title and interest in and to all causes of action it may now or hereafter acquire under the antitrust laws of the United States and the State of West Virginia for price fixing and/or unreasonable restraints of trade relating to the particular commodities or services purchased or acquired by the State of West Virginia. Such assignment shall be made and become effective at the time the purchasing agency tenders the initial payment to the bidder.

I certify that this bid is made without prior understanding, agreement, or connection with any corporation, firm, limited liability company, partnership, or person or entity submitting a bid for the same material, supplies, equipment or services and is in all respects fair and without collusion or fraud. I further certify that I am authorized to sign the certification on behalf of the bidder or this bid.

### INSTRUCTIONS TO BIDDERS

1. Use the quotation forms provided by the Purchasing Division. Complete all sections of the quotation form.
2. Items offered must be in compliance with the specifications. Any deviation from the specifications must be clearly indicated by the bidder. Alternates offered by the bidder as **EQUAL** to the specifications must be clearly defined. A bidder offering an alternate should attach complete specifications and literature to the bid. The Purchasing Division may waive minor deviations to specifications.
3. Unit prices shall prevail in case of discrepancy. All quotations are considered F.O.B. destination unless alternate shipping terms are clearly identified in the quotation.
4. All quotations must be delivered by the bidder to the office listed below prior to the date and time of the bid opening. Failure of the bidder to deliver the quotations on time will result in bid disqualifications: Department of Administration, Purchasing Division, 2019 Washington Street East, P.O. Box 50130, Charleston, WV 25305-0130
5. Communication during the solicitation, bid, evaluation or award periods, except through the Purchasing Division, is strictly prohibited (W.Va. C.S.R. §148-1-6.6).

**Req # DEP 15306  
Chauncey (Miller) Drainage  
Addendum #1**

**REVISIONS TO SPECIFICATIONS**

ARTICLE II – BIDDING INFORMATION – 8.0 TIME OF COMPLETION AND LIQUIDATED DAMAGES – Add “The Contractor will have 120 days from the date of the Notice-to-Proceed to complete construction activities on the project. The \$250 per day liquidation damage clause will be in effect after the 120 days. However, the total performance period will be 365 days from the date of the Notice-to-Proceed for invoicing purposes.”

Specification 7.2.2 – Stone – Now reads “Rock for the splash pads shall consist of hard durable sandstone or limestone and shall have a d50 of 12-inches.” Revise to read “Rock for the splash pads and 24” diameter culvert outlet grouted rock riprap slope protection shall consist of hard durable sandstone or limestone and shall have a d50 of 12-inches.”

Specification 8.3 – Now reads “Any water discharged during mine seal installation shall meet minimum effluent standards as set forth by West Virginia Surface Mining Regulations.” Revise to read “Any water discharged during mine seal installation shall be treated to between a minimum ph of 6.0 to a maximum ph of 9.0.”

Add Specification 7.2.5 – Grout – Grout for the 24” diameter culvert outlet grouted rock riprap slope protection shall be as outlined in Specification 9.2.2 “Grout”.

Specification 7.3.2 – Add “Rock riprap shall be placed on the outslope of the 24” diameter culvert as outlined on the attached drawing. The stone shall be wet immediately before the grout is applied. The grout shall be worked thoroughly into the joints to achieve 100% penetration and completely fill the voids. The grout shall be kept damp by spraying with a fine mist of water every 2 hours during daylight hours for a period of 3 days or as approved by the WVDEP.”

Specification 7.4.2 – Pipe – Now reads “The method of measurement for installation of the pipe will be on a linear foot basis and shall include excavation, disposal of material and purchase and installation of pipe, backfill, drainage swale and repair of roadways.” Revise to read “The method of measurement for installation of the pipe will be on a linear foot basis and shall include excavation, disposal of material and purchase and installation of pipe, backfill, grouted rock riprap outlet slope protection, drainage swale and repair of roadways.”

**Req # DEP 15306  
Chauncey (Miller) Drainage  
Addendum #1**

**QUESTIONS AND ANSWERS**

Q: What do we do with the guy wires on the power pole at the toe of the slope? Do we cut the poplar trees and take out the stump that the wire is tied to?

A: If the power pole is in the way of the work and has to be moved, the Contractor is responsible to follow Special Provision XV "UTILITIES AND OTHER OBSTRUCTIONS". The trees that the guy wire is tied to will need to be cut but taking out the stumps may cause the slope above the slide area to become unstable so those stumps will be left in place.


Q: Is there outlet slope protection for the 24 inch diameter culvert?

A: Grouted rock riprap slope protection has been added.

Q: What is the height of the voids.

A: Bore logs are attached showing the top and bottom of voids.

SEE ATTACHED DRAWING



**PIPE OUTLET SLOPE PROTECTION**  
NTS

**REQ # DEP 15306  
CHAUNCEY (MILLER) DRAINAGE  
ADDENDUM #1**



TRIAD ENGINEERING, INC.  
ST. ALBANS & MORGANTOWN, WEST VIRGINIA  
OFFICES IN VIRGINIA, MARYLAND & PENNSYLVANIA

TEST BORING LOG

DEP 13900  
W.D. #10

Project Name CHAUNCEY (MILLER) DRAINAGE  
Project Location CHAUNCEY, WV  
Project Manager MNR.

Boring No. B-1  
Job No. 04-10-0045  
Ground Surface Elevation N/A

SOIL / ROCK DESCRIPTION	Strata Depth	Depth Scale	SAMPLE				
			Blows / 6"	No.	Type	Rec.	RQD
SURFACE	0.0	0.0					
BROWN SANDY CLAY INTO ROCK REFSAL →		7.0					
Brown & Gray SANDSTONE		13.0	/	1	RC	5.7	4.11
SANDSTONE SHALE MIX →		23.0	/	2	RC	10.0	5.6
		33.0	/	3	RC	10.0	7.0
		43.0	/	4	RC	10.0	6.1
COAL 41.5 - 43.4 Shale		53.0	/	5	RC	10.0	2.5
COAL 47.0 - 54.4		58.0	/	6	RC	5.0	3.9
BTB - 58.0							

Start Date 4-5-10 Hammer Wt. N/A Lbs.  
Finish Date 4-5-10 Hammer Drop N/A Inches


Rock Core Dia. \_\_\_\_\_  
Boring Method \_\_\_\_\_  
Driller RAL  
Helper SH  
Drill Rig TRACK

Ground Water Depth  
FIRST NOTED DRY Ft.  
AT COMPLETION 17.1 Ft.  
AFTER \_\_\_\_\_ HRS. \_\_\_\_\_ Ft.  
BACKFILLED \_\_\_\_\_ Hrs.

Sampler Type  
SS - DRIVEN SPLIT SPOON  
ST - PRESSED SHELBY TUBE  
B - BAG SAMPLE  
 ROCK CORE

Boring Method  
HSA - HOLLOW STEM AUGERS  
CFA - CONTINUOUS FLIGHT AUGERS  
DC - DRIVING CASING  
MD - MUD DRILLING

Addendum #1

	<b>TRIAD ENGINEERING, INC.</b> ST. ALBANS & MORGANTOWN, WEST VIRGINIA OFFICES IN VIRGINIA, MARYLAND & PENNSYLVANIA
	DEP 13900 W.D. # 10
	<b>TEST BORING LOG</b>

Project Name CHAUNCEY (MILLER) DRAINAGE Boring No. B-1A  
 Project Location CHAUNCEY, WV Job No. 04-10-0045  
 Project Manager DHR Ground Surface Elevation \_\_\_\_\_

SOIL / ROCK DESCRIPTION	Strata Depth	Depth Scale	SAMPLE				
			Blows /8"	No.	Type	Rec.	RQD
SURFACE	0.0	0.0					
Sandy Brown Clay INTO Rock							
AT 6.0 REFUSAL →		7.0					
Brown & Gray Sandstone				1	RC		
SANDSTONE shale mix		13.0		2	RC		
		23.0		3	RC		
		33.0		4	RC		
COAL 41.0 - 43.1		43.0		5	RC		
Shale				6	RC		
COAL 48.4 - 54.5		53.0					
Gray shale							
		58.0					
BTB - 58.0							

Start Date 4-5-10 Hammer Wt. N/A Lbs. Rock Core Dia. \_\_\_\_\_ Driller RAL  
 Finish Date 4-5-10 Hammer Drop N/A Inches Boring Method HSA Helper JH  
 Drill Rig TRACK

Ground Water Depth  
 FIRST NOTED DRY Ft.  
 AT COMPLETION 21.4 Ft.  
 AFTER \_\_\_\_\_ HRS. \_\_\_\_\_ Ft.  
 BACKFILLED \_\_\_\_\_ Hrs.

Sampler Type  
 SS - DRIVEN SPLIT SPOON  
 ST - PRESSED SHELBY TUBE  
 B - BAG SAMPLE  
 RC - ROCK CORE

Boring Method  
 HSA - HOLLOW STEM AUGERS  
 CFA - CONTINUOUS FLIGHT AUGERS  
 DC - DRIVING CASING  
 MD - MUD DRILLING



TEST BORING LOG

DEP13900  
W.D. # 10

Project Name CHAUNCEY (MILLER) DRAINAGE Boring No. B-2  
 Project Location CHAUNCEY, WV Job No. 04-10-0045  
 Project Manager MHR Ground Surface Elevation \_\_\_\_\_

SOIL / ROCK DESCRIPTION	Strata Depth	Depth Scale	SAMPLE				
			Blows /8"	No.	Type	Rec.	RQD
<u>SURFACE</u> BROWN SANDY CLAY INTO ROCK AT 6.0 AUGER REFUSAL →	0.0	0.0					
BROWN & GRAY SANDSTONE		7.0	/	1	MC	5.7	4.0
GRAY SHALE 15.5 TO 17.3		13.0	/	2	MC	8.7	4.3
VOID 35.5 TO 38.0		23.0	/	3	MC	8.8	4.0
VOID <del>43.5</del> TO 51.4 SANDSTONE SHALE MIT		33.0	/	4	MC	4.8	3.7
		43.0	/	5	MC	1.8	0.0
COAL 71.6 TO 72.8		53.0	/	6	MC	8.3	5.4
		63.0	/	7	MC	10.0	6.0
		73.0					

BTB - 73.0  
INSTALLED PRESSUREMETER

Start Date 4-2-16 Hammer Wt. \_\_\_\_\_ Lbs. Rock Core Dia. \_\_\_\_\_ Driller PAC  
 Finish Date 4-2-16 Hammer Drop \_\_\_\_\_ Inches Boring Method \_\_\_\_\_ Helper JH  
 Drill Rig TRAC

Ground Water Depth FIRST NOTED Dry Ft.  
 AT COMPLETION 45.1 Ft.  
 AFTER \_\_\_\_\_ HRS. \_\_\_\_\_ Ft.  
 BACKFILLED \_\_\_\_\_ Hrs.

Sampler Type  
 SS - DRIVEN SPLIT SPOON  
 ST - PRESSED SHELBY TUBE  
 B - BAG SAMPLE  
 RC - ROCK CORE

Boring Method  
 HSA - HOLLOW STEM AUGERS  
 CFA - CONTINUOUS FLIGHT AUGERS  
 DC - DRIVING CASING  
 MD - MUD DRILLING





TRIAD ENGINEERING, INC.  
ST ALBANS & MORGANTOWN, WEST VIRGINIA  
OFFICES IN VIRGINIA, MARYLAND & PENNSYLVANIA

TEST BORING LOG

DEP13900  
W.D. #10

Project Name CHAUNCEY (MILLER) DRAINAGE  
Project Location CHAUNCEY, WV  
Project Manager MHR

Boring No. B-3  
Job No. 04-10-0045  
Ground Surface Elevation \_\_\_\_\_


SOIL / ROCK DESCRIPTION	Strata Depth	Depth Scale	SAMPLE				
			Blows /6"	No.	Type	Rec.	RQD
SURFACE	0.0	0.0					
BROWN SANDY CLAY INTO ROCK AT 6.0 AUGER REFUSAL →		10.0					
BROWN & GRAY SANDSTONE		13.0	/	1	RC	3.0	2.5
TOOL DROP 21.0 - 21.9 BROKEN UP SANDSTONE		23.0	/	2	RC	9.3	7.4
TOOL DROP 38.2 TO 40.5		33.0	/	3	RC	9.6	1.4
TOOL DROP 47.4 TO 50.6		43.0	/	4	RC	6.6	2.8
GRAY SHALE SANDSTONE MIX		53.0	/	5	RC	6.5	3.10
		63.0	/	6	RC	10.0	9.1
COAL 70.1 TO 71.2		73.0	/	7	RC	10.0	7.3
GOOD SANDSTONE		83.0	/	8	RC	10.0	8.8
		93.0	/	9	RC	10.0	10.0
u u u		103.0	/	10	RC	10.0	10.0

Start Date 3-31-10 Hammer Wt. \_\_\_\_\_ Lbs. Rock Core Dia. \_\_\_\_\_ Driller RAJ  
Finish Date 4-2-10 Hammer Drop \_\_\_\_\_ Inches Boring Method \_\_\_\_\_ Helper JH  
Drill Rig TACK

Ground Water Depth  
FIRST NOTED Dry Ft.  
AT COMPLETION 4 1/2 Ft.  
AFTER \_\_\_\_\_ HRS. \_\_\_\_\_ Ft.  
BACKFILLED \_\_\_\_\_ Hrs.

Sampler Type  
SS - DRIVEN SPLIT SPOON  
ST - PRESSED SHELBY TUBE  
B - BAG SAMPLE  
RC ROCK CORE

Boring Method  
HSA - HOLLOW STEM AUGERS  
CFA - CONTINUOUS FLIGHT AUGERS  
DC - DRIVING CASING  
MD - MUD DRILLING



### TEST BORING LOG

DEP 13900  
W.D. #10

Project Name CHAUNCEY (MILLER) DRAINAGE Boring No. B-3  
 Project Location CHAUNCEY, WV Job No. 04-10-0045  
 Project Manager MHR Ground Surface Elevation \_\_\_\_\_

SOIL / ROCK DESCRIPTION	Strata Depth	Depth Scale	SAMPLE				
			Blows /6"	No.	Type	Rec.	RQD
SURFACE GRAY SANDSTONE	0.0	103.0	/	11	RC	10.0	10.0
BTB - 113.0 INSTALLED PIEZOMETER							
		113.0					

Start Date 3-31-10 Hammer Wt. \_\_\_\_\_ Lbs. Rock Core Dia. \_\_\_\_\_ Driller RAC  
 Finish Date 4-2-10 Hammer Drop \_\_\_\_\_ Inches Boring Method HSA Helper JH  
 Drill Rig TACK

Ground Water Depth  
 FIRST NOTED Dry Ft.  
 AT COMPLETION 96.1 Ft.  
 AFTER \_\_\_\_\_ HRS. \_\_\_\_\_ Ft.  
 BACKFILLED \_\_\_\_\_ Hrs.

Sampler Type  
 SS - DRIVEN SPLIT SPOON  
 ST - PRESSED SHELBY TUBE  
 B. - BAG SAMPLE  
 RC - ROCK CORE

Boring Method  
 HSA - HOLLOW STEM AUGERS  
 CFA - CONTINUOUS FLIGHT AUGERS  
 DC - DRIVING CASING  
 MD - MUD DRILLING

## MANDATORY PRE-BID SIGN-IN ATTENDANCE SHEET

PLEASE PRINT LEGIBLY

Req. # :	DEP15306	Pre-Bid Date:	3/3/2011
Project :	Chauncey (Miller) Drainage	Bid Opening Date:	4/5/2011
Name:	<u>Mark Lester</u>	Name:	<u>Bonnie F. Foster</u>
Company:	<u>Lester's Excavating Inc.</u>	Company:	<u>EAGLE CONTRACTORS LLC</u>
Address:	<u>221 Foundation Fork</u> <u>Simon, WV 24882</u>	Address:	<u>1721 Winfield Road</u> <u>Winfield WV 25213</u>
Phone #:	<u>304 664-3094</u>	Phone #:	<u>304-552-7781</u>
Fax #:	<u>304 664 3094</u>	Fax #:	<u>304-755-3150</u>
Email:	<u>LestersExcavating@yahoo.com</u>	Email:	<u>colent@gefinc.com</u>
Name:	<u>Harrison Bowman</u>	Name:	<u>GEORGE FRESHOUR</u>
Company:	<u>Green Mountain</u>	Company:	<u>EAGLE EXCAVATION INC</u>
Address:	<u>511 50<sup>th</sup> St</u> <u>Charleston WV 25304</u>	Address:	<u>P.O. BOX 218</u> <u>KENNA, WV 25248</u>
Phone #:	<u>304-925-0253</u>	Phone #:	<u>(304) 372-4378</u>
Fax #:	<u>304-925-9230</u>	Fax #:	<u>(304) 372-4378</u>
Email:	<u>Jody May@aol.com</u>	Email:	<u>ADW@</u>
Name:	<u>Robert Barnes</u>	Name:	<u>Conny Manhart</u>
Company:	<u>Barnes EXC. INC.</u>	Company:	<u>Simon &amp; Associates, INC</u>
Address:	<u>P.O. BOX 13384</u> <u>Sissonville WV. 25360</u>	Address:	<u>3700 Commerce St</u> <u>Blacksburg, VA 24060</u>
Phone #:	<u>304-984-1725</u>	Phone #:	<u>540-451-4234</u>
Fax #:	<u>304-984-0074</u>	Fax #:	<u>540-451-4219</u>
Email:	<u>BarnesEXC@AOL.com</u>	Email:	<u>manhartj1@Simonassoc.com</u>
Name:	<u>Mike Carpenter</u>	Name:	<u>Ashley Atkins</u>
Company:	<u>Carpenter Reclamation Inc.</u>	Company:	<u>Aspen Corporations</u>
Address:	<u>P.O. Box 13015</u> <u>Sissonville, WV 25360</u>	Address:	<u>2400 Ritter Drive</u> <u>Daniels WV 28832</u>
Phone #:	<u>(304) 984-1115</u>	Phone #:	<u>304-763-4573</u>
Fax #:	<u>(304) 984-2770</u>	Fax #:	<u>304-763-4591</u>
Email:	<u>Rcarpen121@aol.com</u>	Email:	<u>jatkins@aspen-golf.com</u>

# MANDATORY PRE-BID SIGN-IN ATTENDANCE SHEET

PLEASE PRINT LEGIBLY

Req. # : 

DEP15306
----------

  
Project : 

Chauncey (Miller) Drainage
----------------------------

Pre-Bid Date: 

3/3/2011
----------

  
Bid Opening Date: 

4/5/2011
----------

Name: DAVE DERLE / EL TESTER  
Company: ALL-CON  
Address: 12A Philpott LN  
BEAVER WV 25813  
Phone #: 304-731-0190  
Fax #: 255-4232  
Email: DERLE@9ci-wv.com

Name: DAVE M. FARMER  
Company: NEMESIS CONTRACTING LLC  
Address: 44446 Pond Fk Rd  
Wharton WV 25208  
Phone #: (304) 247 6934  
Fax #: \_\_\_\_\_  
Email: david.farmer46@yahoo.com

Name: DENNIS C ELBON  
Company: CONGIRLUP INC  
Address: PO Box 43  
SIMPSON WV 26435  
Phone #: 304-739-4397  
Fax #: 304-739-4401  
Email: DCE@CONGIRLUP@SARTLINK.NET

Name: \_\_\_\_\_  
Company: \_\_\_\_\_  
Address: \_\_\_\_\_  
Phone #: \_\_\_\_\_  
Fax #: \_\_\_\_\_  
Email: \_\_\_\_\_

Name: Allen Marker  
Company: Garcie R. Marker & Sons  
Address: 1119 Jefferson Rd.  
Sp. Chas, WV, 25309  
Phone #: 304 744 0590  
Fax #: 304 746 5203  
Email: grmarkersons@aol

Name: \_\_\_\_\_  
Company: \_\_\_\_\_  
Address: \_\_\_\_\_  
Phone #: \_\_\_\_\_  
Fax #: \_\_\_\_\_  
Email: \_\_\_\_\_

Name: \_\_\_\_\_  
Company: \_\_\_\_\_  
Address: \_\_\_\_\_  
Phone #: \_\_\_\_\_  
Fax #: \_\_\_\_\_  
Email: \_\_\_\_\_

Name: \_\_\_\_\_  
Company: \_\_\_\_\_  
Address: \_\_\_\_\_  
Phone #: \_\_\_\_\_  
Fax #: \_\_\_\_\_  
Email: \_\_\_\_\_