



State of West Virginia
 Department of Administration
 Purchasing Division
 2019 Washington Street East
 Post Office Box 50130
 Charleston, WV 25305-0130

Request for Quotation

RFQ NUMBER
 GSD116402

PAGE
 1

ADDRESS CORRESPONDENCE TO ATTENTION OF
 KRISTA FERRELL
 304-558-2596

VENDOR

RFQ COPY
 TYPE NAME/ADDRESS HERE

SHIP TO

DEPARTMENT OF ADMINISTRATION
 GENERAL SERVICES DIVISION
 BUILDING TWENTY FOUR
 153 WEST MAIN STREET
 CLARKSBURG WV
 26301 304-558-2317

DATE PRINTED	TERMS OF SALE	SHIP VIA	F.O.B	FREIGHT TERMS
08/27/2010				

BID OPENING DATE: 08/31/2010 BID OPENING TIME 01:30PM

LINE	QUANTITY	UOP	CAT NO	ITEM NUMBER	UNIT PRICE	AMOUNT
ADDENDUM NO. 4						
THIS ADDENDUM IS ISSUED TO PROVIDE THE ATTACHED INFORMATION INADVERTANTLY OMITTED FROM ADDENDUM NO. 2.						
BID OPENING DATE REMAINS: 08/31/2010						
BID OPENING TIME REMAINS: 1:30 PM						
***** END ADDENDUM NO. 4 *****						
0001	1	LS		968-32		
DEMOLITION OF CLARKSBURG, BLDG#24, 153 W MAIN ST						
***** THIS IS THE END OF RFQ GSD116402 ***** TOTAL:						

SEE REVERSE SIDE FOR TERMS AND CONDITIONS

SIGNATURE	TELEPHONE	DATE
TITLE	FEIN	ADDRESS CHANGES TO BE NOTED ABOVE

WHEN RESPONDING TO RFQ, INSERT NAME AND ADDRESS IN SPACE ABOVE LABELED 'VENDOR'


GENERAL TERMS & CONDITIONS
REQUEST FOR QUOTATION (RFQ) AND REQUEST FOR PROPOSAL (RFP)

1. Awards will be made in the best interest of the State of West Virginia.
2. The State may accept or reject in part, or in whole, any bid.
3. Prior to any award, the apparent successful vendor must be properly registered with the Purchasing Division and have paid the required \$125 fee.
4. All services performed or goods delivered under State Purchase Order/Contracts are to be continued for the term of the Purchase Order/Contracts, contingent upon funds being appropriated by the Legislature or otherwise being made available. In the event funds are not appropriated or otherwise available for these services or goods this Purchase Order/Contract becomes void and of no effect after June 30.
5. Payment may only be made after the delivery and acceptance of goods or services.
6. Interest may be paid for late payment in accordance with the *West Virginia Code*.
7. Vendor preference will be granted upon written request in accordance with the *West Virginia Code*.
8. The State of West Virginia is exempt from federal and state taxes and will not pay or reimburse such taxes.
9. The Director of Purchasing may cancel any Purchase Order/Contract upon 30 days written notice to the seller.
10. The laws of the State of West Virginia and the *Legislative Rules* of the Purchasing Division shall govern the purchasing process.
11. Any reference to automatic renewal is hereby deleted. The Contract may be renewed only upon mutual written agreement of the parties.
12. **BANKRUPTCY:** In the event the vendor/contractor files for bankruptcy protection, the State may deem this contract null and void, and terminate such contract without further order.
13. **HIPAA BUSINESS ASSOCIATE ADDENDUM:** The West Virginia State Government HIPAA Business Associate Addendum (BAA), approved by the Attorney General, is available online at www.state.wv.us/admin/purchase/vrc/hipaa.htm and is hereby made part of the agreement. Provided that the Agency meets the definition of a Cover Entity (45 CFR §160.103) and will be disclosing Protected Health Information (45 CFR §160.103) to the vendor.
14. **CONFIDENTIALITY:** The vendor agrees that he or she will not disclose to anyone, directly or indirectly, any such personally identifiable information or other confidential information gained from the agency, unless the individual who is the subject of the information consents to the disclosure in writing or the disclosure is made pursuant to the agency's policies, procedures, and rules. Vendor further agrees to comply with the Confidentiality Policies and Information Security Accountability Requirements, set forth in <http://www.state.wv.us/admin/purchase/privacy/noticeConfidentiality.pdf>.
15. **LICENSING:** Vendors must be licensed and in good standing in accordance with any and all state and local laws and requirements by any state or local agency of West Virginia, including, but not limited to, the West Virginia Secretary of State's Office, the West Virginia Tax Department, and the West Virginia Insurance Commission. The vendor must provide all necessary releases to obtain information to enable the director or spending unit to verify that the vendor is licensed and in good standing with the above entities.
16. **ANTITRUST:** In submitting a bid to any agency for the State of West Virginia, the bidder offers and agrees that if the bid is accepted the bidder will convey, sell, assign or transfer to the State of West Virginia all rights, title and interest in and to all causes of action it may now or hereafter acquire under the antitrust laws of the United States and the State of West Virginia for price fixing and/or unreasonable restraints of trade relating to the particular commodities or services purchased or acquired by the State of West Virginia. Such assignment shall be made and become effective at the time the purchasing agency tenders the initial payment to the bidder.

I certify that this bid is made without prior understanding, agreement, or connection with any corporation, firm, limited liability company, partnership, or person or entity submitting a bid for the same material, supplies, equipment or services and is in all respects fair and without collusion or fraud. I further certify that I am authorized to sign the certification on behalf of the bidder or this bid.

INSTRUCTIONS TO BIDDERS

1. Use the quotation forms provided by the Purchasing Division. Complete all sections of the quotation form.
2. Items offered must be in compliance with the specifications. Any deviation from the specifications must be clearly indicated by the bidder. Alternates offered by the bidder as **EQUAL** to the specifications must be clearly defined. A bidder offering an alternate should attach complete specifications and literature to the bid. The Purchasing Division may waive minor deviations to specifications.
3. Unit prices shall prevail in case of discrepancy. All quotations are considered F.O.B. destination unless alternate shipping terms are clearly identified in the quotation.
4. All quotations must be delivered by the bidder to the office listed below prior to the date and time of the bid opening. Failure of the bidder to deliver the quotations on time will result in bid disqualifications: Department of Administration, Purchasing Division, 2019 Washington Street East, P.O. Box 50130, Charleston, WV 25305-0130
5. Communication during the solicitation, bid, evaluation or award periods, except through the Purchasing Division, is strictly prohibited (W.Va. C.S.R. §148-1-6.6).



RFQ GSD 116402
Clarksburg State Office Building
Technical Bulletin No.1

Demolition of Clarksburg, Bldg. #24, 153 W. Main Street

RFQ No. GSD 116402
AAI PROJECT NO. 0810123.00

TO ALL BIDDERS:

1.0 GENERAL NOTES:


- 1.01 This Addendum is part of the Contract Documents for the Project.
- 1.02 Acknowledge receipt of this Addendum on the Form of Proposal in the space provided. Failure to do so may be cause for rejection of bid.
- 1.03 The bid date remains unchanged.
- 1.04 A mandatory Pre-Bid Conference was held on August 18, 2010. Copies of the Pre-Bid Conference Minutes are appended to this Addendum.

2.0 CORRECTIONS/ADDITIONS TO THE PROJECT MANUAL DATED July 23rd, 2010

- 2.01 Section 015000-Temporary Facilities and Controls; 1.3 Use Charges
OMIT: D. Electric Power Service: "Pay electric-power-service-use charges...for construction operations."
ADD.: "The owner will allow the temporary use of electric service that is currently operational by the successful bidder, at no charge. Once owner turns building over to the contractor, the existing utility maintenance is the responsibility of the contractor, any upgrades to the service that are needed for operation of contractor's equipment is the responsibility of the contractor."

- 2.02 Section 015000-Temporary Facilities and Controls; 3.4 Preparation, Termination, and Removal;

OMIT: D. Termination and Removal: Remove each temporary facility when need for its service has ended, "when it has been replaced by authorized use of a permanent facility, or no later than Substantial Completion." "Repair damaged Work, clean exposed



Technical Bulletin No. 1
August 23, 2010


surfaces, and replace construction that cannot be satisfactorily repaired.”

OMIT: “2. At Substantial Completion, repair, renovate, and clean permanent facilities used during construction period. Comply with final cleaning requirements specified in Division 01 Section “Closeout Procedures.”

- 2.03 **OMIT:** Section 024116-Structure Demolition as bound in Project Manual.
ADD: Revised Section 024116-Structure Demolition as attached. Highlighted items indicate modifications.
- 2.04 **OMIT:** Section 024213 Reclamation of Acoustical Ceiling Panels
NOTE: Acoustical Ceiling tile reclamation shall not be part of this project.

Issued August 23, 2010
Alpha Associates, Incorporated


Rebecca Jean Key, AIA



Clarksburg State Office Building
Phase 1-Demolition Pre-Bid Meeting

Demolition of Clarksburg, Bldg. #24, 153 W. Main Street

RFQ No. GSD 116402
AAI PROJECT NO. 0810123.00

Meeting Minutes

MANDATORY PRE-BID FOR GENERAL CONTRACTORS

DATE: August 19, 2010
FROM: Rebecca Key

R. Key


LOCATION: Clarksburg State Office Building,
August 18, 2010 Approximately 1:00 PM

ATTENDEES: Sign in sheet has previously been distributed.

DISTRIBUTION: To all plan holders of record, Pre-Bid Attendees and Depositories

PB-01 **Introductions:**
Robert Krause, WVGSD, introduced Bob Kilpatrick, also of the WVGSD representing the procurement division. Also in attendance from Alpha Associates, Inc. was Rebecca Key, project architect; Charlie Luttrell, project structural engineer; and Alex Haill, project construction coordinator. Julie Szymanek, was representing Triad Engineering.

PB-02 Contract Administration and procurement rules were reviewed by Bob Krause and Bob Kilpatrick.
Bid Due Date: August 31, 2010
Last Day for questions: Friday, August 20, 2010
Address questions in writing to: Krista Ferrell, contact information is contained in the RFQ.
Construction time period: NTP 120 days to substantial, 45 days to final.



-
- PB-03 Project Description:
1. Demolition and site restoration of a six storey existing former hotel/office building. Building is pre-cast plank.
 2. Building and building components are to be salvaged, reused, recycled and removed utilizing sustainable methods and documented in accordance with LEED certification for credit MR-2.
 3. Hazardous material is present and will be removed with approved abatement procedures under the same contract. Refer to Asbestos Inspection Report dated October 2009.
 4. Building is approximately 70k-75k sq. ft.
 5. Recycling is part of the project; however, the asbestos may negate the recycling of the ceiling tile. Look to future addenda for a determination.
- PB-04 City Requirements:
City License may be obtained at www.cityofclarksburgwv.com under the Finance Dept.
Demolition Permit must be obtained as well as street and sidewalk closures. They may be obtained from the Code Enforcement Office, Adam Barberio or Donna Hill at 304-624-1633. They are located at 222 W. Main Street. Permit fee must be paid.
City B & O tax must be paid at 2%.
- PB-05 Hazardous Materials Report: Julie Szymanek gave a brief overview of the Hazardous Materials report that is part of the project manual.
- PB-06 Description of Structure & Cautions. Charlie Luttrell gave a brief physical description of the building. There are no existing original drawings of the building. Review the drawings to determine the extent of concrete slab to remain in the building.
Implosion is not allowed, building to be brought down by mechanical means.
- PB-07 Description of LEED Documentation. Section 017419 describes in detail how to keep track of Demolition waste. Every effort must be made to divert the construction waste from a landfill. However, the products that are diverted must be documented and accounted for and be disposed of in a legal manner.
- PB-08 Questions
- Q.: Are utilities on, electric and water, and available for the contractor's use?
- A.: They can be turned on, see Temporary Facilities Section.
- Q. : Is air monitoring by General Contractor?



A.: Yes, all third party inspections are by GC.

Q.: What about mercury ballasts?

A.: All hazardous materials are to be removed and disposed of according to regulations in place, by the general contractor.

Q.: Was caulking at exterior of windows tested for asbestos?

A.: Materials tested are listed in the report. If other non-tested material is found that may have asbestos, then the testing and removal will be performed by the General Contractor. Please see the report.

SECTION 024116 - STRUCTURE DEMOLITION

PART 1 - GENERAL

1.1 RELATED DOCUMENTS

- A. Drawings and general provisions of the Contract, including General and Supplementary Conditions and Division 01 Specification Sections, apply to this Section.

1.2 SUMMARY

A. Section Includes:

1. Demolition and removal of buildings.
2. Abandoning in-place and removing below-grade construction.
3. Disconnecting, capping or sealing, abandoning in-place and removing site utilities.
4. Salvaging items for reuse by Owner.

B. Related Sections:

1. Division 01 Section "Summary" for use of the premises and phasing requirements.
2. Division 01 Section "Construction Progress Documentation" for preconstruction photographs taken before building demolition.
3. Division 31 Section "Site Clearing" for site clearing and removal of above- and below-grade site improvements not part of building demolition.

1.3 DEFINITIONS

- A. Remove: Detach items from existing construction and legally dispose of them off-site unless indicated to be removed and salvaged or recycled.
- B. Remove and Salvage: Carefully detach from existing construction, in a manner to prevent damage.
- C. Recycle: Recovery of demolition waste for subsequent processing in preparation for reuse.

1.4 MATERIALS OWNERSHIP

- A. Unless otherwise indicated, demolition waste becomes property of Contractor.

1.5 SUBMITTALS

- A. Qualification Data: For qualified refrigerant recovery technician.

- B. Proposed Protection Measures: Submit informational report, including Drawings, that indicates the measures proposed for protecting individuals and property, for environmental protection, for dust control and for noise control. Indicate proposed locations and construction of barriers.
 - 1. Adjacent Buildings: Detail special measures proposed to protect adjacent buildings to remain.
- C. Schedule of Building Demolition Activities: Indicate the following:
 - 1. Detailed sequence of demolition work, with starting and ending dates for each activity.
 - 2. Temporary interruption of utility services.
 - 3. Shutoff and capping of utility services.
- D. Inventory: Submit a list of items to be removed and salvaged prior to start of demolition.
- E. Pre-demolition photographs or video: Show existing conditions of adjoining construction and site improvements, including finish surfaces, that might be misconstrued as damage caused by demolition operations. Provide copies of these photographs or videos to the Architect prior to beginning the Work.
- F. Landfill Records: Indicate receipt and acceptance of hazardous wastes by a landfill facility licensed to accept hazardous wastes.
- G. Statement of Refrigerant Recovery: Signed by refrigerant recovery technician responsible for recovering refrigerant, stating that all refrigerant that was present was recovered and that recovery was performed according to EPA regulations. Include name and address of technician and date refrigerant was recovered.

1.6 QUALITY ASSURANCE

- A. The demolition contractor shall have a minimum of five years of experience removing multi-story structures of similar size and scope. The demolition contractor shall provide a list of at least five similar projects at the time the project bid is submitted.
- B. Refrigerant Recovery Technician Qualifications: Certified by EPA-approved certification program.
- C. Regulatory Requirements: Comply with governing EPA notification regulations before beginning demolition. Comply with hauling and disposal regulations of authorities having jurisdiction.
- D. Standards: Comply with ANSI/ASSE A10.6 and NFPA 241.
- E. Pre-demolition Conference: Conduct conference at the project site.
 - 1. Inspect and discuss condition of construction to be demolished.
 - 2. Review and finalize building demolition schedule and verify availability of demolition personnel, equipment, and facilities needed to make progress and avoid delays.
 - 3. Review and finalize protection requirements.

4. Review procedures for noise control and dust control.
5. Review procedures for protection of adjacent buildings.
6. ~~Review Hazardous Materials Abatement Plan.~~

1.7 PROJECT CONDITIONS

- A. Buildings to be demolished have already been vacated.
- B. Buildings immediately adjacent to demolition area will be occupied. Conduct building demolition so operations of occupied buildings will not be disrupted.
 1. Provide not less than 72 hours notice of activities that will affect operations of adjacent occupied buildings.
 2. Maintain access to existing walkways, exits, and other facilities used by occupants of adjacent buildings.
 - a. Do not close or obstruct walkways, exits, or other facilities used by occupants of adjacent buildings without written permission from authorities having jurisdiction.
- C. Owner assumes no responsibility for buildings and structures to be demolished.
 1. Conditions existing at time of inspection for bidding purpose will be maintained by Owner as far as practical.
- D. Hazardous Materials: Hazardous materials are present in buildings and structures to be demolished. A report on the presence of hazardous materials is on file for review and use. Examine report to become aware of locations where hazardous materials are present.
 1. Hazardous material remediation is specified elsewhere in the Contract Documents.
 2. Do not disturb hazardous materials or items suspected of containing hazardous materials except under procedures specified elsewhere in the Contract Documents.
 3. ~~General Contractor is responsible for design and execution of abatement of hazardous materials present in the building, to be performed by individuals licensed to design and implement removal and abatement of ACM (Asbestos Containing Material). General Contractor is further responsible for the hiring of third party testing agency for air quality monitoring.~~
- E. On-site storage or sale of removed items or materials is not permitted.

1.8 COORDINATION

- A. Arrange demolition schedule so as not to interfere with operations of adjacent occupied buildings.

PART 2 - PRODUCTS

2.1 SOIL MATERIALS

- A. Satisfactory Soils: Comply with requirements in Division 31 Section "Earth Moving."

PART 3 - EXECUTION

3.1 EXAMINATION

- A. Verify that utilities have been disconnected and capped before starting demolition operations.
- B. Review Project Record Documents of existing construction provided by Owner. Owner does not guarantee that existing conditions are same as those indicated in Project Record Documents.
- C. Engage a professional engineer to perform an engineering survey of condition of building to determine whether removing any element might result in structural deficiency or unplanned collapse of any portion of structure or adjacent structures during building demolition operations.
1. Steel Tendons: Locate tensioned steel tendons and include recommendations for de-tensioning.
- D. Verify that hazardous materials have been remediated before proceeding with building demolition operations.

3.2 PREPARATION

- A. ~~Refrigerant and Hydraulic fluids~~ Remove refrigerant from mechanical equipment according to 40 CFR 82 and regulations of authorities having jurisdiction before starting demolition. ~~Hydraulic fluids and all other fluid filled operating systems to be drained and removed in accordance with current regulations of authorities having jurisdiction, by qualified personnel.~~
- B. Existing Utilities: Locate, identify, disconnect, and seal or cap off indicated utilities serving buildings and structures to be demolished.
1. Verify that all utilities have been shut off. Arrange to shut off any utilities not already shut off with the utility companies.
2. If removal, relocation, or abandonment of utility services will affect adjacent occupied buildings, then provide temporary utilities that bypass buildings and structures to be demolished and that maintain continuity of service to other buildings and structures.
3. Cut off pipe or conduit a minimum of 24 inches below grade. Cap, valve, or plug and seal remaining portion of pipe or conduit after bypassing according to requirements of authorities having jurisdiction.
- C. Temporary and Permanent Shoring: Provide and maintain interior and exterior shoring, bracing, or structural support to preserve stability and prevent unexpected movement or collapse of construction being demolished.

1. Strengthen or add new supports where indicated or when required during progress of demolition.

3.3 PROTECTION

- A. Existing Facilities: Protect adjacent walkways, loading docks, building entries, and other building facilities during demolition operations. Maintain exits from existing buildings.
- B. Existing Utilities: Maintain utility services to remain and protect from damage during demolition operations.
 1. Do not interrupt existing utilities serving adjacent occupied or operating facilities unless authorized in writing by Owner and authorities having jurisdiction.
 2. Provide temporary services during interruptions to existing utilities, as acceptable to Owner and authorities having jurisdiction.
 - a. Provide at least 72 hours' notice to occupants of affected buildings if shutdown of service is required during changeover.
- C. Temporary Protection: Erect temporary protection, such as walks, fences, railings, canopies, and covered passageways, where required by authorities having jurisdiction and as indicated. Comply with requirements in Division 01 Section "Temporary Facilities And Controls."
 1. Protect adjacent buildings and facilities from damage due to demolition activities.
 2. Protect existing site improvements, appurtenances, and landscaping to remain.
 3. Provide temporary barricades and other protection required to prevent injury to people and damage to adjacent buildings and facilities to remain.
 4. Provide protection to ensure safe passage of people around building demolition area and to and from occupied portions of adjacent buildings and structures.
 5. Protect walls, windows, roofs, and other adjacent exterior construction that are to remain and that are exposed to building demolition operations.
- D. Remove temporary barriers and protections where hazards no longer exist. Where open excavations or other hazardous conditions remain, leave temporary barriers and protections in place.

3.4 DEMOLITION, GENERAL

- A. General: Demolish indicated buildings completely. Use methods required to complete the Work within limitations of governing regulations and as follows:
 1. Do not use cutting torches until work area is cleared of flammable materials. Maintain portable fire-suppression devices during flame-cutting operations.
 2. Maintain fire watch during and for at least 2 hours after flame cutting operations.
 3. Maintain adequate ventilation when using cutting torches.
 4. Locate building demolition equipment and remove debris and materials so as not to impose excessive loads on supporting walls, floors, or framing.

- B. Engineering Surveys: During demolition, perform surveys to detect hazards that may result from building demolition activities.
- C. Site Access and Temporary Controls: Conduct building demolition and debris-removal operations to ensure minimum interference with roads, streets, walks, walkways, and other adjacent occupied and used facilities.
1. Do not close or obstruct streets, walks, walkways, or other adjacent occupied or used facilities without permission from Owner and authorities having jurisdiction. Provide alternate routes around closed or obstructed traffic ways if required by authorities having jurisdiction.
 2. Use water mist and other suitable methods to limit spread of dust and dirt. Comply with governing environmental-protection regulations. Do not use water when it may damage adjacent construction or create hazardous or objectionable conditions, such as ice, flooding, and pollution.

D. Explosives: Use of explosives is NOT permitted.

E. Hazardous Material Abatement

1. All Asbestos Containing Materials are to be abated from the structure prior to, or in conjunction with, demolition activities. All removal or abatement of ACM should be performed by a licensed contractor who will provide all necessary labor, equipment, licenses, insurance, third party monitoring, and any required regulatory notifications needed to remove, transport, and legally dispose of ACM.
2. The project has not been tested for lead based paint, should the contractor encounter such, during the demolition, the contractor should bring it to the attention of the owner and/or architect.
3. A plan of hazardous material abatement is to be submitted prior to any demolition work occurring on site.
4. The report enclosed with the project manual, outlines methods, procedures, locations, and results of testing performed on the structure. In the event, that any additional materials, not previously described herein (i.e., sub-floors, hidden walls and/or spaces or ceilings, etc.) are encountered during demolition activities, such materials shall be sampled and tested to determine if asbestos is present.

3.5 DEMOLITION BY MECHANICAL MEANS

- A. Proceed with demolition of structural framing members systematically, from higher to lower level. Complete building demolition operations above each floor or tier before disturbing supporting members on the next lower level.
- B. Remove debris from elevated portions of the building by chute, hoist, or other device that will convey debris to grade level in a controlled descent.
1. Remove structural framing members and lower to ground by method suitable to minimize ground impact and dust generation.
- C. Salvage or Recycling: Items to be removed and salvaged are indicated below:

- a. Concrete and steel reinforcing.
- b. Doors and frames.
- c. Door hardware.
- d. Acoustical tile and panels.
- e. Carpet.
- f. Cabinets.
- g. Plumbing fixtures.
- h. Copper wiring.
- i. Brick.
- j. Lighting Fixtures.
- k. Miscellaneous metals or structural steel.
- l. Aluminum curtain wall and window framing material.

- D. Below-Grade Construction: Abandon foundation walls and other below-grade construction as indicated on the contract drawings. Cut below-grade construction flush with grade. Permanently brace existing basement walls to remain as indicated.
- E. Existing Utilities: Abandon existing below grade utilities and below-grade utility structures. Cut utilities flush with grade.

3.6 SITE RESTORATION

- A. Below-Grade Areas: Fill below-grade areas and voids resulting from building demolition operations as indicated on the contract drawings with recycled pulverized concrete or recycled pulverized masonry according to backfill requirements in Division 31 Section "Earth Moving."

3.7 REPAIRS

- A. Promptly repair damage to adjacent buildings caused by demolition operations.

3.8 DISPOSAL OF DEMOLISHED MATERIALS

- A. Remove demolition waste materials from Project site and legally dispose of them in an EPA-approved landfill acceptable to authorities having jurisdiction. See Division 01 Section "Construction Waste Management and Disposal" for recycling and disposal of demolition waste.
1. Do not allow demolished materials to accumulate on-site.
 2. Remove and transport debris in a manner that will prevent spillage on adjacent surfaces and areas.
 3. Provide appropriate documentation that certifies ACM has been hauled and deposited into approved hazardous materials site.
- B. Do not burn demolished materials.

3.9 CLEANING

- A. Clean adjacent structures and improvements of dust, dirt, and debris caused by building demolition operations. Return adjacent areas to condition existing before building demolition operations began.
 - 1. Clean roadways of debris caused by debris transport.

END OF SECTION 024116