



ENT

- ALL ELECTRICAL COMPONENTS MUST MET NEC AND MUST BE SUBMITTED TO OWNER FOR APPROVAL PRIOR TO CONSTRUCTION.
- LIGHT POST MUST MATCH EXISTING
- CONDUIT DEEP MUST MET NEC.
- ALL UNDERGROUND WIRING MUST BE IN RIGID ELECTRICAL PVC CONDUIT.
- WARNING TAPE MUST BE PLACED ABOVE CONDUIT.
- CONTRACTOR SHALL FIELD VERIFY ALL
 DIMENSIONS. ANY DISCREPENCIES
 SHALL BE BROUGHT TO THE PROJECT
 MANAGER / ARCHITECT ATTENTION PRIOR
 TO CONSTRUCTION.

BLDG. 5, 6 and 7 Park CAPITOL COMPLEX BUILDING #5, 6 AND 7 1900 KANAWHA BOULEVARD EAST CHARLESTON, WEST VIRGINIA 25305

REVISIONS

DATE NO.

SEAL

DATE SCALE

08/12/10 NOTED

DRAWN BY CHK. BY

BMG

DRAWING NUMBER

E2.1