

GSD126405 Technical Questions and Answers

Q1. You have 2 Lithonia items listed which are the ELM2 LED and the LHQMLED SW3R listed on your request for quote. They do not meet the ARRA, will these again be exempt from the ARRA but American Provision?

A1. There are no ARRA Buy American Provisions for this RFQ.

Q2.

Substitution Requests

A. Sure-Lites model number APEL against Lithonia ELM2 LED

*This light is an acceptable substitute.

B. Sure-Lites model number APCH7R against Lithonia LHQM LED SW3R

* This light does not meet the minimum specification. Each light head has .78W output compared to the specified product that has 1.5W output per light head.

C. Mule Lighting model number SQ-LED against Lithonia ELM2 LED.

*This light does not meet the minimum specification. Each light head has 1.0W output compared to the specified product that has 1.5W output per light head.

D. BIU-154T5-UNV-EBT1-U against Lithonia WP-1-54T5HO-MVOLT-GEB10PS

*This light is an acceptable substitute.

E. HBL-454T5-N-UNV-EBT1-U against IBZT54

*This light is an acceptable substitute.

F. 2GC-328T5A125-UNV-EBT1-U against Lithonia 2SP5-G-328T5A12125-MVOLT-GEB10PS

*This light is an acceptable substitute.

G. Mule Lighting ELW-BB-10L2-W against Lithonia ELM2

*This light is an acceptable substitute.

H. Mule Lighting SSLW against Lithonia ELM2

*This light is an acceptable substitute.

I. Mule Lighting MAKO-LED against Lithonia ELM2

*This light is an acceptable substitute.

J. Cooper HBE series against Lithonia IBZT5 4

*This light is intended for suspension mounting and the installation for this fixture should be for drop ceiling, therefore it is not an acceptable substitute.

K. ASL TLW against Lithonia WP 1 54T5HO MVOLT GEB10PS

*This light is an acceptable substitute.