

TOLL FREE 1 (888) 212-6324
 TP FAX 1 (866) 296-6035
 OFFICE (502) 966-0121
 FAX (502) 966-8116
 www.aamservice.com



A&A MECHANICAL SERVICE, INC.

7200 DISTRIBUTION DRIVE
 LOUISVILLE, KENTUCKY 40258-2827

24 HR. SERVICE

Page 1 of

Job # 112094

Incomplete Complete

Heating - Air Conditioning - Refrigeration - Building Automation - Boilers - Sheet Metal - Plumbing

Name: State of WV Customer Complaint: Dept of Administration
 Address: General Services Bldg # 32
 City: Huntington State: WV Round-Trip Mileage: Winter Start up RTU 1-9

DATE	NAME	HOURS		DATE	NAME	HOURS	
		REG	OT			REG	OT
11/2/11	Jeff Tygart	6.25					

Service Performed: RTU^s 1-7, I checked and adjusted belt tension, pulleys bearings, blower wheels. I found RTU #2 needs belt (RXL) RTU 4, 5, 6, 7 needs belt and drive pulleys. RTU #5 blower wheel bearing slightly worn. RTU #2 Test Mode imp. economizer only open in full operation. RTU #4 1st stage compressor contactor & wire bad (just visual). RTU #1, just visual. Refrigerant oil on cond lines & cond coils. RTU #7 gas heat igniter faulty. I checked found all air filters dirty, 20x20x2x4, 20x25x4 in unit. I ran test mode on 3 coils unit, chd gas pressure - 0.2"wc, Evap coil air flow, wiring, economizer lamps OK.

PO#	Material Used Under P.O.#	Ticket #	Specify # of Days Equipment Is Used	
			Sm. Recovery Machine	Tube Brushing Machine
			Low Pres. Recovery	DUCT tape
			High Pres. Recovery	Sm. Sink Machine
			Vacuum Pump	Large Sewer Machine
			Torch Charge	K-3800
			Poly Pipe Threader	Pro Press
			Lg Pipe Threader	See Snake <input type="checkbox"/> VCR
Qty	Truck Stock		Electric Welder	Back Flow Tester
			Welder w/Generator	Jetter
			Flue Gas Analyzer	Aqua Scope
			Balometer Air Balance	Line Locator
			Other	

not. And not get to ck all heat exchangers
 RTU 8, 9 - Pulled off job site, work stopped
 lbs R- Refrigerant per WV State Admin
 Environmental Waste Disposal: Refrigerant Disposal Waste Oil Disposal
 Serial # 2471006084

Recommendations To User: Trans RTU # 6
YCD 240 B4 LCHA
249100 529J
460 v 30 R22 18.9"
21.0"

Customer's Signature: [Signature] Date: _____ Customer's P.O. #: 56821