

PAGE 1 OF 3

PHONE: (304) 861-0131 Lifting and Lowering Devices Acceptance Inspection Form FORM #403	CERTIFIED ELEVATOR INSPECTION SERVICE P. O. Box 555 Washington, WV 26181		FAX: (304) 861-0349 EV#
Company Name: <u>WV STATE CAPITAL</u>		Contact Person: <u>MICHAEL S.</u>	
Billing Address: <u>1900 KANAWHA BLVD. EAST</u>		Telephone: <u>632-1600</u>	
City: <u>CHARLESTON</u>	State: <u>WV</u>	Zip: <u>25305</u>	County: <u>KANAWHA</u>
Elevator Location: <u>HOUSE OF DELEGATES EAST WING ELEVATOR # 4</u>			
Installed By: <u>THYSSEN KRUPP ELEVATOR</u>		Telephone: <u>302-8115</u>	
Address: <u>901 MORRIS ST.</u>		City: <u>CHARLESTON</u>	State: <u>WV</u> Zip: <u>25301</u>

Traction Device Information

Serial No #: <u>BAY 599</u>	Speed: Up: _____ Down: _____	Top Runby: _____
Type: <u>PASS-TRACTION</u>	Mech. Tripping Speed: _____	Top Refuge Space: _____
Make: <u>OTIS -TKE</u>	Elec. Tripping Speed: _____	Bottom Runby: _____
Capacity: <u>1800</u> Landings: <u>3</u>	Governor Pull Thru: _____	Bottom Refuge Space: _____
Installed: <u>10/30</u> Modified <u>2012</u>	Releasing Carriage Pull Out: _____	Door Closing Force: _____
	Top Car Clearance: _____	Fire Service: _____

Accepted Rejected Reinspection Temporary Construction Use

At the time of inspection the following conditions were observed.
Repairs shall be made per West Virginia Code §21-3C

A.17.1 2007 Applicable Code Reference	All Incomplete And Rejected Items Are To Be Explained Below With Code Reference
5.1	_____
5.1	SUMP PUMP LINE MUST BE GALV PIPE OR COPPER
2.8	STEAM LINE BLOW OFF MUST BE ROUTED OUT OF MACHINEROOM
5.1	_____
5.1	_____ MUST EXTEND PIT LADDER DOWN TO CONCRETE PIT FLOOR AND RELOCATE STEP SWITCH
5.1	_____
5.1	_____

PER WEST VIRGINIA CODE §42-21-6.3 YOU HAVE 20 DAYS TO APPEAL THIS REPORT

SIGNATURE OF PERSON RECEIVING FORM: [Signature] MECH # 1247 DATE: 1-9-12
INSPECTOR'S SIGNATURE: [Signature] WV NUMBER 1 DATE: 1-9-12

PAGE 2 OF 3

PHONE: (304) 861-0131 Lifting and Lowering Devices Acceptance Inspection Form FORM #403	CERTIFIED ELEVATOR INSPECTION SERVICE P. O. Box 555 Washington, WV 26181	FAX: (304) 861-0349 EV#
--	---	--------------------------------

Company Name : <u>WV STATE CAPITAL</u>			Contact Person :
Billing Address :			Telephone :
City :	State :	Zip :	County :

Elevator Location :

Installed By :		Telephone :	
Address :		City :	State : Zip :

Traction Device Information

Serial No #: <u>DAV 599</u>	Speed: Up: _____ Down: _____	Top Runby: _____
Type :	Mech. Tripping Speed: _____	Top Refuge Space: _____
Make :	Elec. Tripping Speed: _____	Bottom Runby: _____
Capacity : Landings :	Governor Pull Thru: _____	Bottom Refuge Space: _____
Installed : Modified :	Releasing Carriage Pull Out: _____	Door Closing Force: _____
	Top Car Clearance: _____	Fire Service: _____

Accepted Rejected Reinspection Temporary Construction Use

*At the time of inspection the following conditions were observed.
Repairs shall be made per West Virginia Code §21-3C*

A.17.1 2007 Applicable Code Reference	All Incomplete And Rejected Items Are To Be Explained Below With Code Reference
[REDACTED]	[REDACTED]
[REDACTED]	[REDACTED]
3.12	MUST REMOVE AC LINES AND POWER LINES FROM TOP OF HOISTWAY
3.10	MUST SEAL TOP OF HOISTWAY WITH 2 SHEETS OF 5/8" DRYWALL (COMPLETE TOP OF HOISTWAY)
[REDACTED]	[REDACTED]
[REDACTED]	[REDACTED]
[REDACTED]	[REDACTED]

PER WEST VIRGINIA CODE §42-21-6.3 YOU HAVE 20 DAYS TO APPEAL THIS REPORT

SIGNATURE OF PERSON RECEIVING FORM: _____ DATE: _____

INSPECTOR'S SIGNATURE: _____ WV NUMBER 1 DATE: _____

WHITE - WV DOL YELLOW - Inspector's Copy PINK - Owner/Operator's Copy Revision Date: _____

ELEVATOR VARIANCE

West Virginia Division of Labor
Building 6, Room B-749 · Capitol Complex
Charleston, WV 25305
304.558.7890 · 304.558.2415 (fax)
www.wvlabor.org

Variance granted to State of West Virginia Department of Administration
General Services Division

Account Number EV0001639

Street 1900 Kanawha Boulevard East

City Charleston State WV Zip Code 25305

Equipment Information

Name of Building Main Capitol Building

Location Office of the Attorney General

City Charleston State WV Zip Code 25305


Type of Device Elevator/Traction Serial Number 200450

Variance Granted

Variance from Rule/Standard ASME A17.1-2007, Section 2.8.3.4 Existing
pipng may remain in the shaft and equipment room.

Explanation/Conditions to be Met: Variance is granted because rerouting of the piping
and maintenance of the slope for drainage and steam condensate return is not possible.
Insulation and metal jackets must be installed over the piping. No further intrusion of
pipes, ducts or wiring not directly related to the operation of the elevator will be
permitted in the equipment room.

ADDENDUM: Steam blow off pipe is to be run to a drain and installed in drain in a
vertical position to facilitate steam transfer to drain.



David W. Mullins, Commissioner of Labor

January 9, 2012

Date

This variance applies to this device at this location only and must be posted in the elevator machine room for the life of the unit.

INSPECTOR'S REPORT, PAGE 1 OF 3, ITEM 3