



**PLAN NOTES**

- 1 PANS SHALL BE CONSTRUCTED OF 16 GA. GALVANIZED SHEET METAL WITH WELDED, WATER PROOF SEAMS; CONNECT TO ADJACENT PANS WITH A T-20 FLANGE CONNECTION AND SCREWS
- 2 DIMENSIONS GIVEN ARE FOR BIDDING PURPOSES; THE CONTRACTOR WILL FIELD VERIFY THESE DIMENSIONS AND ADJUST FOR PROPER FIT
- 3 ALL PANS ON THE SOUTH EDGE SHALL HAVE A ONE INCH (1") HOLE ON THE NORTH EAST CORNER FOR THE 1" BLACK IRON PIPE CONNECTION TO THE NEXT PAN
- 4 ALL OTHER PANS SHALL HAVE TWO 1" HOLES WHICH ALIGN WITH ADJACENT PANS (SE CORNER AND NE CORNER) FOR THE 1" BLACK IRON PIPE CONNECTION
- 5 SEAL PAN/PIPE CONNECTIONS WITH HEAT RESISTANT RUBBER WASHERS AND UNIONS
- 6 PROVIDE AND INSTALL 1" BLACK IRON PIPE AND FITTINGS CONNECTING EACH PAN OUTLET ON THE NORTH FACE AND ROUTE TO FLOOR DRAIN AS INDICATED
- 7 REMOVE AND REPLACE ANY EXISTING STEEL FLOOR GRATING AND PIPING AS REQUIRED TO ACCESS SPACE BETWEEN STEEL BEAMS FOR PAN INSTALLATION
- 8 BOILER SUPPORT GRID IS CONSTRUCTED WITH W 4 X 13 STEEL BEAMS SET ON EACH OTHER AND ON 1' X 7' CONCRETE CURBS; DIMENSIONS SHOWN ARE BEAM TO BEAM. (SEE M1b)

REVISIONS	
DATE	NO.

SEAL

REVISED	
DATE	SCALE
02/24/2011	AS NOTED
DRAWN BY UMH	CHK. BY 
DRAWING NUMBER	