



State of West Virginia
 Department of Administration
 Purchasing Division
 2019 Washington Street East
 Post Office Box 50130
 Charleston, WV 25305-0130

Solicitation

NUMBER
DEFK13016

PAGE
1

ADDRESS CORRESPONDENCE TO ATTENTION OF
TARA LYLE 304-558-2544

RFQ COPY
 TYPE NAME/ADDRESS HERE

V
E
N
D
O
R

S
H
I
P
T
O

DIV ENGINEERING & FACILITIES
 ARMORY BOARD SECTION
 1707 COONSKIN DRIVE
 CHARLESTON, WV
 25311-1099 304-341-6368

DATE PRINTED
05/20/2013

BID OPENING DATE: 05/28/2013 BID OPENING TIME 1:30PM

LINE	QUANTITY	UOP	CAT. NO.	ITEM NUMBER	UNIT PRICE	AMOUNT
				ADDENDUM NO. 2		
				SEE ATTACHED PAGES.		
				END OF ADDENDUM NO. 2		
0001	1	JB	988-15	FENCE, GUARDRAIL AND GATE INSTALLATION		
***** THIS IS THE END OF RFQ DEFK13016 ***** TOTAL:						

SIGNATURE		TELEPHONE		DATE
TITLE	FEIN	ADDRESS CHANGES TO BE NOTED ABOVE		

WHEN RESPONDING TO SOLICITATION, INSERT NAME AND ADDRESS IN SPACE ABOVE LABELED 'VENDOR'

SOLICITATION NUMBER: DEFK13016
Addendum Number: 2

The purpose of this addendum is to modify the solicitation identified as DEFK13014 ("Solicitation") to reflect the change(s) identified and described below.

Applicable Addendum Category:

- Modify bid opening date and time
- Modify specifications of product or service being sought
- Attachment of vendor questions and responses
- Attachment of pre-bid sign-in sheet
- Correction of error
- Other

Description of Modification to Solicitation:

1. Responses to vendor questions attached.
2. Mandatory pre-bid sign-in sheets.
3. Revisions to specifications.

Additional Documentation: Documentation related to this Addendum (if any) has been included herewith as Attachment A and is specifically incorporated herein by reference.

Terms and Conditions:

1. All provisions of the Solicitation and other addenda not modified herein shall remain in full force and effect.
2. Vendor should acknowledge receipt of all addenda issued for this Solicitation by completing an Addendum Acknowledgment, a copy of which is included herewith. Failure to acknowledge addenda may result in bid disqualification. The addendum acknowledgement should be submitted with the bid to expedite document processing.

ATTACHMENT A

REVISIONS TO SPECIFICATIONS:

Part 1 – General

1.1 Summary of Work (Revised)

All other language from this section remains unchanged except for the following revisions.

Provide and install approximately 1,521 lin. Ft. of 8'-0" high Class 2 galvanized chain link fence.

Provide and install approximately 1,843 lin. Ft. of Type 1, Class II galvanized Steel Deep Beam Type Guardrail.

Provide and install two (2) 8'-0" wide fence gates, each in two (2) 4'-0" wide panels.

Part 2 – Products

2.2 Chain-Link Fence Fabric

A.1.a. Delete Class 1: Not less than 1.2 oz./sq. ft. of uncoated wire surface

VENDOR SUBMITTED QUESTIONS:

Q1: Please verify the west side fence is to be extended south until it intersects the fence on the south end.

A1: True, as discussed at the pre-bid meeting.

Q2: Please verify that an additional gate is to be installed as discussed at the pre-bid and it is to meet the same specifications as described in the RFQ.

A2: True, the project now requires (2) 8'-0" wide gates as stated in the revised summary of work.

Q3: Please verify the addendum will include the location of the additional fencing and gate on the west side of the property.

A3: Please see the attached revise site plan.

Q4: Please verify the actual linear footage of fencing and guardrail will be issued in the addendum and clarify that it will still be the responsibility of the contractor to confirm these measurements.

A4: Per the measurements taken at the pre-bid meeting:

The measured fencing is 1,521 linear feet.
The measured guardrail is 1,843 linear feet.

It is the responsibility of the contractor to verify these measurements.

Bids are to be all inclusive and lump sum.

Q5: In the specifications in Addendum #1, Section 2.2 A.2. It lists both 1.2 oz. and 2.0 oz. galvanized fabric. There is some difference in price, which one is it?

A5: Per the revisions to specifications section of this addendum, the reference to Class 1 "not less than 1.2 oz/sq ft. of uncoated wire surface" has been deleted.

Please provide Class 2: Not less than 2.0 oz. sq/ft uncoated wire surface of chain-link fence fabric.

The bid opening remains May 28, 2013 at 1:30 pm.

000005

Glen Jean Armory Site Plan


Glen Jean, WV



150 75 0 S 150 Feet

-Imagery courtesy of ESRI and Bing
-Boundaries derived from real estate documents
-maintained by CFMD
-All locations and data is approximate
Map name: GlenJeanGateFenceGuardrail 5-18-2018

- Proposed Fence
- Proposed Gate
- Proposed Guardrail



DEFK13016 Glen Jean AFRC Fence & Guardrail Project

Addendum No. 2

SIGN IN SHEET

Request for Proposal No. DEFK13016

PLEASE PRINT

Page 1 of 2

Date: 5-15-13

* PLEASE BE SURE TO PRINT LEGIBLY - IF POSSIBLE, LEAVE A BUSINESS CARD

FIRM & REPRESENTATIVE NAME	MAILING ADDRESS	TELEPHONE & FAX NUMBERS
Company: <u>Denner Fence</u>	<u>432 Washington Ave</u>	PHONE <u>304 469 4366</u>
Rep: <u>John Given</u>	<u>Oak Hill WV</u>	TOLL FREE
Email Address: <u>dennerfence@gbsi-net.com</u>	<u>25301</u>	FAX <u>304 469 4366</u>
Company: <u>ALL Quality LLC</u>	<u>PO Box 7169</u>	PHONE <u>304-776-9473</u>
Rep: <u>Cynthia McClure</u>	<u>Cross Lanes WV</u>	TOLL FREE
Email Address: <u>allqualityllc@aol.com</u>	<u>25356</u>	FAX <u>304-776-9474</u>
Company: <u>Dan Hill Construction</u>	<u>PO Box 685</u>	PHONE <u>1-304-632-1600</u>
Rep: <u>MIKE SIEMIACZKO</u>	<u>GADLET BRIDGE, WV 25085</u>	TOLL FREE
Email Address: <u>rdanhill@hotmail.com</u>		FAX <u>1-304-632-1501</u>
Company: <u>Babcock Fence Co</u>	<u>1261 Laurel Ridge Rd</u>	PHONE <u>740 896 2211</u>
Rep: <u>Mike Babcock</u>	<u>Lowell, OH 45744</u>	TOLL FREE <u>Call 740 525 9211</u>
Email Address: <u>mikebabcock@frontier.com</u>		FAX <u>740 896 2277</u>
Company: <u>FOX ENGINEERING PLLC</u>	<u>101 NORTH COURT ST</u>	PHONE <u>304-372-3705</u>
Rep: <u>STEVE WINTERS</u>	<u>Ripley WV 25271</u>	TOLL FREE
Email Address: <u>swinters@foxengineering.net</u>		FAX <u>304-372-4100</u>

00000

SIGN IN SHEET

Page 2 of 2

Request for Proposal No. DEFK13016

PLEASE PRINT

Date: 5-15-13

* PLEASE BE SURE TO PRINT LEGIBLY - IF POSSIBLE, LEAVE A BUSINESS CARD

FIRM & REPRESENTATIVE NAME	MAILING ADDRESS	TELEPHONE & FAX NUMBERS
Company: <u>Whittington Fence Co</u>	<u>400oppers Dr</u>	PHONE <u>304) 935 4826</u>
Rep: <u>Greg Whittington</u>	<u>Charleston WV 25071</u>	TOLL
Email Address: <u>gregwhittington35@yahoo</u>		FREE
Company: <u>McNIEL FENCE Co</u>	<u>P.O. Box 6122</u>	PHONE <u>304744-8051</u>
Rep: <u>CHARLES SWYDER</u>	<u>CHAS WV 25362</u>	TOLL
Email Address: <u>CHARLIE@mcnielFence.com</u>		FREE
Email Address: _____		FAX _____
Company: _____		PHONE _____
Rep: _____		TOLL _____
Email Address: _____		FREE _____
Email Address: _____		FAX _____
Company: _____		PHONE _____
Rep: _____		TOLL _____
Email Address: _____		FREE _____
Email Address: _____		FAX _____
Company: _____		PHONE _____
Rep: _____		TOLL _____
Email Address: _____		FREE _____
Email Address: _____		FAX _____

000007

ADDENDUM ACKNOWLEDGEMENT FORM
SOLICITATION NO.: DEFK13016

Instructions: Please acknowledge receipt of all addenda issued with this solicitation by completing this addendum acknowledgment form. Check the box next to each addendum received and sign below. Failure to acknowledge addenda may result in bid disqualification.

Acknowledgment: I hereby acknowledge receipt of the following addenda and have made the necessary revisions to my proposal, plans and/or specification, etc.

Addendum Numbers Received:

(Check the box next to each addendum received)

- | | |
|---|--|
| <input type="checkbox"/> Addendum No. 1

<input type="checkbox"/> Addendum No. 2

<input type="checkbox"/> Addendum No. 3

<input type="checkbox"/> Addendum No. 4

<input type="checkbox"/> Addendum No. 5 | <input type="checkbox"/> Addendum No. 6

<input type="checkbox"/> Addendum No. 7

<input type="checkbox"/> Addendum No. 8

<input type="checkbox"/> Addendum No. 9

<input type="checkbox"/> Addendum No. 10 |
|---|--|

I understand that failure to confirm the receipt of addenda may be cause for rejection of this bid. I further understand that that any verbal representation made or assumed to be made during any oral discussion held between Vendor's representatives and any state personnel is not binding. Only the information issued in writing and added to the specifications by an official addendum is binding.

Company

Authorized Signature

Date

NOTE: This addendum acknowledgment should be submitted with the bid to expedite document processing.