



State of West Virginia
 Department of Administration
 Purchasing Division
 2019 Washington Street East
 Post Office Box 50130
 Charleston, WV 25305-0130

Solicitation

NUMBER
DEP15898

PAGE
1

ADDRESS CORRESPONDENCE TO ATTENTION OF:
GUY NISBET
304-558-8802

VENDOR

RFQ COPY
 TYPE NAME/ADDRESS HERE

SHIP TO

ENVIRONMENTAL PROTECTION
 DEPARTMENT OF
 DIVISION OF LAND RESTORATION
 601 57TH STREET SE
 CHARLESTON, WV
 25304 304-926-0499

DATE PRINTED
10/15/2012

BID OPENING DATE: 10/31/2012 BID OPENING TIME 1:30PM

LINE	QUANTITY	UOP	CAT NO	ITEM NUMBER	UNIT PRICE	AMOUNT
0001	1	JB		962-73		
ADDENDUM NO. 01 ADDENDUM FOR THE WYOMING COUNTY LANDFILL LEACHATE FORCE MAIN PROJECT ISSUED TO PUBLISH THE ATTACHED DOCUMENTATION. RECLAMATION: RESTORATION OF LAND & OTHER PROPERTIES ***** THIS IS THE END OF RFQ DEP15898 ***** TOTAL:						

SIGNATURE	TELEPHONE	DATE
TITLE	FEIN	ADDRESS CHANGES TO BE NOTED ABOVE

WHEN RESPONDING TO SOLICITATION, INSERT NAME AND ADDRESS IN SPACE ABOVE LABELED 'VENDOR'

SOLICITATION NUMBER: DEP15898
Addendum Number: No. 01

The purpose of this addendum is to modify the solicitation identified as ("Solicitation") to reflect the change(s) identified and described below.

Applicable Addendum Category:

- Modify bid opening date and time
- Modify specifications of product or service being sought
- Attachment of vendor questions and responses
- Attachment of pre-bid sign-in sheet
- Correction of error
- Other

Description of Modification to Solicitation:

Addendum for the Wyoming Landfill Leachate Force Main Project issued to publish the following information.

1. Q & A's
2. Pre-Bid meeting sign in sheet

No other changes.

Additional Documentation: Documentation related to this Addendum (if any) has been included herewith as Attachment A and is specifically incorporated herein by reference.

Terms and Conditions:

1. All provisions of the Solicitation and other addenda not modified herein shall remain in full force and effect.
2. Vendor should acknowledge receipt of all addenda issued for this Solicitation by completing an Addendum Acknowledgment, a copy of which is included herewith. Failure to acknowledge addenda may result in bid disqualification. The addendum acknowledgement should be submitted with the bid to expedite document processing.

ATTACHMENT A

DEP15898
Questions from Pre-bid Meeting
Wyoming County Landfill Leachate Transfer Line Replacement Project

Question: What is the depth of the existing leachate transfer line?

Answer: The exact depth varies and is unknown, however the specifications required a minimum depth of 36-inches to the top of the pipeline.

Question: Is the Contractor to protect the existing leachate transfer line during the excavation, trenching, and installation of the replacement line?

Answer: No, the existing line is to be disconnected on both ends and plugged with grout. Given the planned alignment of the replacement pipeline and its close proximity to the existing line the Contractor is likely to encounter the older line during the work. In the event that the line is broken during the excavation, it should be removed to the extent required to install the new pipeline and then backfilled.

Question: Where is the new pump station to be located?

Answer: The new pump station is to be located as indicated on the design drawings. The location is outside the existing pump station building, between the existing secondary containment tank wall and the existing pump station structure. The control panel and electrical connections are to be mounted and connected within the existing pump station structure.

Question: Where is the existing leachate connection line feeding the pump station?

Answer: The existing connection line which feeds the pump station from the landfill is located along the southern side of the landfill access road near the base of the hillside. The transfer line which is being replaced is situated along the opposite or northern side (adjacent to the airport runway). The existing leachate connection line from the landfill is to remain in service and the Contractor is responsible for protecting this line during the work. In the event that the line is encountered or damaged, it is the Contractor's responsibility to replace and/or repair the line to ensure its proper function at no cost to the WVDEP. The approximate alignment and location of this line is indicated on the design drawings.

Question: Can't the gravity line be air tested instead of water tested?

Answer: Any alternative methods of testing the line may be submitted to the Engineer and will be evaluated at that time.

SIGN IN SHEET

Request for ^{Submittal} Proposal No. DEP 15898

PLEASE PRINT

RECEIVED WV DEP Date: **10-3-12**

* PLEASE BE SURE TO PRINT LEGIBLY - IF POSSIBLE, LEAVE A BUSINESS CARD ²⁰¹² OCT -9 P 2:04

FIRM & REPRESENTATIVE NAME	MAILING ADDRESS	TELEPHONE & FAX NUMBERS
Company: <u>GREEN MOUNTAIN COMPANY</u> Rep: <u>David H. Bowman</u> Email Address: <u>DHB722@yahoo.com</u>	<u>511 50th ST</u> <u>Charleston WV</u> <u>25304</u>	PHONE <u>304-925-0253</u> TOLL FREE FAX <u>304-925-9230</u>
Company: <u>Hi-Tech Construction</u> Rep: <u>Mark Moss</u> Email Address: <u>Janet@Hi-Tech Construction.com</u>	<u>Charleston WV</u>	PHONE <u>304-746-0050</u> TOLL FREE <u>1-800-233-6809</u> FAX <u>304-746-4452</u>
Company: <u>Main Street Builders</u> Rep: <u>Steve Tibbs</u> Email Address: <u>stibbsmsbw.com</u>	<u>P.O. Box 309</u> <u>Princeton WV 24740</u>	PHONE <u>304-457-5912 ext 226</u> TOLL FREE FAX <u>304-425-8171</u>
Company: <u>All Construction Inc.</u> Rep: <u>Jeff Bunker</u> Email Address: <u>All & Frontier con</u>	<u>P.O. Box 756</u> <u>Mount Sterling, WV 26734</u>	PHONE <u>304-693-7191</u> TOLL FREE <u>304-693-7194</u> FAX <u>↗</u>
Company: <u>Capitol Valley Contracting</u> Rep: <u>Mickey Farmer</u> Email Address: <u>Mickey@Capitol-Valley.com</u>	<u>PO Box 920</u> <u>Elkview, WV 25071</u>	PHONE <u>304 437-4505</u> TOLL FREE FAX <u>304 965-2223</u>

SIGN IN SHEET

Qualification
Request for Proposal No. DEP 15898

PLEASE PRINT

Date: **10-3-12**

* PLEASE BE SURE TO PRINT LEGIBLY - IF POSSIBLE, LEAVE A BUSINESS CARD

TELEPHONE & FAX NUMBERS

FIRM & REPRESENTATIVE NAME	MAILING ADDRESS	TELEPHONE & FAX NUMBERS
Company: <u>ALL-CON, LLC</u> Rep: <u>DAVID IRLE</u> Email Address: <u>DIRLE@ACI-WV.COM</u>	<u>124 PHILPOTT LANE</u> <u>BEAVER WV 25813</u>	PHONE <u>304 731 0190</u> TOLL FREE FAX <u>304 255 4232</u>
Company: <u>SCS Engineers</u> Rep: <u>Larry Taylor</u> Email Address: <u>ltaylor@scseng.com</u>	<u>11260 Ridge Backan Drive</u> <u>Reston VA 20190</u>	PHONE <u>703-709-0004</u> TOLL FREE FAX <u>703-709-8379</u>
Company: <u>Bail Contracting Inc.</u> Rep: <u>Abigail Bail</u> Email Address: <u>Bailcon86@hotmail.com</u>	<u>2733 Canvas Nettie Road</u> <u>Canvas, WV 26662</u>	PHONE <u>304 872-6963</u> TOLL FREE FAX <u>304-872-0107</u>
Company: <u>WV DEP</u> Rep: <u>Mark Church</u> Email Address: <u>mark.A.Church@wv.gov</u>	<u>717A Main St.</u> <u>Summersville WV 26451</u>	PHONE <u>304-545-0793</u> TOLL FREE FAX <u>304 872-3800</u>
Company: <u>WV DEP</u> Rep: <u>Nate Meadows</u> Email Address: <u>Nathan.C.Meadows@wv.gov</u>	<u>601 57th St SE</u> <u>Charleston WV 25304</u>	PHONE <u>304-926-0499 x2230</u> TOLL FREE FAX

SIGN IN SHEET

Request for Proposal No. DEP 15898

PLEASE PRINT

Date: 10-3-12

* PLEASE BE SURE TO PRINT LEGIBLY - IF POSSIBLE, LEAVE A BUSINESS CARD

FIRM & REPRESENTATIVE NAME	MAILING ADDRESS	TELEPHONE & FAX NUMBERS
Company: <u>POJESTA</u>	<u>7012 MACCORDE AVE SE</u>	PHONE <u>304 342 1400</u>
Rep: <u>CHRIS GROSS</u>	<u>CHARLESTON, WV. 25304</u>	TOLL FREE
Email Address: <u>CAGROSS@POJESTA.COM</u>		FAX <u>304 343 9031</u>
Company: _____		PHONE
Rep: _____		TOLL FREE
Email Address: _____		FAX
Company: _____		PHONE
Rep: _____		TOLL FREE
Email Address: _____		FAX
Company: _____		PHONE
Rep: _____		TOLL FREE
Email Address: _____		FAX
Company: _____		PHONE
Rep: _____		TOLL FREE
Email Address: _____		FAX

ADDENDUM ACKNOWLEDGEMENT FORM
SOLICITATION NO.: DEP15898

Instructions: Please acknowledge receipt of all addenda issued with this solicitation by completing this addendum acknowledgment form. Check the box next to each addendum received and sign below. Failure to acknowledge addenda may result in bid disqualification.

Acknowledgment: I hereby acknowledge receipt of the following addenda and have made the necessary revisions to my proposal, plans and/or specification, etc.

Addendum Numbers Received:

(Check the box next to each addendum received)

- | | |
|---|--|
| <input type="checkbox"/> Addendum No. 1 | <input type="checkbox"/> Addendum No. 6 |
| <input type="checkbox"/> Addendum No. 2 | <input type="checkbox"/> Addendum No. 7 |
| <input type="checkbox"/> Addendum No. 3 | <input type="checkbox"/> Addendum No. 8 |
| <input type="checkbox"/> Addendum No. 4 | <input type="checkbox"/> Addendum No. 9 |
| <input type="checkbox"/> Addendum No. 5 | <input type="checkbox"/> Addendum No. 10 |

I understand that failure to confirm the receipt of addenda may be cause for rejection of this bid. I further understand that any verbal representation made or assumed to be made during any oral discussion held between Vendor's representatives and any state personnel is not binding. Only the information issued in writing and added to the specifications by an official addendum is binding.

Company

Authorized Signature

Date

NOTE: This addendum acknowledgement should be submitted with the bid to expedite document processing.
Revised 6/8/2012