



State of West Virginia
 Department of Administration
 Purchasing Division
 2019 Washington Street East
 Post Office Box 50130
 Charleston, WV 25305-0130

Solicitation

NUMBER
DEP15911

PAGE
1

ADDRESS CORRESPONDENCE TO ATTENTION OF:
GUY NISBET 304-558-8802

RFQ COPY
 TYPE NAME/ADDRESS HERE

VENDOR

SHIP TO

ENVIRONMENTAL PROTECTION
 DEPARTMENT OF
 OFFICE OF AML&R
 601 57TH STREET SE
 CHARLESTON, WV
 25304 304-926-0499

DATE PRINTED
07/11/2012

BID OPENING DATE: 07/26/2012 BID OPENING TIME 1:30PM

LINE	QUANTITY	UOP	CAT. NO.	ITEM NUMBER	UNIT PRICE	AMOUNT
0001	1	JB		962-73		
ADDENDUM NO. 1 ADDENDUM FOR THE "GREENBRIER HOLLOW REFUSE PILE PROJECT" ISSUED TO PUBLISH AND DISTRIBUTE THE ATTACHED INFORMATION. RECLAMATION: RESTORATION OF LAND & OTHER PROPERTIES ***** THIS IS THE END OF RFQ DEP15911 ***** TOTAL:						

SIGNATURE		TELEPHONE	DATE
TITLE	FEIN	ADDRESS CHANGES TO BE NOTED ABOVE	

WHEN RESPONDING TO SOLICITATION, INSERT NAME AND ADDRESS IN SPACE ABOVE LABELED 'VENDOR'

SOLICITATION NUMBER: DEP15911
Addendum Number: 01

The purpose of this addendum is to modify the solicitation identified as (“Solicitation”) to reflect the change(s) identified and described below.

Applicable Addendum Category:

- Modify bid opening date and time
- Modify specifications of product or service being sought
- Attachment of vendor questions and responses
- Attachment of pre-bid sign-in sheet
- Correction of error
- Other

Description of Modification to Solicitation:

- 1. Questions, Answers and revisions from Pre- Bid meeting
- 2. Pre-Bid sign-in sheet

No other changes.

Additional Documentation: Documentation related to this Addendum (if any) has been included herewith as Attachment A and is specifically incorporated herein by reference.

Terms and Conditions:

- 1. All provisions of the Solicitation and other addenda not modified herein shall remain in full force and effect.
- 2. Vendor should acknowledge receipt of all addenda issued for this Solicitation by completing an Addendum Acknowledgment, a copy of which is included herewith. Failure to acknowledge addenda may result in bid disqualification. The addendum acknowledgement should be submitted with the bid to expedite document processing.

ATTACHMENT A

DEP15911
Greenbrier Hollow Refuse Pile
Addendum # 1

Item 1: The contractor will have 120 days from the date of the Notice to Proceed to complete construction activities on the project. The \$250 per day liquidated damage clause will be in effect after the 120 days. However, the total performance period will be 365 days from the date of the Notice to Proceed for invoicing purposes.

Item 2: Grout to be used in the grouted riprap ditches shall consist of a cubic yard (CY) mixture as follows:

Cement – 470 lbs.

Fly Ash – 220 lbs.

Water – 316 lbs.

Air entrainment 6% +/- 2%

Sand – 2676 lbs.

Rheobuild 1000 (as needed to achieve the required slump and strength).

The minimum required compressive strength of the grout shall be 2000 psi @ 28 days. All testing shall be the responsibility of the contractor as part of the specifications. Two sets (4 cylinders) of test cylinders per day shall serve as a minimum.

Item 3: The WVDEP will obtain the necessary MM-109 encroachment permit(s). Contractor will be responsible for complying with all requirements of the permit, including all traffic control measures. Contractor will be responsible for backfilling around the 36-inch pipe with concrete to within 2-inches of the final road grade. The final 2-inches will consist of an HMA asphalt wearing course. Costs for concrete backfill and HMA wearing course will be incidental to Pay Item 7.5, 36-inch HDPE Pipe. Contractor will be responsible for all costs associated with any MM-109 bonding requirements.

Item 4: On Plan Sheet 7, the work showing wood, piers, and concrete structures to be removed will not be performed as part of the project scope. These structures are to remain in place.

Item 5: In reference to reimbursement for utility-related work, please refer to Section 11 of the Specifications. Contractor will be reimbursed for actual charges invoiced by the Utility Company. Prior to any utility relocation work, the Contractor shall submit a cost estimate of work to be accomplished to the WVDEP for approval.

Item 6: Q: If the gas company requires the Contractor to modify the gas line crossing detail shown in the plans, will the Contractor be compensated for the associated costs?

A: It is anticipated that the detail provided will satisfy all requirements of the gas companies. The Contractor is advised to consult with the gas companies prior to submitting a bid. Bids should be submitted, based on the details provided in the project plans.

Item 7: Survey cross sections for soil borrow areas will not be required.

Item 8: Q: If we encounter a domestic line in use at Site 2, and field adjustments are required in order to accommodate the line, will we be compensated for the associated costs?

A: It is not anticipated that a domestic water line will be encountered at Site 2. Contractor should submit an estimate based on the details shown on the project plans.

Item 9: Part of the construction access will be along the Hatfield & McCoy trail system. The contractor is to coordinate work/travel along the access road with the Hatfield & McCoy Trail Coordinator. The contact information is: John Fekete @ 304-687-9875 (cell) or 1-800-592-2217 (office).

SIGN IN SHEET

Page 1 of 2Request for ^{Quote} Proposal No. DEP15911Date 06-26-12Greenbrier Hollow Refuse Pile

*PLEASE BE SURE TO PRINT LEGIBLY – IF POSSIBLE, LEAVE A BUSINESS CARD

FIRM & REPRESENTATIVE NAME	MAILING ADDRESS	TELEPHONE & FAX NUMBERS
✓ Company: <u>EASTERN ARROW</u>	<u>PO Box 4108</u>	PHONE <u>414-6255</u>
Rep: <u>Ann Karsowicz</u>	<u>CHARLESTON WV 25304</u>	TOLL FREE <u>—</u>
Email Address: <u>easternarrow@hotmail.com</u>		FAX <u>6256</u>
✓ Company: <u>Pineville Paving & Excavating Inc.</u>	<u>P.O. Box 1290</u>	PHONE <u>304-732-8303</u>
Rep: <u>Tony Bradford</u>	<u>Pineville WV 24874</u>	TOLL FREE
Email Address: <u>tonyppi@aol.com</u>		FAX <u>304-732-7855</u>
Company: <u>Cody Energy</u>	<u>1185 Coal Heritage Rd</u>	PHONE <u>304-325-3431</u>
Rep: <u>Jerome McGlothlin</u>	<u>Bluefield WV 24701</u>	TOLL FREE
Email Address: <u>jmcglothlin@codyenergy.com</u>		FAX <u>304-325-2478</u>
✓ Company: <u>GREEN MOUNTAIN COMPANY</u>	<u>511 50th ST</u>	PHONE <u>304-425-0253</u>
Rep: <u>DAVID H. BOYMAN</u>	<u>Charleston WV 25304</u>	TOLL FREE
Email Address: <u>DHB 722@yahoo.com</u>		FAX <u>304 425-9230</u>
✓ Company: <u>Breakaway Inc.</u>	<u>1075 Old Turnpike Rd</u>	PHONE <u>765-5317</u>
Rep: <u>Doug Vincent</u>	<u>Sutton WV 26601</u>	TOLL FREE
Email Address: <u>doug@breakawaywv.com</u>		FAX <u>765-5389</u>

SIGN IN SHEET

Page 2 of 2Request for ^{Quote} Proposal No. DEP15911Date 06-26-12Greenbrier Hollow Refuse Pile

*PLEASE BE SURE TO PRINT LEGIBLY – IF POSSIBLE, LEAVE A BUSINESS CARD

FIRM & REPRESENTATIVE NAME	MAILING ADDRESS	TELEPHONE & FAX NUMBERS
Company: <u>ASA ENERGY INC</u>	<u>151 STEWART ST WALKER WVA 24801</u>	PHONE <u>304-320-3961</u>
Rep: <u>Wes Addair</u>		TOLL FREE
Email Address: <u>Wesaddair@hotmail.com</u>		FAX <u>304-436-5111</u>
Company: <u>FOOTHILL CONTRACTING LLC</u>		PHONE <u>(606) 743-4490</u>
Rep: <u>ANTHONY FREDERICK</u>		TOLL FREE
Email Address: <u>fcollc@mrtc.com</u>		FAX <u>(606) 743-4491</u>
Company: <u>STATAC CONSUMER SERVICES INC.</u>		PHONE <u>304-472-7140</u>
Rep: <u>Randy Calkins</u>		TOLL FREE
Email Address: <u>Randy.Calkins@statac.com</u>		FAX <u>304-472-6239</u>
Company: <u>Main Street Builders</u>		PHONE <u>304-487-3912</u>
Rep: <u>Rusty Sarver</u>		TOLL FREE
Email Address: <u>rusty.sarver@gmail.com</u>		FAX <u>304-425-2171</u>
Company:		PHONE
Rep:		TOLL FREE
Email Address:		FAX

ADDENDUM ACKNOWLEDGEMENT FORM
SOLICITATION NO.: DEP15911

Instructions: Please acknowledge receipt of all addenda issued with this solicitation by completing this addendum acknowledgment form. Check the box next to each addendum received and sign below. Failure to acknowledge addenda may result in bid disqualification.

Acknowledgment: I hereby acknowledge receipt of the following addenda and have made the necessary revisions to my proposal, plans and/or specification, etc.

Addendum Numbers Received:

(Check the box next to each addendum received)

- | | |
|---|--|
| <input type="checkbox"/> Addendum No. 1 | <input type="checkbox"/> Addendum No. 6 |
| <input type="checkbox"/> Addendum No. 2 | <input type="checkbox"/> Addendum No. 7 |
| <input type="checkbox"/> Addendum No. 3 | <input type="checkbox"/> Addendum No. 8 |
| <input type="checkbox"/> Addendum No. 4 | <input type="checkbox"/> Addendum No. 9 |
| <input type="checkbox"/> Addendum No. 5 | <input type="checkbox"/> Addendum No. 10 |

I understand that failure to confirm the receipt of addenda may be cause for rejection of this bid. I further understand that any verbal representation made or assumed to be made during any oral discussion held between Vendor's representatives and any state personnel is not binding. Only the information issued in writing and added to the specifications by an official addendum is binding.

Company

Authorized Signature

Date

NOTE: This addendum acknowledgement should be submitted with the bid to expedite document processing.

Revised 6/8/2012