



State of West Virginia  
 Department of Administration  
 Purchasing Division  
 2019 Washington Street East  
 Post Office Box 50130  
 Charleston, WV 25305-0130

**Solicitation**

NUMBER
DEP15987

PAGE
1

ADDRESS CORRESPONDENCE TO ATTENTION OF:
GUY NISBET 304-558-8802

VENDOR

RFQ COPY  
 TYPE NAME/ADDRESS HERE

SHIP TO

ENVIRONMENTAL PROTECTION  
 DEPARTMENT OF  
 OFFICE OF AML&R  
 601 57TH STREET SE  
 CHARLESTON, WV  
 25304 304-926-0499

DATE PRINTED
--------------

10/19/2012
------------

BID OPENING DATE:

10/30/2012

BID OPENING TIME 1:30PM

LINE	QUANTITY	UOP	CAT NO.	ITEM NUMBER	UNIT PRICE	AMOUNT
				ADDENDUM NO.1		
				ADDENDUM FOR THE "DALE R. THRASHER" PROJECT ISSUED TO PUBLISH AND DISTRIBUTE THE ATTACHED DOCUMENTATION.		
				1. Q & A'S		
				2. PRE BID SIGN IN SHEET		
0001	1	JB		962-73		
				RECLAMATION: RESTORATION OF LAND & OTHER PROPERTIES		
***** THIS IS THE END OF RFQ DEP15987 ***** TOTAL:						

SIGNATURE		TELEPHONE	DATE
TITLE	FEIN	ADDRESS CHANGES TO BE NOTED ABOVE	

WHEN RESPONDING TO SOLICITATION, INSERT NAME AND ADDRESS IN SPACE ABOVE LABELED 'VENDOR'

SOLICITATION NUMBER: DEP15987  
 Addendum Number: No.1

---

The purpose of this addendum is to modify the solicitation identified as ("Solicitation") to reflect the change(s) identified and described below.

**Applicable Addendum Category:**

- Modify bid opening date and time
- Modify specifications of product or service being sought
- Attachment of vendor questions and responses
- Attachment of pre-bid sign-in sheet
- Correction of error
- Other

**Description of Modification to Solicitation:**

Addendum for the "Dale R. Thrasher" project issued to publish and distribute the following information.

1. Q & A's
2. Pre-Bid Sign in sheet from meeting
3. No other changes

**Additional Documentation:** Documentation related to this Addendum (if any) has been included herewith as Attachment A and is specifically incorporated herein by reference.

**Terms and Conditions:**

1. All provisions of the Solicitation and other addenda not modified herein shall remain in full force and effect.
2. Vendor should acknowledge receipt of all addenda issued for this Solicitation by completing an Addendum Acknowledgment, a copy of which is included herewith. Failure to acknowledge addenda may result in bid disqualification. The addendum acknowledgement should be submitted with the bid to expedite document processing.

# ATTACHMENT A

**DEP15987**  
**Dale R. Trasher**  
**Addendum #1**

- Item 1: The Contractor shall have 120 days from the date of the Notice to Proceed to complete construction activities on the project. The \$250 per day liquidated damage clause will be in effect after the 120 days. However, the total performance period will be 365 days from the date of the Notice to Proceed for invoicing purposes.
- Item 2: Q - What are the Cut and Fill Volume Calculations, and do they balance?  
A - For practical purposes, the cut and fill volumes balance. Actual calculations are 93,695 CY for cut and 89,984 CY for fill. Please note that for bidding purposes on the bid schedule, Item 8.0 (Unclassified Excavation) has been rounded to 100,000 CY. (Project Manager's Note: The volumes were re-calculated after the Pre-Bid Conference, and the values given at the Pre-Bid Conference should be disregarded.)
- Item 3: Statement - Sequence of Construction: See Item 17 for a detailed Sequence of Construction, which was discussed at the Pre-Bid Conference.
- Item 4: Q - What is the pH of the water?  
A - The pH for the water tested at two locations was 7.5 and 7.4. The two water samples were from borehole B-4 and the pond.
- Item 5: Statement - Pipelines: An exposed metal pipe, approximately 1 ½ in diameter was visible in the access road between where the Pre-Bid Conference Started (at the Jeep) and the top of the hill. This line is not marked on the drawings. A yellow marker post marked the location. It is not known if this line is an active line, or if it is a gas line.  
The marker post had this information on it:  
ECA - Energy Corporation of America  
24 hour phone no. 304-472-6100  
It is the Contractor's responsibility to determine if this line is an active line, and to protect it from damage during construction operations and access road construction. A black plastic line, approx. 1 inch in diameter, was also observed in this same area, and will also need to be identified and protected if it is an active line.
- Item 6: Q - Where is the limit of the area that the boulders that need to be removed (that have fallen from the highwall near the camping trailers)?  
A - The limit of the area that the boulders need to be removed is 300 ft. east of station 0+00 (along the existing access road). This was extended approx. 80 ft. beyond the circled area on Sheet 4 of the design drawings.

**DEP15987**  
**Dale R. Trasher**  
**Addendum #1**

- Item 7: Q - Where does the impounded water area start?  
A - Relative to the Baseline, the impounded water area begins near Baseline Station 8+15.
- Item 8: Q - Is the constructed access road a bid item?  
A - Yes. The constructed access road is to be bid based on Bid Items 13.1 and 13.2, which are based on stone tonnage and square yards of separation fabric. See Sheet 19, Detail no. 3/19 for constructed access road specifications.
- Item 9: Q - Which way does drainage go for the first portal (Portal ME-1)?  
A - The drainage from Portal ME-1 drains to the northeast into Channel No. 6 (see Sheet 4). The mine entries are not shown on Sheet 6.
- Item 10: Q - Can the trees and brush be burned?  
A - Yes, if done according to Specification section 4.0, and specifically section 4.3.6 relating to burning organic material. Burning will not be allowed on coal refuse, or other areas listed in section 4.3.6. Also, see section 4.3.2 for timber larger than eight (8) inches in diameter.
- Item 11: Q - Is the area by the hunting cabin on coal refuse?  
A - The WVDEP does not believe this area is coal refuse.
- Item 12: Q - If soil is taken from the potential borrow area indicated on Sheet 4, will it be included in the calculation of unclassified excavation?  
A - No. Sections 8.6 of the specifications indicates that excavated material for soil cover will be considered incidental to Item 8.0, Unclassified Excavation.
- Item 13: Q - Are the proposed riprap channels to be lined only with limestone?  
A - No, the channel lining stone can be sound and durable limestone, or sandstone from a WVDEP approved source. Dolomitic limestone shall not be used on this project. Refer to section 7.2.2 for testing requirements.

**DEP15987**  
**Dale R. Trasher**  
**Addendum #1**

Item 14: Q - Is the demolition of the structure, (coal loadout remains on Sheet 4) based on a per foot bid cost, and what is its' length?

A - No. It is a lump sum item included in Bid Item 4.2. The exact length of the structure is not known.

Item 15: Q - Can the coal loadout structure be burned.

A - No. It must be disposed of in an environmentally acceptable way, approved by the WVDEP.

Item 16: Statement - Grout Specifications: The WVDEP standard grout specification listed below is to replace the mixture requirements in item 7.2.4 in the Specifications:

“Grout to be used in the grouted riprap ditches shall consist of a cubic yard (CY) mixture as follows;

Cement - 470 lbs

Fly Ash - 220 lbs

Water - 316 lbs

Air Entrainment - 6% +/-2 %

Sand - 2676 lbs

Rheobuild 1000 (as needed to achieve the required slump and strength)

The minimum required compressive strength of the grout shall be 2000 psi @ 28 days. All testing shall be the responsibility of the contractor as part these specifications. Two sets (4 cylinders) of test cylinders per day shall serve as a minimum.”

**DEP15987**  
**Dale R. Trasher**  
**Addendum #1**

Item 17: Sequence of Construction:

- Install Erosion and Sediment Controls for Access Roads
- Construct Access Roads
- Ensure Installation of Super Silt Fence as Show on Plans
- Clearing and Grubbing
- Demolition and Removal of Structures
- Install Clean Water Diversion at Proposed Channel #10
  - Ensure diversion begins above proposed grading limits and discharges below proposed grading limits with proper scour protection at discharge
- Grading to Reduce Highwalls from Station 24+47 to approximately 16+00
- Install Erosion Control Wattles on Regraded Fill Slope
- Construct Drainage Channels and Rock Check Dams (Channels #9, 10 and 11)
- Revegetate Disturbed Area
- Remove Clean Water Diversion at Channel #10 and Return Natural Drainage to Completed Channel
- Install Clean Water Diversions at Proposed Channels #5 and #7
  - Ensure diversion begins above proposed grading limits and discharges below proposed grading limits with proper scour protection at discharge
- Grading to Reduce Highwalls from Stations 16+00 to approximately 5+00
- Install Erosion Control Wattles on Regraded Fill Slope
- Construct Drainage Channels and Rock Check Dams (Channels #3, 4, 5, 6, 7, 8 and 12)
- Install Modified Wet Seals at ME-1 and ME-2
- Revegetate Disturbed Area
- Remove Clean Water Diversions at Channels #5 and #7 and Return Natural Drainage to Completed Channel
- Grading to Reduce Highwall from Stations 5+00 to 0+00
- Install Erosion Control Wattles on Regraded Fill Slope
- Construct Drainage Channels and Rock Check Dams (Channels #1 and #2)
- Revegetate Disturbed Area

REQUEST FOR QUOTATION NO. DEP15987

**SIGN IN SHEET**

Page 1 of 4

Dale R. Trasher

PLEASE PRINT

Date: October 2, 2012

\* PLEASE BE SURE TO PRINT LEGIBLY - IF POSSIBLE, LEAVE A BUSINESS CARD

FIRM & REPRESENTATIVE NAME	MAILING ADDRESS	TELEPHONE & FAX NUMBERS
Company: <u>GREEN MOUNTAIN COMPANY</u> Rep: <u>DAVID H. BOWMAN</u> Email Address: <u>DHB722@yahoo.com</u>	<u>511 50th ST,</u> <u>Charleston WV</u> <u>25304</u>	PHONE <u>304 925-0253</u> TOLL FREE FAX <u>304-925-9230</u>
Company: <u>CONCRETE UP INC</u> Rep: <u>DENNIS C. ELSON</u> Email Address: <u>DCE-CONCRETEUP@CARTRIDGE.NET</u>	<u>PO Box 243</u> <u>SIERRA WV 26435</u>	PHONE <u>304 739-4397</u> TOLL FREE FAX <u>304-739-4401</u>
Company: <u>Cave Run Contracting</u> Rep: <u>Chris Szabo</u> Email Address: <u>ridelikewhat@hotmail.com</u>	<u>P.O. Box 104</u> <u>Moatsville WV 26405</u>	PHONE <u>304 622 8550</u> TOLL FREE FAX <u>304-622-7026</u>
Company: <u>LAURITA Inc.</u> Rep: <u>Chris decker</u> Email Address: <u>Chrisdecker@laurita.com</u>	<u>302 Dents Row Road</u> <u>Morgantown, WV</u> <u>26501</u>	PHONE <u>304-296-7531</u> TOLL FREE FAX <u>304-292-4606</u>
Company: <u>Hä Tech con.</u> Rep: <u>Mark Moss</u> Email Address: _____	<u>PO Box 8601 SoChap</u> <u>25303</u>	PHONE <u>304-746-0050</u> TOLL FREE FAX <u>304-746-4452</u>



REQUEST FOR QUOTATION NO. DEP15987

**SIGN IN SHEET**

Page 2 of 4

Dale R. Trasher

PLEASE PRINT

Date: October 2, 2012

\* PLEASE BE SURE TO PRINT LEGIBLY - IF POSSIBLE, LEAVE A BUSINESS CARD

FIRM & REPRESENTATIVE NAME	MAILING ADDRESS	TELEPHONE & FAX NUMBERS
Company: <u>Hatch Mott MacDonald</u> Rep: <u>Rich Rogers</u> Email Address: <u>richard.rogers@hatchmott.com</u>	<u>2601 Cranberry Square</u> <u>Morgan town, WV 26508</u>	PHONE <u>304-517-4131</u> TOLL FREE FAX
Company: <u>HATCH MOTT MACDONALD</u> Rep: <u>JEFF LAW</u> Email Address: <u>jeffrey.law@hatchmott.com</u>	<u>2601 CRANBERRY SQUARE</u> <u>MORGANTOWN, WV 26508</u>	PHONE <u>304-286-0199</u> TOLL FREE FAX
Company: <u>JF ALLIEN CO</u> Rep: <u>JAMIES ALLIEN</u> Email Address: <u>JAMIES.ALLIEN@JF-ALLIENCO.COM</u>	<u>PO BOX 2049</u> <u>Beckhannon WV</u> <u>26201</u>	PHONE <u>304 472 8890</u> TOLL FREE FAX <u>304 472 8897</u>
Company: <u>High Point Construction</u> Rep: <u>Todd Brockman</u> Email Address: <u>T.Brockman@HighpointWV.com</u>	<u>Beckhannon WV 26201</u>	PHONE <u>(304) 472-5595</u> TOLL FREE FAX
Company: <u>Eastern Arrow</u> Rep: <u>Ann Klausner</u> Email Address: <u>easternarrow@hotmail.com</u>	<u>PO BOX 4108</u> <u>CHARLESTON, WV 25314</u>	PHONE <u>304-414-0255</u> TOLL FREE FAX <u>0256</u>

REQUEST FOR QUOTATION NO. DEP15987

**SIGN IN SHEET**

Page 3 of 4

Dale R. Trasher

PLEASE PRINT

Date: October 2, 2012

\* PLEASE BE SURE TO PRINT LEGIBLY - IF POSSIBLE, LEAVE A BUSINESS CARD

FIRM & REPRESENTATIVE NAME	MAILING ADDRESS	TELEPHONE & FAX NUMBERS
Company: <u>Collins Building &amp; Contracting</u> Rep: <u>Roger Collins Jr.</u> Email Address: <u>Collinsbuilding@Hughes.net</u>	<u>7404 Carly Rd</u> <u>Fluoromonds, WV</u> <u>26021</u>	PHONE <u>304-765-3521</u> TOLL FREE FAX <u>304-765-3521</u>
Company: <u>ALL-CON, LLC</u> Rep: <u>DAVID IRLE</u> Email Address: <u>DAVID@ALLCON.WV.COM</u>	<u>124 PHILPOTT LANE</u> <u>BEAVER WV 25813</u>	PHONE <u>304-731-0990</u> TOLL FREE FAX <u>304-255-4232</u>
Company: <u>Barnes EXC. Inc.</u> Rep: <u>Robert Barnes</u> Email Address: <u>Barnes EXC@AOL.COM</u>	<u>P.O. BOX 13384</u> <u>Sissonville</u> <u>WV 25360</u>	PHONE <u>304-984-1725</u> TOLL FREE FAX <u>304-984-0074</u>
Company: <u>Carpenter Reclamation Inc</u> Rep: <u>Randy Carpenter</u> Email Address: <u>Rcarpen13@aol.com</u>	<u>PO BX 13815</u> <u>Sissonville, WV</u> <u>25360</u>	PHONE <u>304-984-1115</u> TOLL FREE FAX <u>984-2770</u>
Company: <u>BREAKAWAY, Inc.</u> Rep: <u>Doug Vincent</u> Email Address: <u>doug@breakaway.wv.com</u>	<u>Doug Vincent</u> <u>1075 Old Turnpike Rd</u> <u>Seton WV 26601</u>	PHONE <u>765-5317</u> TOLL FREE FAX <u>765-5389</u>

REQUEST FOR QUOTATION NO. DEP15987

**SIGN IN SHEET**

Page 4 of 4

Dale R. Trasher

PLEASE PRINT

Date: October 2, 2012

\* PLEASE BE SURE TO PRINT LEGIBLY - IF POSSIBLE, LEAVE A BUSINESS CARD

FIRM & REPRESENTATIVE NAME	MAILING ADDRESS	TELEPHONE & FAX NUMBERS
Company: <u>EAGLE EXCAVATION INC</u> Rep: <u>GEORGE FRESHOUR</u> Email Address: <u>None</u>	<u>P.O. BOX 218</u> <u>KENNA, WV</u> <u>25248</u>	PHONE <u>(304) 372-4378</u> TOLL FREE <u>None</u> FAX <u>(304) 372-4378</u>
Company: <u>McCourt's Saw Coast.</u> Rep: <u>GARY Long</u> Email Address: <u>glong@wirefire.com</u>	<u>2790 Centralia Rd</u> <u>Sutton WV 26601</u>	PHONE <u>(304) 765-5288</u> TOLL FREE FAX <u>(304) 765-5293</u>
Company: <u>Doss Enterprises</u> Rep: <u>Rodney Somerville</u> Email Address: <u>rodneysomerville@dossenterprises.com</u>	<u>7522 US Hwy 19W</u> <u>JANESVILLE WV</u>	PHONE <u>304-884-2325</u> TOLL FREE FAX <u>304 884-2328</u>
Company: <u>VECCELLIO &amp; Grogan, Inc</u> Rep: <u>Ray Adkins</u> Email Address: <u>RAY.ADKINS@vecelligrogan.com</u>	<u>2251 Robert C Byrd Dr</u> <u>Beckley, WV 25802</u>	PHONE <u>304-712-4186</u> TOLL FREE FAX <u>304-252-4131</u>
Company: <u>Foster Supply Inc</u> Rep: <u>Dion Wamsley</u> Email Address: <u>dwamsley@fostersupply.com</u>	<u>RT 1 Box 44</u> <u>Mt Clair WV</u>	PHONE <u>304-203-2351</u> TOLL FREE FAX <u>304-326-0196</u>

**ADDENDUM ACKNOWLEDGEMENT FORM**  
**SOLICITATION NO.:** DEP15987

**Instructions:** Please acknowledge receipt of all addenda issued with this solicitation by completing this addendum acknowledgment form. Check the box next to each addendum received and sign below. Failure to acknowledge addenda may result in bid disqualification.

**Acknowledgment:** I hereby acknowledge receipt of the following addenda and have made the necessary revisions to my proposal, plans and/or specification, etc.

**Addendum Numbers Received:**

(Check the box next to each addendum received)

- |   |  |
|---|--|
| <input type="checkbox"/> Addendum No. 1 | <input type="checkbox"/> Addendum No. 6  |
| <input type="checkbox"/> Addendum No. 2 | <input type="checkbox"/> Addendum No. 7  |
| <input type="checkbox"/> Addendum No. 3 | <input type="checkbox"/> Addendum No. 8  |
| <input type="checkbox"/> Addendum No. 4 | <input type="checkbox"/> Addendum No. 9  |
| <input type="checkbox"/> Addendum No. 5 | <input type="checkbox"/> Addendum No. 10 |

I understand that failure to confirm the receipt of addenda may be cause for rejection of this bid. I further understand that any verbal representation made or assumed to be made during any oral discussion held between Vendor's representatives and any state personnel is not binding. Only the information issued in writing and added to the specifications by an official addendum is binding.

\_\_\_\_\_  
Company

\_\_\_\_\_  
Authorized Signature

\_\_\_\_\_  
Date

NOTE: This addendum acknowledgment should be submitted with the bid to expedite document processing.  
Revised 6/8/2012