



State of West Virginia
 Department of Administration
 Purchasing Division
 2019 Washington Street East
 Post Office Box 50130
 Charleston, WV 25305-0130

Solicitation

NUMBER
DEP16184

PAGE
1

ADDRESS CORRESPONDENCE TO ATTENTION OF:
FRANK WHITTAKER 304-558-2316

RFQ COPY
 TYPE NAME/ADDRESS HERE

VENDOR

SHIP TO

ENVIRONMENTAL PROTECTION
 DEPARTMENT OF
 OFFICE OF AML&R
 601 57TH STREET SE
 CHARLESTON, WV
 25304 304-926-0499

DATE PRINTED
05/21/2013

BID OPENING DATE: 05/30/2013 BID OPENING TIME 1:30PM

LINE	QUANTITY	UOP	CAT NO	ITEM NUMBER	UNIT PRICE	AMOUNT
ADDENDUM NO. 1						
1.				ADDENDUM IS ISSUED TO PROVIDE ANSWER TO QUESTIONS REGARDING THE SOLICITATION AND TO ADDRESS CHANGES MADE TO THE SPECIFICATIONS.		
2.				TO PROVIDE VENDORS A COPY OF THE MANDATORY PRE-BID MEETING SIGN-IN SHEETS.		
3.				TO PROVIDE ADDENDUM ACKNOWLEDGEMENT. THIS DOCUMENT SHOULD BE SIGNED AND RETURNED WITH YOUR BID. FAILURE TO SIGN AND RETURN MAY RESULT IN THE DISQUALIFICATION OF YOUR BID.		
***** END OF ADDENDUM NO. 1 *****						

SIGNATURE		TELEPHONE	DATE
TITLE	FEIN	ADDRESS CHANGES TO BE NOTED ABOVE	

WHEN RESPONDING TO SOLICITATION, INSERT NAME AND ADDRESS IN SPACE ABOVE LABELED 'VENDOR'



State of West Virginia
 Department of Administration
 Purchasing Division
 2019 Washington Street East
 Post Office Box 50130
 Charleston, WV 25305-0130

Solicitation

NUMBER
DEP16184

PAGE
2

ADDRESS CORRESPONDENCE TO ATTENTION OF
FRANK WHITTAKER 304-558-2316

VENDOR

RFQ COPY
 TYPE NAME/ADDRESS HERE

SHIP TO

ENVIRONMENTAL PROTECTION
 DEPARTMENT OF
 OFFICE OF AML&R
 601 57TH STREET SE
 CHARLESTON, WV
 25304 304-926-0499

DATE PRINTED
05/21/2013

BID OPENING DATE: 05/30/2013 BID OPENING TIME 1:30PM

LINE	QUANTITY	UOP	CAT NO.	ITEM NUMBER	UNIT PRICE	AMOUNT
0001	1	JB		962-73		
RECLAMATION: RESTORATION OF LAND & OTHER PROPERTIES						
***** THIS IS THE END OF RFQ DEP16184 ***** TOTAL:						

SIGNATURE		TELEPHONE	DATE
TITLE	FEIN	ADDRESS CHANGES TO BE NOTED ABOVE	

WHEN RESPONDING TO SOLICITATION, INSERT NAME AND ADDRESS IN SPACE ABOVE LABELED 'VENDOR'

SOLICITATION NUMBER: DEP16184
Addendum Number: 1

The purpose of this addendum is to modify the solicitation identified as (“Solicitation”) to reflect the change(s) identified and described below.

Applicable Addendum Category:

- Modify bid opening date and time
- Modify specifications of product or service being sought
- Attachment of vendor questions and responses
- Attachment of pre-bid sign-in sheet
- Correction of error
- Other

Description of Modification to Solicitation:

1. To provide answer to questions asked regarding the RFQ and to address changes made to the specifications.
2. To provide vendors a copy of the mandatory pre-bid sign-in sheets.
3. To provide Addendum Acknowledgement.

Additional Documentation: Documentation related to this Addendum (if any) has been included herewith as Attachment A and is specifically incorporated herein by reference.

Terms and Conditions:

1. All provisions of the Solicitation and other addenda not modified herein shall remain in full force and effect.
2. Vendor should acknowledge receipt of all addenda issued for this Solicitation by completing an Addendum Acknowledgment, a copy of which is included herewith. Failure to acknowledge addenda may result in bid disqualification. The addendum acknowledgement should be submitted with the bid to expedite document processing.

ATTACHMENT A

Indian Creek Refuse Pile

DEP16184

Addendum #1

The Contractor will have 60 days from the date of the Notice to Proceed to complete construction activities on the project. The \$250 per day liquidated damages clause will be in effect after the 60 days. However, the total performance period will be 365 days from the date of the Notice to Proceed for invoicing purposes.

PRE-BID MEETING QUESTIONS AND ANSWERS:

Question and Answers

A. **Question:** Is hydro-seeding required?

Answer: Yes, hydro-seeding is the required method of seeding for the refuse pile area.

B. **Question:** Can regular silt fence be used instead of the proposed straw wattles?

Answer: Yes, regular silt fence can be substituted for the proposed silt fence.

If silt fence is used, it must be installed properly, trenched in, and the contractor will be required to remove the silt fence, once vegetation has been established.

Straw wattles were proposed because wattles can be left in place after installation.

Equipment is not permitted on the slope and refuse area. Silt fence trenching will have to be performed by hand.

CHANGES TO SPECIFICATIONS:

A. The drawing sheets calls for 315 feet of chain link fence; while the bid schedule calls for 320 feet of chain link fence. The contractor shall install 320 feet of chain link fence.

Comments and Clarification

A. No grubbing shall be permitted on this project.

B. The area specified for the new chain link fence shall be cleared, but NOT grubbed. Vegetation and trees shall be cut at ground level leaving the root system intact. Special care is to given as not cause the slope to become unstable.

- C. The refuse pile area shall not to be cleared or grubbed.
- D. The refuse pile shall be direct seeded as proposed in the specification. The use of soil amendments shall be permitted on this project; however it is not required. The use of soil amendments shall be at the contractor's expense. Contractor's requesting to use a soil amendment shall submit that proposal the Department of Environmental Protection (DEP), Office of Abandon Mine Lands (AML) prior to performing the work.
- E. The contractor is held to a one year warranty period on all work and seeding; therefore it is **recommended** that direct seeding be performed during the cooler seasons of the year. The refuse can burn the seed during the hot months of summer. The aforementioned are recommendations of the DEP; however the schedule of work is the sole responsible of the contractor.
- F. Work on the refuse pile area shall be performed using hand tools only; no equipment will be permitted on the refuse area. Furthermore it is RECOMMENDED, that work on the fence area be performed by hand as well. Contractor will be responsible for repairing any damages to the project site, at the contractor's expense.
- G. All unsuitable materials, construction debris, existing fence, and trash shall be removed from the site and disposed of properly; at the contractors expense.
- H. Burning is NOT permitted on this project site. Burnable materials shall be disposed of properly, off site, at the contractor's expense.
- I. It is the responsibility of the contractor to confirm and locate all utilities prior to beginning work. It is recommended that the contractor contact the church and inquire about sanitary sewer system for the church. Damages to any utilities caused by contractor shall be repaired at the contractor's expense.
- J. The (DEP) shall reimburse the contractor for any required relocation or alterations to existing utilities. This reimbursement requires prior approval, and no markup on cost shall be permitted. The DEP shall only reimburse for the invoice amounts.
- K. Submittal of cut sheets for material is required for all materials used on this project.
- L. A copy of the certified payroll must accompany applications for payment.
- M. Contractor is responsible for field verifying all measurements.

SIGN IN SHEET

Request for ^{QUOTE} Proposal No. DEP16184

Date 05-09-13

Indian Creek Refuse Pile

***PLEASE BE SURE TO PRINT LEGIBLY – IF POSSIBLE, LEAVE A BUSINESS CARD**

FIRM & REPRESENTATIVE NAME

MAILING ADDRESS

TELEPHONE & FAX NUMBERS

Company: <u>A+A Energy INC</u>	<u>151 Stewart street Welch WVA 24801</u>	PHONE <u>304-320-3961</u>
Rep: <u>John Winner - Welsy</u>	<u>Alcoa</u>	TOLL FREE
Email Address:		FAX <u>304 320 ⁴³⁶ 5111</u>
Company: <u>CLCO Corp</u>	<u>Drawer A</u>	PHONE <u>276-880-1034</u>
Rep: <u>Terry Ball</u>	<u>Rosedale Va. 24280</u>	TOLL FREE
Email Address: <u>terry@clco.com</u>		FAX <u>276-880-3119</u>
Company: <u>Nemesis Contracting LLC</u>	<u>4444 G Porel Fork Road</u>	PHONE <u>304 247 6934</u>
Rep: <u>Dave Farmer / Ina Rash</u>	<u>Wheaton W.V. 25208</u>	TOLL FREE
Email Address: <u>info@nemesiscontracting.com</u>		FAX
Company: <u>Thyken Construction</u>	<u>Box 1 Whitetail Lane</u>	PHONE <u>304 984-2299</u>
Rep: <u>Duke Thyken</u>	<u>Charleston, WV</u>	TOLL FREE
Email Address:	<u>25312</u>	FAX
Company: <u>FOSTER SUPPLY</u>	<u>PO Box 488</u>	PHONE <u>304-553-6965</u>
Rep: <u>DERRICK SEARS</u>	<u>SCOTT DEPOT WJ 25560</u>	TOLL FREE
Email Address: <u>dsears@foster supply.com</u>		FAX <u>304-755-8280</u>

ADDENDUM ACKNOWLEDGEMENT FORM
SOLICITATION NO.: DEP16184

Instructions: Please acknowledge receipt of all addenda issued with this solicitation by completing this addendum acknowledgment form. Check the box next to each addendum received and sign below. Failure to acknowledge addenda may result in bid disqualification.

Acknowledgment: I hereby acknowledge receipt of the following addenda and have made the necessary revisions to my proposal, plans and/or specification, etc.

Addendum Numbers Received:

(Check the box next to each addendum received)

- | | |
|---|--|
| <input type="checkbox"/> Addendum No. 1 | <input type="checkbox"/> Addendum No. 6 |
| <input type="checkbox"/> Addendum No. 2 | <input type="checkbox"/> Addendum No. 7 |
| <input type="checkbox"/> Addendum No. 3 | <input type="checkbox"/> Addendum No. 8 |
| <input type="checkbox"/> Addendum No. 4 | <input type="checkbox"/> Addendum No. 9 |
| <input type="checkbox"/> Addendum No. 5 | <input type="checkbox"/> Addendum No. 10 |

I understand that failure to confirm the receipt of addenda may be cause for rejection of this bid. I further understand that any verbal representation made or assumed to be made during any oral discussion held between Vendor's representatives and any state personnel is not binding. Only the information issued in writing and added to the specifications by an official addendum is binding.

Company

Authorized Signature

Date

NOTE: This addendum acknowledgement should be submitted with the bid to expedite document processing.
 Revised 6/8/2012