



State of West Virginia  
 Department of Administration  
 Purchasing Division  
 2019 Washington Street East  
 Post Office Box 50130  
 Charleston, WV 25305-0130

# Solicitation

NUMBER
DEP16197

PAGE
1

ADDRESS CORRESPONDENCE TO ATTENTION OF:
FRANK WHITTAKER 304-558-2316

V E N D O R	RFQ COPY
	TYPE NAME/ADDRESS HERE

S H I P T O	ENVIRONMENTAL PROTECTION DEPARTMENT OF OFFICE OF AML&R 601 57TH STREET SE CHARLESTON, WV 25304	304-926-0499
----------------------------	---	--------------

DATE PRINTED
04/30/2013

BID OPENING DATE: 05/09/2013 BID OPENING TIME 1:30PM

LINE	QUANTITY	UOP	CAT. NO.	ITEM NUMBER	UNIT PRICE	AMOUNT
ADDENDUM NO. 1						
1.				ADDENDUM ISSUED TO PROVIDE VENDORS A COPY OF THE MANDATORY PRE-BID SIGN-IN SHEET.		
2.				TO PROVIDE ANSWERS TO QUESTIONS REGARDING THE ORIGINAL SOLICITATION. REVISIONS ARE ALSO INCLUDED AS DEFINED IN THE ATTACHED QUESTION & ANSWER SHEET.		
3.				TO PROVIDE AN ESTIMATED CUT AND FILL QUANTITIES FOR THE REFUSE PILE. CUT AND FILL TABLE IS ATTACHED.		
4.				TO PROVIDE ADDENDUM ACKNOWLEDGEMENT. THIS DOCUMENT SHOULD BE SIGNED AND RETURNED WITH YOUR BID. FAILURE TO SIGN AND RETURN MAY RESULT IN THE DISQUALIFICATION OF YOUR BID.		
END OF ADDENDUM NO. 1						

SIGNATURE		TELEPHONE	DATE
TITLE	FEIN	ADDRESS CHANGES TO BE NOTED ABOVE	

WHEN RESPONDING TO SOLICITATION, INSERT NAME AND ADDRESS IN SPACE ABOVE LABELED 'VENDOR'



State of West Virginia  
 Department of Administration  
 Purchasing Division  
 2019 Washington Street East  
 Post Office Box 50130  
 Charleston, WV 25305-0130

# Solicitation

NUMBER
DEP16197

PAGE
2

ADDRESS CORRESPONDENCE TO ATTENTION OF:
FRANK WHITTAKER
304-558-2316

RFQ COPY  
 TYPE NAME/ADDRESS HERE

VENDOR

SHIP TO

ENVIRONMENTAL PROTECTION  
 DEPARTMENT OF  
 OFFICE OF AML&R  
 601 57TH STREET SE  
 CHARLESTON, WV  
 25304 304-926-0499

DATE PRINTED
04/30/2013

BID OPENING DATE: 05/09/2013 BID OPENING TIME 1:30PM

LINE	QUANTITY	UOP	CAT. NO.	ITEM NUMBER	UNIT PRICE	AMOUNT
0001	1	JB		962-73		
RECLAMATION: RESTORATION OF LAND & OTHER PROPERTIES						
***** THIS IS THE END OF RFQ DEP16197 ***** TOTAL:						

SIGNATURE		TELEPHONE	DATE
TITLE	FEIN	ADDRESS CHANGES TO BE NOTED ABOVE	

WHEN RESPONDING TO SOLICITATION, INSERT NAME AND ADDRESS IN SPACE ABOVE LABELED 'VENDOR'

SOLICITATION NUMBER: DEP16197

Addendum Number: 1

---

The purpose of this addendum is to modify the solicitation identified as (“Solicitation”) to reflect the change(s) identified and described below.

**Applicable Addendum Category:**

- Modify bid opening date and time
- Modify specifications of product or service being sought
- Attachment of vendor questions and responses
- Attachment of pre-bid sign-in sheet
- Correction of error
- Other

**Description of Modification to Solicitation:**

1. To provide Vendors a copy of the mandatory pre-bid sign-in sheet.
2. To provide answer to questions submitted.
3. To provide revisions; also included in the Q&A sheet.
4. To provide Addendum Acknowledgement.

**Additional Documentation:** Documentation related to this Addendum (if any) has been included herewith as Attachment A and is specifically incorporated herein by reference.

**Terms and Conditions:**

1. All provisions of the Solicitation and other addenda not modified herein shall remain in full force and effect.
2. Vendor should acknowledge receipt of all addenda issued for this Solicitation by completing an Addendum Acknowledgment, a copy of which is included herewith. Failure to acknowledge addenda may result in bid disqualification. The addendum acknowledgement should be submitted with the bid to expedite document processing.

# ATTACHMENT A

**DEP16197**  
**Abney Refuse Piles**  
**Addendum # 1**

Item 1: The contractor will have 180 days from the date of the Notice to Proceed to complete construction activities on the project. The \$250 per day liquidated damage clause will be in effect after the 180 days. However, the total performance period will be 365 days from the date of the Notice to Proceed for invoicing purposes.

Item 2: All rock riprap used throughout the project shall consist of locally available, commercially purchased, or on-site durable stone meeting the following requirements. The rock riprap shall have a maximum weighted loss of thirty percent when subjected to five (5) cycles of the Sodium Sulfate Soundness Test, 30% requirement – ASTM C88 (ASTM C88-99a Standard Test Method for Soundness of Aggregates by Use of Sodium Sulfate or Magnesium Sulfate), as modified by the American Association of State Highway and Transportation Officials (AASHTO) T-104. A certification on sodium sulfate soundness test shall be submitted to the WVDEP prior to delivery and/or use.

Item 3: Q: Can the compaction requirements be reduced from 95% to 90%, and can you clarify the statement “..or as directed by the Engineer...” concerning required frequency of testing?

A: The compaction criteria listed in the specifications can be reduced to 90% of the Maximum Dry Density as determined by the Standard Proctor Test ASTM-D698. Frequency of testing shall be a minimum of one test per day when fill materials are being placed or one test for every 5000 cubic yards of material placed.

Item 4: Q: Is the Contractor responsible for obtaining RR protective liability insurance?

A: Yes. Please refer to Article III, Section 10.4 (page 6-A) of the General Conditions. Detailed instructions and contact information are provided.

Item 5: Q: Can the brush be windrowed, or is burning required?

A: Please refer to Section 4.3.1, Clearing and Grubbing, of the specifications.

Item 6: Q: Can the concrete debris be buried on site?

A: Concrete, foundation ruins, bricks, stone and cinder blocks, if encountered, may be incorporated into the fill and shall be of size less than two feet in any dimension and shall be buried at least one foot below finished grade in locations approved by the WVDEP. Hollow core cinder blocks shall be crushed prior to incorporation into the fill. Please refer to Section 4.3.4 of the Specifications.

Item 7: Q: Does the pipe under the RR grade require boring and jacking?

A: Yes. Please refer to Section 7.3.6 of the Specifications.

Item 8: Q: Can we use a 36-inch casing instead of a 30-inch casing for the pipe under the RR?

A: The casing must be installed as per plan, due to the RR's prior review and approval of a 36-inch casing.

Item 9: Contractor is reminded that sediment controls shall be installed about the perimeter of disturbed areas prior to any construction activities. Contractor shall take any necessary steps to prevent erosion or silting problems from occurring and minimize pollution or sedimentation of the stream. If any such problems occur, the Contractor shall be responsible for taking immediate corrective action. Only those erosion and sediment controls which are illustrated on the contract drawings shall be included for measurement. Any additional erosion and sediment controls, installed by the Contractor to meet any applicable State or Federal law or regulations, to protect streams, or for other purposes, shall be the Contractor's sole responsibility and all costs pursuant thereto shall be borne fully by the Contractor.

Item 10: Q: Can you provide an estimate of cut/fill quantities for the refuse piles?

A: An estimate of cut/fill quantities are included with this addendum.

ABNEY REFUSE PILE					
SITE 1 BASELINE 1					
Location		Excavation			
Station	Length	cut		fill	
	FT	SF	CY	SF	CY
50		0		0	
	50		0		0
0+00		0		0	
	50		19		11
0+50		21		12	
	50		31		656
1+00		12		697	
	50		11		1125
1+50		0		518	
	50		0		1105
2+00		0		675	
	50		0		1134
2+50		0		550	
	50		0		1541
3+00		0		1114	
	50		0		1852
3+50		0		886	
	50		0		1445
4+00		0		675	
	50		9		1736
4+50		10		1200	
	50		120		1935
5+00		120		890	
	50		412		1639
5+50		325		880	
	50		380		1713
6+00		85		970	
	50		329		1704
6+50		270		870	
	50		620		1315
7+00		400		550	
	50		745		1000
7+50		405		530	
	50		644		548
8+00		290		62	
	50		407		775
8+50		150		775	
	50		477		956
9+00		365		257	
	50		958		331
9+50		670		100	
	50		713		213
10+00		100		130	
	50		120		120
10+50		30		0	
	50		65		0
11+00		40		0	
	50		134		0
11+50		105		0	
	50		97		0
12+00		0		0	
			0		0
		total cut	6293	total fill	22854







ABNEY REFUSE PILE						
site 3 baseline 1						
Location		Excavation				
Station	Length	fill		cut		
		SF	CY	SF	CY	
30+00	50	0	73	0	393	
30+50	50	79	439	424	673	
31+00	50	395	779	303	598	
31+50	50	446	709	343	688	
32+00	50	320	579	400	499	
32+50	50	305	433	139	577	
33+00	50	163	186	484	638	
33+50	50	38	64	205	617	
34+00	50	31	43	461	874	
34+50	50	15	28	483	725	
35+00	50	15	31	300	339	
35+50	50	18	17	66	61	
36+00	50	0	0	0	0	
		total fill	3380	total cut	6681	



## SIGN IN SHEET

Page 1 of 3Request for <sup>Quote</sup> Proposal No. DEP16197Date 04-17-13Abney Refuse Piles

\*PLEASE BE SURE TO PRINT LEGIBLY – IF POSSIBLE, LEAVE A BUSINESS CARD

FIRM & REPRESENTATIVE NAME	MAILING ADDRESS	TELEPHONE & FAX NUMBERS
Company: <u>GREEN MOUNTAIN COMPANY</u>	<u>511 50<sup>th</sup> ST</u>	PHONE <u>304 925 0253</u>
Rep: <u>DAVID H BOWMAN</u>	<u>Charleston WV</u>	TOLL FREE
Email Address: <u>DHB722@yahoo.com</u>	<u>25304</u>	FAX <u>304 925 9230</u>
Company: <u>Hi Tech Con.</u>		PHONE <u>304-746-0050</u>
Rep: <u>Mark Moss</u>		TOLL FREE
Email Address: <u>smoss@hitechconstruction.com</u>	<u>Po Box 8601 <sup>25303</sup> Charleston</u>	FAX <u>746-4452</u>
Company: <u>DCI SHIRTS</u>		PHONE <u>304-693-9988</u>
Rep: <u>Robert Conley</u>		TOLL FREE
Email Address: <u>Bob Conley@DCIshirts.com</u>		FAX <u>304-223-9037</u>
Company: <u>EASTERN ARROW</u>	<u>PO BOX 4108</u>	PHONE <u>304-44-0255</u>
Rep: <u>Ann Karawski</u>	<u>Charleston WV 25364</u>	TOLL FREE
Email Address: <u>easternarrow@hotmail.com</u>		FAX <u>0256</u>
Company: <u>FOSTER SUPPLY</u>		PHONE <u>304-553-6565</u>
Rep: <u>DERRECK SEARS</u>		TOLL FREE
Email Address: <u>dsears@fostersupply.com</u>		FAX <u>304-755-8280</u>

## SIGN IN SHEET

Page 2 of 3Request for <sup>Quote</sup> Proposal No. DEP16197Date 04-17-13Abney Refuse Piles

\*PLEASE BE SURE TO PRINT LEGIBLY – IF POSSIBLE, LEAVE A BUSINESS CARD

FIRM & REPRESENTATIVE NAME	MAILING ADDRESS	TELEPHONE & FAX NUMBERS
Company: <u>J F ALLEN CO</u>	<u>P O Box 2049</u>	PHONE <u>304 472 8890</u>
Rep: <u>JAMES ALLEN</u>	<u>Buckhannon WV</u>	TOLL FREE
Email Address: <u>JAMES.ALLEN@JFALLENCO.COM</u>	<u>26201</u>	FAX <u>304 472 8897</u>
Company: <u>Aspen Corporation</u>	<u>2400 River Drive</u>	PHONE <u>304-763-4573</u>
Rep: <u>Ashtley Adkins</u>	<u>Daniels WV 25832</u>	TOLL FREE
Email Address: <u>jadkins@aspen-golf.com</u>		FAX <u>304-763-4591</u>
Company: <u>ALLCON</u>		PHONE <u>304 731 0190</u>
Rep: <u>DAVID TIZLE</u>		TOLL FREE <u>304 255 4232</u>
Email Address: <u>DIRLE@ACI-WV.COM</u>		FAX
Company: <u>Pineville Paving &amp; Excavating</u>	<u>P.O. - Box 1290</u>	PHONE <u>732-8303</u>
Rep: <u>Kevin D. Bradford</u>	<u>Pineville WV 24874</u>	TOLL FREE
Email Address: <u>Kevin.Bradford@AOL.COM</u>		FAX <u>304-732-7855</u>
Company: <u>McCourt &amp; Son Const.</u>	<u>2790 Centralia Rd</u>	PHONE <u>304 765-5288</u>
Rep: <u>GARY LONG</u>	<u>Sutton WV 26601</u>	TOLL FREE
Email Address: <u>glong@wirefire.com</u>		FAX <u>304-765-5293</u>

SIGN IN SHEET

Request for <sup>Quote</sup> Proposal No. DEP16197

Date 04-17-13

Abney Refuse Piles

**\*PLEASE BE SURE TO PRINT LEGIBLY – IF POSSIBLE, LEAVE A BUSINESS CARD**

FIRM & REPRESENTATIVE NAME	MAILING ADDRESS	TELEPHONE & FAX NUMBERS
Company: <u>Breakaway Inc.</u>	<u>1075 Old Turnpike Rd</u>	PHONE <u>765-5317</u>
Rep: <u>Doug Vincent</u>	<u>Sutton WV 26601</u>	TOLL FREE
Email Address: <u>doug@breakawayinc.com</u>		FAX <u>765-5389</u>
Company: <u>Carpenter Reclamation</u>	<u>PO BX 13015 Sissonville, WV</u>	PHONE
Rep: <u>Randy Carpenter</u>		TOLL FREE <u>304-9841115</u>
Email Address: <u>Rcarpen103@aol.com</u>		FAX <u>984-2770</u>
Company:		PHONE
Rep:		TOLL FREE
Email Address:		FAX
Company:		PHONE
Rep:		TOLL FREE
Email Address:		FAX
Company:		PHONE
Rep:		TOLL FREE
Email Address:		FAX

**ADDENDUM ACKNOWLEDGEMENT FORM**  
**SOLICITATION NO.: DEP16197**

**Instructions:** Please acknowledge receipt of all addenda issued with this solicitation by completing this addendum acknowledgment form. Check the box next to each addendum received and sign below. Failure to acknowledge addenda may result in bid disqualification.

**Acknowledgment:** I hereby acknowledge receipt of the following addenda and have made the necessary revisions to my proposal, plans and/or specification, etc.

**Addendum Numbers Received:**

(Check the box next to each addendum received)

- |   |  |
|---|--|
| <input type="checkbox"/> Addendum No. 1 | <input type="checkbox"/> Addendum No. 6  |
| <input type="checkbox"/> Addendum No. 2 | <input type="checkbox"/> Addendum No. 7  |
| <input type="checkbox"/> Addendum No. 3 | <input type="checkbox"/> Addendum No. 8  |
| <input type="checkbox"/> Addendum No. 4 | <input type="checkbox"/> Addendum No. 9  |
| <input type="checkbox"/> Addendum No. 5 | <input type="checkbox"/> Addendum No. 10 |

I understand that failure to confirm the receipt of addenda may be cause for rejection of this bid. I further understand that any verbal representation made or assumed to be made during any oral discussion held between Vendor's representatives and any state personnel is not binding. Only the information issued in writing and added to the specifications by an official addendum is binding.

\_\_\_\_\_  
Company

\_\_\_\_\_  
Authorized Signature

\_\_\_\_\_  
Date

NOTE: This addendum acknowledgement should be submitted with the bid to expedite document processing.  
 Revised 6/8/2012