



State of West Virginia
 Department of Administration
 Purchasing Division
 2019 Washington Street East
 Post Office Box 50130
 Charleston, WV 25305-0130

Solicitation

NUMBER
DEP16271

PAGE
1

ADDRESS CORRESPONDENCE TO ATTENTION OF:
FRANK WHITTAKER 304-558-2316

VENDOR

RFQ COPY
 TYPE NAME/ADDRESS HERE

SHIP TO

ENVIRONMENTAL PROTECTION
 DEPARTMENT OF
 OFFICE OF AML&R
 601 57TH STREET SE
 CHARLESTON, WV
 25304 304-926-0499

DATE PRINTED
06/11/2013

BID OPENING DATE: 06/19/2013 BID OPENING TIME 1:30PM

LINE	QUANTITY	UOP	CAT. NO.	ITEM NUMBER	UNIT PRICE	AMOUNT
				ADDENDUM NO. 1		
				ADDENDUM IS ISSUED:		
				1. TO PROVIDE ANSWERS TO QUESTIONS ASKED REGARDING TO THE SOLICITATION AND TO ADDRESS REVISIONS MADE TO THE SPECIFICATIONS. REVISIONS, QUESTIONS AND ANSWERS ARE ATTACHED.		
				2. TO PROVIDE VENDORS A COPY OF THE MANDATORY PRE-BID MEETING SIGN-IN SHEET.		
				3. TO PROVIDE ADDENDUM ACKNOWLEDGEMENT. THIS DOCUMENT SHOULD BE SIGNED AND RETURNED WITH YOUR BID. FAILURE TO SIGN AND RETURN MAY RESULT IN THE DISQUALIFICATION OF YOUR BID.		
				***** END OF ADDENDUM NO. 1 *****		

SIGNATURE		TELEPHONE	DATE
TITLE	FEIN	ADDRESS CHANGES TO BE NOTED ABOVE	

WHEN RESPONDING TO SOLICITATION, INSERT NAME AND ADDRESS IN SPACE ABOVE LABELED 'VENDOR'



State of West Virginia
 Department of Administration
 Purchasing Division
 2019 Washington Street East
 Post Office Box 50130
 Charleston, WV 25305-0130

Solicitation

NUMBER
DEP16271

PAGE
2

ADDRESS CORRESPONDENCE TO ATTENTION OF:
FRANK WHITTAKER 304-558-2316

VENDOR

RFQ COPY
 TYPE NAME/ADDRESS HERE

SHIP TO

ENVIRONMENTAL PROTECTION
 DEPARTMENT OF
 OFFICE OF AML&R
 601 57TH STREET SE
 CHARLESTON, WV
 25304 304-926-0499

DATE PRINTED
06/11/2013

BID OPENING DATE: 06/19/2013 BID OPENING TIME 1:30PM

LINE	QUANTITY	UOP	CAT. NO.	ITEM NUMBER	UNIT PRICE	AMOUNT
0001	1	JB		962-73		
RECLAMATION: RESTORATION OF LAND & OTHER PROPERTIES						
***** THIS IS THE END OF RFQ DEP16271 ***** TOTAL:						

SIGNATURE		TELEPHONE	DATE
TITLE	FEIN	ADDRESS CHANGES TO BE NOTED ABOVE	

WHEN RESPONDING TO SOLICITATION, INSERT NAME AND ADDRESS IN SPACE ABOVE LABELED 'VENDOR'

SOLICITATION NUMBER: DEP16271**Addendum Number: 1**

The purpose of this addendum is to modify the solicitation identified as (“Solicitation”) to reflect the change(s) identified and described below.

Applicable Addendum Category:

- | Modify bid opening date and time
- | Modify specifications of product or service being sought
- | Attachment of vendor questions and responses
- | Attachment of pre-bid sign-in sheet
- | Correction of error
- | Other

Description of Modification to Solicitation:

1. To provide answer to questions asked regarding the RFQ and to address revisions made to the specifications.
2. To provide a copy of mandatory pre-bid meeting sign-in sheet.
3. To provide Addendum Acknowledgement.

Additional Documentation: Documentation related to this Addendum (if any) has been included herewith as Attachment A and is specifically incorporated herein by reference.

Terms and Conditions:

1. All provisions of the Solicitation and other addenda not modified herein shall remain in full force and effect.
2. Vendor should acknowledge receipt of all addenda issued for this Solicitation by completing an Addendum Acknowledgment, a copy of which is included herewith. Failure to acknowledge addenda may result in bid disqualification. The addendum acknowledgement should be submitted with the bid to expedite document processing.

ATTACHMENT A

**Addendum #1 - Questions During Pre-Bid Meeting
Fairmont (Jackson Addition) Subsidence
DEP16271**

The following comments and questions were identified from the Pre-Bid Conference. The answers provided herein take precedence over verbal answers at the PBC should there be any conflict between the two.

- 1) Is a road bond required by the City of Fairmont for pavement repair for damage to the city streets?
 - A) No. You may contact the Fairmont Public Works Director, Ron Miller, to verify.
- 2) The following identifies structures shown on the design plan that are to be deleted from this project:

<u>HOUSE ID#</u>	<u>TAX MAP #</u>	<u>PARCEL#</u>
13	36	62.1
29	36	84
44	36	131
45	36	132
52	36	95
55	36	144
86	37	8
90	37	10
91	37	13.1
92	37	13
94	37	10.1

- 3) The following identifies proposed injection borings that are to be relocated off of the indicated parcels:

<u>HOLE#</u>	<u>TAX MAP#</u>	<u>PARCEL#</u>
85-9A	37	9
87-1A	37	7

- 4) When drilling through the soil zone, the contractor shall minimize the air or water pressure so as not to damage the surrounding soil and any adjacent structures. The air pressure shall be no more than necessary to positively displace the cuttings to the surface.

Extreme care shall be exercised when drilling near structures and the contractor shall be responsible for any damage to property or structures.

- 5) Specification 13.3.4 shall also require the contractor to obtain approval from the WVDEP for the disposal location of the cuttings and dust sludge that are cleaned and removed from the borehole area.
- 6) Specification 14.6.3 shall be revised such that the requirement for a minimum period of 12 hours elapsing between subsequent injection stages in a given hole shall not apply. Instead, the WVDEP representative shall determine the staging of injection materials in a given hole by limiting the volume of injection materials to 50 c.y. per injection sequence.
- 7) There are five locations on the plans where boreholes are proposed in the street. The contractor shall make every effort to avoid drilling in the pavement, but if necessary, these holes shall be repaired as described herein. The pavement around the borehole shall be square cut 2 ft. x 2 ft. in area and milled 1.5 inches deep. The borehole shall be filled to the top of the ground surface with grout/concrete and asphalt pavement overlay applied for a thickness of 1.5 inches to match the existing pavement.

The Contractor shall have 270 days from the date of the Notice to Proceed to complete construction activities on the project. The \$250.00 per day liquidated damages clause will be in effect after the 270 days. However, the total performance period will be 365 days from the date of the Notice to Proceed for invoicing purposes.

FAIRMONT (JACKSON ADDITION) SUBSIDENCE

REQUEST FOR QUOTATION NO. DEP16271

SIGN IN SHEET

Page 1 of 2

PLEASE PRINT

Date: 5/29/13

*** PLEASE BE SURE TO PRINT LEGIBLY - IF POSSIBLE, LEAVE A BUSINESS CARD**

FIRM & REPRESENTATIVE NAME	MAILING ADDRESS	TELEPHONE & FAX NUMBERS
Company: <u>Moore Concrete Pumping</u>	<u>PO Box 39 B. C. dger. 115 PA</u>	PHONE <u>412-221-4514</u>
Rep: <u>LARRY MOORE</u>	<u>15017</u>	TOLL FREE
Email Address: <u>Elmerfraser@comcast.net</u>		FAX <u>412-588-0900</u>
Company: <u>Cowgirl Up Inc</u>	<u>PO Box 243</u>	PHONE <u>304 739 4397</u>
Rep: <u>Spencer C Wooddell</u>	<u>SIMPSON, WVA 26435</u>	TOLL FREE
Email Address: <u>scw-cowgirlup@earthlink.net</u>		FAX <u>304 739 4461</u>
Company: <u>Howard Concrete Pumping Co</u>		PHONE <u>412-252-8800</u>
Rep: <u>Lynn Crazne</u>		TOLL FREE
Email Address: <u>lcrazne@howardconcretepumping.com</u>		FAX <u>412-252-8380</u>
Company: <u>Reclaim Company, LLC</u>	<u>PO Box 2162</u>	PHONE <u>3043667070</u>
Rep: <u>Brett Coker</u>	<u>Fairmont, WV 26555</u>	TOLL FREE
Email Address: <u>broker@reclaimco.com</u>		FAX <u>304 816 0194</u>
Company: <u>CTL Engineering</u>		PHONE <u>(304)292-1135</u>
Rep: <u>Tim Darran</u>		TOLL FREE
Email Address: <u>tdarran@ctleng.com</u>		FAX

REQUEST FOR QUOTATION NO. DEP116271

SIGN IN SHEET

Page 2 of 2

PLEASE PRINT

Date: 5/29/13

* PLEASE BE SURE TO PRINT LEGIBLY - IF POSSIBLE, LEAVE A BUSINESS CARD

FIRM & REPRESENTATIVE NAME	MAILING ADDRESS	TELEPHONE & FAX NUMBERS
Company: <u>CTL Engineering</u>		PHONE <u>292-1135</u>
Rep: <u>Joe Stanley</u>		TOLL
Email Address: <u>jstanley@ctleng.com</u>		FREE
		FAX
Company: <u>CTL Engineering</u>		PHONE <u>292-1135</u>
Rep: <u>Pat Gallagher</u>		TOLL
Email Address: <u>pgallagher@ctleng.com</u>		FREE
		FAX
Company: _____		PHONE
Rep: _____		TOLL
Email Address: _____		FREE
		FAX
Company: _____		PHONE
Rep: _____		TOLL
Email Address: _____		FREE
		FAX
Company: _____		PHONE
Rep: _____		TOLL
Email Address: _____		FREE
		FAX

ADDENDUM ACKNOWLEDGEMENT FORM
SOLICITATION NO.: DEP16271

Instructions: Please acknowledge receipt of all addenda issued with this solicitation by completing this addendum acknowledgment form. Check the box next to each addendum received and sign below. Failure to acknowledge addenda may result in bid disqualification.

Acknowledgment: I hereby acknowledge receipt of the following addenda and have made the necessary revisions to my proposal, plans and/or specification, etc.

Addendum Numbers Received:

(Check the box next to each addendum received)

- | | |
|---|--|
| <input type="checkbox"/> Addendum No. 1 | <input type="checkbox"/> Addendum No. 6 |
| <input type="checkbox"/> Addendum No. 2 | <input type="checkbox"/> Addendum No. 7 |
| <input type="checkbox"/> Addendum No. 3 | <input type="checkbox"/> Addendum No. 8 |
| <input type="checkbox"/> Addendum No. 4 | <input type="checkbox"/> Addendum No. 9 |
| <input type="checkbox"/> Addendum No. 5 | <input type="checkbox"/> Addendum No. 10 |

I understand that failure to confirm the receipt of addenda may be cause for rejection of this bid. I further understand that any verbal representation made or assumed to be made during any oral discussion held between Vendor's representatives and any state personnel is not binding. Only the information issued in writing and added to the specifications by an official addendum is binding.

Company

Authorized Signature

Date

NOTE: This addendum acknowledgement should be submitted with the bid to expedite document processing.

Revised 6/8/2012