



State of West Virginia  
 Department of Administration  
 Purchasing Division  
 2019 Washington Street East  
 Post Office Box 50130  
 Charleston, WV 25305-0130

# Solicitation

NUMBER
DNR212187

PAGE
1

ADDRESS CORRESPONDENCE TO ATTENTION OF:
FRANK WHITTAKER 304-558-2316

VENDOR

RFQ COPY  
 TYPE NAME/ADDRESS HERE

SHIP TO

DIVISION OF NATURAL RESOURCES  
 WILDLIFE RESOURCES SECTION  
 WILDLIFE CENTER-UPSHUR COUNTY  
 ROUTE 20 SOUTH  
 FRENCH CREEK, WV  
 26218 304-924-6211

DATE PRINTED
09/25/2012

LINE	QUANTITY	UOP	CAT. NO.	ITEM NUMBER	UNIT PRICE	AMOUNT
ADDENDUM NO. 1  THIS ADDENDUM IS ISSUED TO PROVIDE THE FOLLOWING DOCUMENTATION.						
0001	1	LS		968-42		
GENERAL CONSTRUCTION						
***** THIS IS THE END OF RFQ DNR212187 ***** TOTAL:						

SIGNATURE		TELEPHONE	DATE
TITLE	FEIN	ADDRESS CHANGES TO BE NOTED ABOVE	

WHEN RESPONDING TO SOLICITATION, INSERT NAME AND ADDRESS IN SPACE ABOVE LABELED 'VENDOR'

**SOLICITATION NUMBER: DNR212187**

**Addendum Number: 01**

---

The purpose of this addendum is to modify the solicitation identified as ("Solicitation") to reflect the change(s) identified and described below.

**Applicable Addendum Category:**

- | Modify bid opening date and time
- | Modify specifications of product or service being sought
- | Attachment of vendor questions and responses
- | Attachment of pre-bid sign-in sheet
- | Correction of error
- | Other

**Description of Modification to Solicitation:** Bid opening date and time extended to:  
10/04/2012 at 1:30

Provide the attached Pricing Page

**Additional Documentation:** Documentation related to this Addendum (if any) has been included herewith as Attachment A and is specifically incorporated herein by reference.

**Terms and Conditions:**

1. All provisions of the Solicitation and other addenda not modified herein shall remain in full force and effect.
2. Vendor should acknowledge receipt of all addenda issued for this Solicitation by completing an Addendum Acknowledgment, a copy of which is included herewith. Failure to acknowledge addenda may result in bid disqualification. The addendum acknowledgement should be submitted with the bid to expedite document processing.

## Wildlife Center Barn Siding Questions

1. The East and West sides of the barn have openings that have been covered over that are not flush with the original surface. Can this be removed before installing the new siding; will the original surface have to be furred out to be flush with the cover or can the cover be left in place and sided over?

Answer: We assume you are referring to the hayloft openings that have doors – the doors need covered with vinyl or metal and need to be functional, that is the doors need to open to allow hay to be stored and retrieved and they need to securely close to keep precipitation out. Above the hayloft door on the front end is an opening covered with wire mesh. This area needs covered with wood, fanfold, and vinyl siding.

2. There is cable running through the North and South sides of the barn at the Eave Elevation. Does this cable have to be left exposed or can the Fascia and soffit be installed so that it will hide the cable and wood ?

Answer: To our knowledge there is no cable running through the North and South sides – we removed the piece of wood and lag bolts that were in question. There are electric cords that went to lights on the front and back (East and West) ends of the barn – we have removed those and that area needs sided over.

3. There are some areas where there are damaged or rotted materials. Do these areas require repair before siding is installed or can they be sided over ?

Answer: Any of the existing siding or trim that is missing, lifted up, damaged/rotted needs to be repaired/replaced to bring up or down flush before installing siding.

4. The specifications state that metal is an option for the doors, window casings, window seals, fascia and soffit. During the prebid it was understood that only metal is to be used. Is metal now the requirement ?

Answer: Metal is not a requirement. Either metal or vinyl can be used for those items at the discretion of the contractor.

WEST VIRGINIA DIVISION OF NATURAL RESOURCES  
DNR 212187 WV STATE WILDLIFE CENTER BARN SIDING

**PRICING SHEET**

Item	Description	Total Lump Sum Amount
1	Materials and labor required to cover the existing wood siding on the outside barn walls with fanfold siding underlayment, surfaced with new vinyl siding, and vinyl or aluminum trim all in accordance with the attached specifications.	

WV DIVISION OF NATURAL RESOURCES

Request for Quotation/Proposal No.

SIGN IN SHEET

Page 1 of 2

ONR 212187

PLEASE PRINT

Date: 9/11/12

\*PLEASE BE SURE TO PRINT LEGIBLY. IF POSSIBLE, LEAVE A BUSINESS CARD

FIRM & REPRESENTATIVE NAME	MAILING ADDRESS	TELEPHONE & FAX NUMBERS
Company: <u>Danhill Construction CO.</u> Rep: <u>Dale Legg</u> Email Address: <u>rdanhill@hotmail.com</u>	<u>P.O. 685 Gauley Bridge</u> <u>W.V. 25085</u>	PHONE <u>304-632-1600</u> FAX <u>304-632-1501</u>
Company: <u>A.J. Smith, Inc. dba Capital Builders</u> Rep: <u>Brenda Pack</u> Email Address: <u>bpack@capitalbuilders.us</u>	<u>4008 5th Street Rd</u> <u>Huntington WV 25701</u>	PHONE <u>304-697-5002</u> FAX <u>304-697-5004</u>
Company: <u>Veritas Contracting LLC</u> Rep: <u>Ron Joseph</u> Email Address: <u>ksaharick@VeritasWV.com</u>	<u>1233 Suite 1</u> <u>Pineview Dr.</u> <u>Morgantown WV 26501</u>	PHONE <u>304-598-2285</u> FAX <u>304-598-2287</u>
Company: <u>Pearl Gate Construction</u> Rep: <u>Craig Brown</u> Email Address: <u>Cbbrown10@yahoo.com</u>	<u>7 Anchors Way</u> <u>Winfield, WV</u> <u>25213</u>	PHONE <u>304-539-8999</u> FAX <u>304-755-4885</u>

WV DIVISION OF NATURAL RESOURCES

SIGN IN SHEET

PLEASE PRINT

Request for Quotation/Proposal No.

DNR 212187

Page 2 of 2

Date: 9/11/12

\*PLEASE BE SURE TO PRINT LEGIBLY. IF POSSIBLE, LEAVE A BUSINESS CARD

FIRM & REPRESENTATIVE NAME	MAILING ADDRESS	TELEPHONE & FAX NUMBERS
Company: <u>Riffle Contracting LLC</u>	<u>PO box 418</u>	PHONE <u>304-685-422</u>
Rep: <u>Jason</u>	<u>Rollston WV 26501</u>	
Email Address: <u>RiffleContracting@gmail.com</u>		FAX <u>304-241-4354</u>
Company: _____	_____	PHONE _____
Rep: _____	_____	_____
Email Address: _____	_____	FAX _____
Company: _____	_____	PHONE _____
Rep: _____	_____	_____
Email Address: _____	_____	FAX _____
Company: _____	_____	PHONE _____
Rep: _____	_____	_____
Email Address: _____	_____	FAX _____

**ADDENDUM ACKNOWLEDGEMENT FORM**  
**SOLICITATION NO.: DNR212187**

**Instructions:** Please acknowledge receipt of all addenda issued with this solicitation by completing this addendum acknowledgment form. Check the box next to each addendum received and sign below. Failure to acknowledge addenda may result in bid disqualification.

**Acknowledgment:** I hereby acknowledge receipt of the following addenda and have made the necessary revisions to my proposal, plans and/or specification, etc.

**Addendum Numbers Received:**

(Check the box next to each addendum received)

- |   |  |
|---|--|
| <input type="checkbox"/> Addendum No. 1 | <input type="checkbox"/> Addendum No. 6  |
| <input type="checkbox"/> Addendum No. 2 | <input type="checkbox"/> Addendum No. 7  |
| <input type="checkbox"/> Addendum No. 3 | <input type="checkbox"/> Addendum No. 8  |
| <input type="checkbox"/> Addendum No. 4 | <input type="checkbox"/> Addendum No. 9  |
| <input type="checkbox"/> Addendum No. 5 | <input type="checkbox"/> Addendum No. 10 |

I understand that failure to confirm the receipt of addenda may be cause for rejection of this bid. I further understand that that any verbal representation made or assumed to be made during any oral discussion held between Vendor's representatives and any state personnel is not binding. Only the information issued in writing and added to the specifications by an official addendum is binding.

---

Company

---

Authorized Signature

---

Date

NOTE: This addendum acknowledgment should be submitted with the bid to expedite document processing.  
 Revised 6/8/2012