



State of West Virginia
 Department of Administration
 Purchasing Division
 2019 Washington Street East
 Post Office Box 50130
 Charleston, WV 25305-0130

Solicitation

NUMBER
DNR213029

PAGE
1

ADDRESS CORRESPONDENCE TO ATTENTION OF:
FRANK WHITTAKER 304-558-2316

VENDOR

RFQ COPY
 TYPE NAME/ADDRESS HERE

SHIP TO

DIVISION OF NATURAL RESOURCES
 PARKS & RECREATION SECTION

 324 4TH AVENUE
 SOUTH CHARLESTON, WV
 25303-1228 304-558-3397

DATE PRINTED
10/24/2012

BID OPENING DATE: 10/31/2012 BID OPENING TIME 1:30PM

LINE	QUANTITY	UOP	CAT NO	ITEM NUMBER	UNIT PRICE	AMOUNT
ADDENDUM NO. 2						
THIS ADDENDUM IS ISSUED TO PROVIDE THE ATTACHED DOCUMENTAION.						
0001	1	LS		968-42		
PEDESTRIAN BRIDGE AND WALKWAY REPLACEMENT						
***** THIS IS THE END OF RFQ DNR213029 ***** TOTAL:						

SIGNATURE		TELEPHONE	DATE
TITLE	FEIN	ADDRESS CHANGES TO BE NOTED ABOVE	

WHEN RESPONDING TO SOLICITATION, INSERT NAME AND ADDRESS IN SPACE ABOVE LABELED 'VENDOR'

SOLICITATION NUMBER: DNR213029
Addendum Number: 02

The purpose of this addendum is to modify the solicitation identified as (“Solicitation”) to reflect the change(s) identified and described below.

Applicable Addendum Category:

- Modify bid opening date and time
- Modify specifications of product or service being sought
- Attachment of vendor questions and responses
- Attachment of pre-bid sign-in sheet
- Correction of error
- Other

Description of Modification to Solicitation:

Additional Documentation: Documentation related to this Addendum (if any) has been included herewith as Attachment A and is specifically incorporated herein by reference.

Terms and Conditions:

1. All provisions of the Solicitation and other addenda not modified herein shall remain in full force and effect.
2. Vendor should acknowledge receipt of all addenda issued for this Solicitation by completing an Addendum Acknowledgment, a copy of which is included herewith. Failure to acknowledge addenda may result in bid disqualification. The addendum acknowledgement should be submitted with the bid to expedite document processing.

Camp Creek S.P.
 Pedestrian Bridge and Scenic Walkway Replacement
 DNR213029
 Addendum No. 2
 Dated: October 19, 2012

1. Please allow this letter to serve as request to approve Redi-Rock as an alternative source for the construction of the abutments wall on the referenced project.

It is acceptable to use a Redi-Rock abutment, provided drawings are submitted for review and stamped/signed by a WV Professional Engineer.

2. Can type H concrete be used in the abutment walls, per WVDOT specification 601009-001 Standard Specifications Road and Bridges dated 2010?

Type H concrete is acceptable in the abutment walls.

3. Can we use existing onsite stone for the foundation protection?

If existing site stone is used for foundation protection, it must be coordinated with the Park Superintendent and may not come from the stream or the stream banks.

4. On the wooden walkway would it be possible to move the 6X6 post be moved from 10 foot centers to 12 foot centers?

The 6x6 posts shall remain at 10 feet centers.

5. Since aluminum bridges are acceptable, must they be bid as an alternate?

No. They will just need to meet the specifications in Section 05122 and be approved during the submittal process.

6. Will there be a revised form sent out?

No revised bid form will be issued.

7. The provided detail for the abutment wall is for a Contech Structure, if we use another brand of structure can we design our own foundation by using an in-house WV licensed engineers?

The contractor may re-engineer the abutments for other structure brands. If dimensional changes are such that the overall abutment height or width changes, provide drawings for review that are stamped/signed by a WV Professional Engineer. This does not guarantee acceptance during the submittal process.

8. Will the owner have existing walkway removed prior to the contractor receiving notice to proceed?

The asphalt walkway within the project limits will be removed by Park Staff prior to the start date given on the Notice to Proceed.

9. Can the concrete for the 12-inch diameter foundation supports for the walkway be mixed on site? They are remotely located across the creek. A pump truck will probably be required if this is not allowed.

On-site concrete batching is allowed for the 12" diameter foundation supports for the walkway.

10. During the pre bid meeting there was discussion about the asphalt and that its only location would be at the entry to the upper bridge. It was concluded that concrete could be used instead of the asphalt. The drawing show asphalt at the entries of the lower bridge also. Is asphalt to be used at the location or concrete?

No asphalt is shown on the revised plans. Both bridge approaches use concrete.

11. It was stated that any asphalt removed could be placed at a designated location on the owner's property. Please Verify.

Any asphalt removed from the project site can be place within the park at the discretion of the Park Superintendent.

12. It was stated that an aluminum bridge was an acceptable alternate. Can Aluminum planking be used to replace the #1 grade treated Southern Yellow Pine ?

Aluminum planking is acceptable

13. The owner stated that they would remove any trees and conduct any required trimming of trees that may be required to install the bridges and the walkway. Please verify.

Owner will remove trees and trim as necessary.

14. The owner stated that they would allow the contractor to place the wood removed from the walkway and the upper bridge at a designated sight on the owner's property. Please verify.

Wood debris may be placed on site as directed by the Park Superintendent.

15. It was stated that the old abutments could be broken up to size and used as a substitute for some of the rip rap requirements. Please verify.

Concrete from demolition may be used as rip rap provided all reinforcing steel is cut flush.

16. It was stated that concrete would be used rather than asphalt for any of the walkway requirements. Please verify.

Concrete has been shown in the revised drawings for the walkway.

17. There was discussion as to whether the lower bridge would have to meet ADA requirements. Please verify if it must meet these requirements and if it does what type of walkway will be required for the entries to the bridge.

The entire limits of the project must meet ADA requirements. A hard surface has been provided for all walking surfaces.

18. It was stated that there could be no stream disturbance from February 01 through June 01. Please provide some guidelines.

Entry into the stream will not be prohibited, but temporary waivers will have to be applied for and coordinated with DNR. Waivers will only be granted in week long increments. Also, the flow of the stream will be the highest and the Superintendent will need to be notified in order to adjust where trout are stocked.

ADDENDUM ACKNOWLEDGEMENT FORM
SOLICITATION NO.: DNR213029

Instructions: Please acknowledge receipt of all addenda issued with this solicitation by completing this addendum acknowledgment form. Check the box next to each addendum received and sign below. Failure to acknowledge addenda may result in bid disqualification.

Acknowledgment: I hereby acknowledge receipt of the following addenda and have made the necessary revisions to my proposal, plans and/or specification, etc.

Addendum Numbers Received:

(Check the box next to each addendum received)

- | | |
|---|--|
| <input type="checkbox"/> Addendum No. 1 | <input type="checkbox"/> Addendum No. 6 |
| <input type="checkbox"/> Addendum No. 2 | <input type="checkbox"/> Addendum No. 7 |
| <input type="checkbox"/> Addendum No. 3 | <input type="checkbox"/> Addendum No. 8 |
| <input type="checkbox"/> Addendum No. 4 | <input type="checkbox"/> Addendum No. 9 |
| <input type="checkbox"/> Addendum No. 5 | <input type="checkbox"/> Addendum No. 10 |

I understand that failure to confirm the receipt of addenda may be cause for rejection of this bid. I further understand that any verbal representation made or assumed to be made during any oral discussion held between Vendor's representatives and any state personnel is not binding. Only the information issued in writing and added to the specifications by an official addendum is binding.

Company

Authorized Signature

Date

NOTE: This addendum acknowledgment should be submitted with the bid to expedite document processing.
 Revised 6/8/2012