



State of West Virginia  
 Department of Administration  
 Purchasing Division  
 2019 Washington Street East  
 Post Office Box 50130  
 Charleston, WV 25305-0130

# Solicitation

NUMBER
DNRB12195

PAGE
1

ADDRESS CORRESPONDENCE TO ATTENTION OF:
FRANK WHITTAKER 304-558-2316

VENDOR

RFQ COPY  
 TYPE NAME/ADDRESS HERE

SHIP TO

DIVISION OF NATURAL RESOURCES  
 ELKINS OFFICE  
 RANDOLPH CENTER - SUITE 222  
 1200 HARRISON AVENUE  
 ELKINS, WV  
 26241

DATE PRINTED
08/27/2012

BID OPENING DATE: 09/11/2012 BID OPENING TIME 1:30PM

LINE	QUANTITY	UOP	CAT NO	ITEM NUMBER	UNIT PRICE	AMOUNT
				ADDENDUM NO. 2		
				THIS ADDENDUM IS ISSUED TO PROVIDE THE ATTACHED DOCUMENTATION, AND EXTEND THE BID OPENING DATE AND TIME.		
0001	1	LS		968-42		
				GENERAL CONSTRUCTION		
***** THIS IS THE END OF RFQ DNRB12195 ***** TOTAL:						

SIGNATURE	TELEPHONE	DATE
TITLE	FEIN	ADDRESS CHANGES TO BE NOTED ABOVE

WHEN RESPONDING TO SOLICITATION, INSERT NAME AND ADDRESS IN SPACE ABOVE LABELED 'VENDOR'

SOLICITATION NUMBER: DNRB12195

Addendum Number: 02

---

The purpose of this addendum is to modify the solicitation identified as ("Solicitation") to reflect the change(s) identified and described below.

**Applicable Addendum Category:**

- Modify bid opening date and time
- Modify specifications of product or service being sought
- Attachment of vendor questions and responses
- Attachment of pre-bid sign-in sheet
- Correction of error
- Other

**Description of Modification to Solicitation:**

Bid opening date and time is extended to 09/11/2012 at 1:30 PM.

**Additional Documentation:** Documentation related to this Addendum (if any) has been included herewith as Attachment A and is specifically incorporated herein by reference.

**Terms and Conditions:**

1. All provisions of the Solicitation and other addenda not modified herein shall remain in full force and effect.
2. Vendor should acknowledge receipt of all addenda issued for this Solicitation by completing an Addendum Acknowledgment, a copy of which is included herewith. Failure to acknowledge addenda may result in bid disqualification. The addendum acknowledgement should be submitted with the bid to expedite document processing.

**Canaan Valley Resort State Park  
Potable Water Wells  
Contract 8 - Potable Water Wells  
Requisition DNRB12195  
Addendum No. 2  
August 23, 2012**

**A. General**

The bid opening date has been changed to September 11, 2012, at 1:30 PM.

**A. Bidder Questions**

1. Q: Can rock removed from trench excavation be disposed of on-site?

*A: Rocks should be hauled to a waste area across from the Park office.*

2. Q: Is there a borrow site available on-site for suitable bedding material?

*A: The Contractor shall provide suitable bedding and backfill material from off-site sources.*

3. Q: What is the required horizontal separation between electrical conductors and water main?

*A: The minimum horizontal separation distance between the water pipe and electrical conductors is 5 LF, refer to Plan Sheet No. 2.*

4. Q: What do you mean by upper casing to match casing?

*A: The intent to ensure the well casing and the upper casing of the pitless unit are of same diameter and nominal wall thickness.*

5. Q: What do you require for rust protective coating?

*A: The pitless unit manufacturer's standard corrosion resistant coating will be acceptable.*

6. Q: Item #9, pg. 11 -- does this mean the Contractor is not responsible for obtaining water samples or cost of water sample testing?

*A: Correct. The owner or owner's representative will collect water samples, submit to appropriate authorities having jurisdiction, and bear costs for such.*

7. Q: Please provide name and model number of pitless unit specified.

A: Acceptable manufacturers include, but are not limited to: Monitor / Baker Water Systems Division.

*Due to items which are the Contractor's option (i.e. welded vs. threaded casing connections, discharge pipe material and subsequent connections, etc.) the Contractor will be required to supply a pitless adapter compatible with other components, subsequently no specific model number can be provided.*

**B. Additional Clarifications**

- 1. Electrical connections within the WTP and River Pump Station must be completed by a licensed master electrician.
- 2. The well test pump (even if new) cannot be used as the final service pump. Since the test pump will be required to pump 150 GPM vs. the target well yield of 100 GPM, the well pump motor and electrical conductors would be larger than would otherwise be required for a 100 GPM pump.
- 3. No office trailer will be required.

**CHAPMAN TECHNICAL GROUP**



Stephen M. Johnson, PE  
Project Engineer

**ADDENDUM ACKNOWLEDGEMENT FORM**  
**SOLICITATION NO.: DNRB12195**

**Instructions:** Please acknowledge receipt of all addenda issued with this solicitation by completing this addendum acknowledgment form. Check the box next to each addendum received and sign below. Failure to acknowledge addenda may result in bid disqualification.

**Acknowledgment:** I hereby acknowledge receipt of the following addenda and have made the necessary revisions to my proposal, plans and/or specification, etc.

**Addendum Numbers Received:**

(Check the box next to each addendum received)

- |   |  |
|---|--|
| <input type="checkbox"/> Addendum No. 1 | <input type="checkbox"/> Addendum No. 6  |
| <input type="checkbox"/> Addendum No. 2 | <input type="checkbox"/> Addendum No. 7  |
| <input type="checkbox"/> Addendum No. 3 | <input type="checkbox"/> Addendum No. 8  |
| <input type="checkbox"/> Addendum No. 4 | <input type="checkbox"/> Addendum No. 9  |
| <input type="checkbox"/> Addendum No. 5 | <input type="checkbox"/> Addendum No. 10 |

I understand that failure to confirm the receipt of addenda may be cause for rejection of this bid. I further understand that any verbal representation made or assumed to be made during any oral discussion held between Vendor's representatives and any state personnel is not binding. Only the information issued in writing and added to the specifications by an official addendum is binding.

\_\_\_\_\_  
Company

\_\_\_\_\_  
Authorized Signature

\_\_\_\_\_  
Date

NOTE: This addendum acknowledgment should be submitted with the bid to expedite document processing.  
Revised 6/8/2012