

1. COORDINATE ALL INSTALLATION REQUIREMENTS WITH OTHERS PRIOR TO ROUGH-IN 2. PROVIDE PULLWIRE IN ALL CONTROL CONDUITS.








NPP-16-ER

POWER SUPPLY

PS-150



ATTACHMENT AA



LIGHTING FIXTURE **SCHEDULE & DETAILS** 



Phone: (412) 931-8888

Fax: (412) 939-2525

LOW VOLTAGE

CEILING SENSOR

NCM-PDT-9/10

**→** 

LOW VOLTAGE

CEILING SENSOR

NCM-PDT-9/10

**→** 

LOW VOLTAGE

CEILING

DIMMING PHOTOCELL

WALLPOD

NPODM-DX

"\$LV"

LOW VOLTAGE

CEILING

DIMMING PHOTOCELL

NCM-PC-ADC

<u>GENERAL NOTES:</u>
1. MODEL NUMBERS ARE BASED ON SENSOR

SWITCH nLIGHT SYSTEM.

LOW VOLTAGE

CEILING SENSOR

WALLPOD

NPODM "\$LV"

SYSTEM GATEWAY

NGWY

NCM-PDT-9/10

NCM-PC-ADC

Φ

WALLPOD

LOW VOLTAGE

**CEILING SENSOR** 

NCM-PDT-9/10

**→**�>**-**

Φ

WALLPOD NPODM

"\$LV"

SERVICE, IS THE PROPERTY OF THE ARCHITECT AND MAY NOT BE USED IN ANY WAY WITHOUT WRITTEN PERMISSION OF THIS FIRM. Project Number PROJECT No: 20856 DRAWN BY: Author 2011227

Lighting Control System Typical Riser
Not to Scale

TRANE

TRACER SYSTEM

NPP-16

NETWORK SWITCH

BY OTHERS