



State of West Virginia
 Department of Administration
 Purchasing Division
 2019 Washington Street East
 Post Office Box 50130
 Charleston, WV 25305-0130

Solicitation

NUMBER
ISCN0018

PAGE
1

ADDRESS CORRESPONDENCE TO ATTENTION OF:
KRISTA FERRELL 304-558-2596

VENDOR

RFQ COPY
 TYPE NAME/ADDRESS HERE

SHIP TO

DEPARTMENT OF ADMINISTRATION
 IS&C - COMMUNICATIONS
 1900 KANAWHA BLVD. E.
 BUILDING 5, 10TH FLOOR
 CHARLESTON, WV
 25305 304-558-5472

DATE PRINTED
10/15/2012

BID OPENING DATE: 10/23/2012 BID OPENING TIME 1:30PM

LINE	QUANTITY	UOP	CAT. NO.	ITEM NUMBER	UNIT PRICE	AMOUNT
ADDENDUM NO. 2						
THIS ADDENDUM IS ISSUED TO AMEND THE ORIGINAL SOLICITATION (ISCN0018) PER THE ATTACHED.						
0001	1	LS		280-75		
	TIES, CABLE AND WIRING					
***** THIS IS THE END OF RFQ ISCN0018 ***** TOTAL:						

SIGNATURE	TELEPHONE	DATE
TITLE	FEIN	ADDRESS CHANGES TO BE NOTED ABOVE

WHEN RESPONDING TO SOLICITATION, INSERT NAME AND ADDRESS IN SPACE ABOVE LABELED 'VENDOR'

SOLICITATION NUMBER: ISCN0018

Addendum Number: 2

The purpose of this addendum is to modify the solicitation identified as ("Solicitation") to reflect the change(s) identified and described below.

Applicable Addendum Category:

- Modify bid opening date and time
- Modify specifications of product or service being sought
- Attachment of vendor questions and responses
- Attachment of pre-bid sign-in sheet
- Correction of error
- Other

Description of Modification to Solicitation:

To revise cost sheet per answers to technical questions

To provide answers to all technical questions submitted in accordance with the provisions of the original RFQ

To provide a copy of the mandatory pre-bid attendee list.

Additional Documentation: Documentation related to this Addendum (if any) has been included herewith as Attachment A and is specifically incorporated herein by reference.

Terms and Conditions:

1. All provisions of the Solicitation and other addenda not modified herein shall remain in full force and effect.
2. Vendor should acknowledge receipt of all addenda issued for this Solicitation by completing an Addendum Acknowledgment, a copy of which is included herewith. Failure to acknowledge addenda may result in bid disqualification. The addendum acknowledgement should be submitted with the bid to expedite document processing.

ATTACHMENT A

TECHNICAL QUESTIONS

ISCN0018

1. Are power poles going to be acceptable for cubicles?
 - A. Yes
2. Can the Fiber change-over be done during the weekend and/or evenings?
 - A. Yes
3. With no OSP work, can we strike the specialist from the requirement?
 - A. **No, there is OSP between the buildings at the D-6 HQ and yet to be determined at the county HQ's and sub stations.**
4. Does the old data/phone get demoed?
 - A. Yes
5. If our material count ends up different, whose number do we use?
 - A. **Vendor must bid the materials on the revised price sheet. Vendor must bid installation labor for all 16 locations. Pages 27 and 28 reflect the amount of cable runs. District 6 HQ has a total of 352 cable runs. Each of the 6 county HQ's has 36 total cable runs. Each of the 7 substations has 20 total cable runs. The 2 DMV locations change from 38 cable runs at each location to 90 total cable runs at each location.**
6. Page 27 states that OM4 12 strand terminating at administration building and 6 strand terminating at DT5-SHP, but bid price sheet states to use a hybrid 12/12SM. MM?
 - A. **The vendor must install 12 strands of SM and 12 strands of MM fiber from the admin building 1st floor Telecommunications Equipment Room (TER) to the 3rd floor TER, install 12 strands of SM and 12 strands of MM fiber from the admin building 1st floor equipment room to the Bridge Sign Shop TER and install 12 strands of SM and 12 strands of MM fiber from the admin building 1st floor equipment room to the Maintenance Shop TER.**
7. Are blank covers on old plant required after change-over?
 - A. Yes
8. Will plenum cable be acceptable in the maintenance shop open ceiling if secured above wind braces instead of conduit?
 - A. **No. Conduit must be used to protect the cable.**

9. Can the IT rooms be secured for warranty issues?
- A. **The security for the rooms will have to be addressed in a separate procurement.**
10. Do you want hard and electronic copies of the certifications?
- A. **Yes.**
11. In the pre-bid meeting, it was discussed that the existing cable would need to be removed (demo) after the new system is cut over. Is this a task that is to be added to the RFQ scope of work?
- A. **Yes. To be in compliance with the National Electrical Code, all abandoned cable must be removed by the vendor after migration to the new cable.**
12. In the pre-bid meeting, it was discussed that the install of network equipment and cut over may be desired by the State to be added to the RFQ scope of work. Is this a task that is to be added to the RFQ scope of work?
- A. **No.**
13. In the pre-bid meeting, it was discussed that the existing voice and data cabling will need to be in service until the new cabling is cut over. The existing jack locations are stubbed with conduit which most likely will not have the capacity to handle the new Cat-6A cable along with the existing. Is it desired that the existing cables in service be removed from the conduit and station boxes and re-terminated outside of the wall and conduit temporarily to make room for the new Cat-6A? If so, will this additional task be added to the RFQ scope of work?
- A. **Yes. The existing cables in service shall be removed from the conduit and station boxes and re-terminated outside of the wall and conduit temporarily to make room for the new Cat-6A and must be removed along with other abandoned cable after migration to the new cable.**
14. In the pre-bid meeting, it was observed that the existing voice cabling terminates in a separate location from the Data cabling. Once the new cabling is in place, all Cat-6A drops will reside in the data room. Using any new Cat-6A cable for legacy voice applications will require a voice tie cable to be installed between the voice closet (MPOP) and the data closet. Is the task of installing a Cat-3 multi-pair tie cable between the closets to be added to the RFQ scope of work? If so, what is the quantity of pairs desired between the Voice closet (MPOP) and the 1st Floor Data closet and the Voice closet (MPOP) and the 3rd Floor Data closet?
- A. **Yes, 100 pair on 1st floor and 4 – 4 pairs or 1 – 25 pair to 3rd floor terminated on 66 blocks on 89b style brackets on both ends.**

PRE-BID CONFERENCE
SIGN IN SHEET

Request for Quotation Number:

ISCNC18

Date:

10/02/12

Project Description:

DISTRICT 6 DOT REPAIR

PLEASE PRINT LEGIBLY. THIS INFORMATION IS ESSENTIAL TO CONTACT THE ATTENDEES IN A TIMELY MANNER. FAILURE TO DO SO MAY RESULT IN DELAYS IN YOUR COMPANY GETTING IMPORTANT BID INFORMATION.

Firm Name:	GRAYBAR
Firm Address:	1010 Young Street CHARLES RD WV 25301
Representative Attending:	Kevin Hypes
Phone Number:	304-344-2371
Fax Number:	304-344-0327
Email Address:	Kevin.hypes@graybar.com

Firm Name:	STATE Electric Supply
Firm Address:	4601 Camden Ave Parkersburg WV 26101
Representative Attending:	Bill Roberts
Phone Number:	304-424-8100
Fax Number:	304-424-8144
Email Address:	Bill.Roberts@STATEElectric.com

Firm Name:	Fort Henry Battersby, dba Advanced Communications
Firm Address:	2744 Eoff St. Wheeling, WV 26003
Representative Attending:	Louis Harvath
Phone Number:	304-233-3000
Fax Number:	304-233-9666
Email Address:	lharvath@acccentral.com

Firm Name:	PRO-1-ELECTRIC LLC
Firm Address:	194 Parkview Ln Mineral Wells WV 26150 PHONE (304) 482-8487
Representative Attending:	mark@pro1electric.com
Phone Number:	304-482-8487
Fax Number:	304-699-5379
Email Address:	mark@pro1electric.com

Firm Name:	GARYSON Electrical
Firm Address:	902 Rhode Ave PITTSBURGH PA 15216
Representative Attending:	Gary Rodgers
Phone Number:	(712) 320-2576
Fax Number:	(412) 323-9685
Email Address:	gary.rogers@garyson.com

Firm Name:	Verizon
Firm Address:	827 Fairmont Rd Suite 204 Morgan Town, WV 26501
Representative Attending:	Lance Host (Lawrence)
Phone Number:	304-284-0502
Fax Number:	304-284-0500
Email Address:	lawrence.host@verizon.com

PRE-BID CONFERENCE
SIGN IN SHEET

Request for Quotation Number: _____

Date: _____

Project Description: _____

PLEASE PRINT LEGIBLY. THIS INFORMATION IS ESSENTIAL TO CONTACT THE ATTENDEES IN A TIMELY MANNER. FAILURE TO DO SO MAY RESULT IN DELAYS IN YOUR COMPANY GETTING IMPORTANT BID INFORMATION.

Firm Name:	Mow Valley Technologies
Firm Address:	3564 River Road Morgantown WV 26501
Representative Attending:	Bob Bishop
Phone Number:	304 278-7773
Fax Number:	304 278-7404
Email Address:	R.BISHOP@MTECH.US

Firm Name:	_____
Firm Address:	_____
Representative Attending:	_____
Phone Number:	_____
Fax Number:	_____
Email Address:	_____

Firm Name:	_____
Firm Address:	_____
Representative Attending:	_____
Phone Number:	_____
Fax Number:	_____
Email Address:	_____

Firm Name:	_____
Firm Address:	_____
Representative Attending:	_____
Phone Number:	_____
Fax Number:	_____
Email Address:	_____

Firm Name:	_____
Firm Address:	_____
Representative Attending:	_____
Phone Number:	_____
Fax Number:	_____
Email Address:	_____

Firm Name:	_____
Firm Address:	_____
Representative Attending:	_____
Phone Number:	_____
Fax Number:	_____
Email Address:	_____

ADDENDUM ACKNOWLEDGEMENT FORM
SOLICITATION NO.: ISCN0018

Instructions: Please acknowledge receipt of all addenda issued with this solicitation by completing this addendum acknowledgment form. Check the box next to each addendum received and sign below. Failure to acknowledge addenda may result in bid disqualification.

Acknowledgment: I hereby acknowledge receipt of the following addenda and have made the necessary revisions to my proposal, plans and/or specification, etc.

Addendum Numbers Received:

(Check the box next to each addendum received)

- | | |
|---|--|
| <input type="checkbox"/> Addendum No. 1 | <input type="checkbox"/> Addendum No. 6 |
| <input type="checkbox"/> Addendum No. 2 | <input type="checkbox"/> Addendum No. 7 |
| <input type="checkbox"/> Addendum No. 3 | <input type="checkbox"/> Addendum No. 8 |
| <input type="checkbox"/> Addendum No. 4 | <input type="checkbox"/> Addendum No. 9 |
| <input type="checkbox"/> Addendum No. 5 | <input type="checkbox"/> Addendum No. 10 |

I understand that failure to confirm the receipt of addenda may be cause for rejection of this bid. I further understand that any verbal representation made or assumed to be made during any oral discussion held between Vendor's representatives and any state personnel is not binding. Only the information issued in writing and added to the specifications by an official addendum is binding.

Company

Authorized Signature

Date

NOTE: This addendum acknowledgement should be submitted with the bid to expedite document processing.
 Revised 6/8/2012