



State of West Virginia  
 Department of Administration  
 Purchasing Division  
 2019 Washington Street East  
 Post Office Box 50130  
 Charleston, WV 25305-0130

# Solicitation

NUMBER
COR61581

PAGE
1

ADDRESS CORRESPONDENCE TO ATTENTION OF:
TARA LYLE 304-558-2544

RFQ COPY

TYPE NAME/ADDRESS HERE

VENDOR

SHIP TO

HUTTONSVILLE CORRECTIONAL  
 CENTER  
 ATTENTION: KEN HOLBROOK  
 ROUTE 250 SOUTH  
 HUTTONSVILLE, WV  
 26273 335-2291

DATE PRINTED
08/26/2013

BID OPENING DATE: 09/03/2013

BID OPENING TIME 1:30PM

LINE	QUANTITY	UOP	CAT. NO.	ITEM NUMBER	UNIT PRICE	AMOUNT
				ADDENDUM NO. 1		
				SEE ATTACHED PAGES.		
				END OF ADDENDUM NO. 1		
0001	1	JB	968-42	REMOVE & INSTALL NEW UV DISINFECTION SYSTEM		
***** THIS IS THE END OF RFQ COR61581 ***** TOTAL:						

SIGNATURE	TELEPHONE	DATE
TITLE	FEIN	ADDRESS CHANGES TO BE NOTED ABOVE

WHEN RESPONDING TO SOLICITATION, INSERT NAME AND ADDRESS IN SPACE ABOVE LABELED 'VENDOR'

**SOLICITATION NUMBER: COR61581**  
**Addendum Number: 1**

---

The purpose of this addendum is to modify the solicitation identified as COR61581 (“Solicitation”) to reflect the change(s) identified and described below.

**Applicable Addendum Category:**

- Modify bid opening date and time
- Modify specifications of product or service being sought
- Attachment of vendor questions and responses
- Attachment of pre-bid sign-in sheet
- Correction of error
- Other

**Description of Modification to Solicitation:**

1. Responses to vendor questions attached.
2. Pre-bid sign in sheets attached – Exhibit 1.
3. The bid opening remains 09/03/2013 at 1:30 pm.

**Additional Documentation:** Documentation related to this Addendum (if any) has been included herewith as Attachment A and is specifically incorporated herein by reference.

**Terms and Conditions:**

1. All provisions of the Solicitation and other addenda not modified herein shall remain in full force and effect.
2. Vendor should acknowledge receipt of all addenda issued for this Solicitation by completing an Addendum Acknowledgment, a copy of which is included herewith. Failure to acknowledge addenda may result in bid disqualification. The addendum acknowledgement should be submitted with the bid to expedite document processing.

## ATTACHMENT A

### Questions:

- Q1: What is the width, Depth and length of the concrete channel?
- A1: The dimensions on the UV system are twenty-four (24") inches wide by nineteen (19") inches in depth by thirty-two (32') feet in length.
- Q2: How far away is the existing water supply?
- A2: The water supply is adjacent to UV system and less than five (5') feet.
- Q3: How far away is the existing electrical supply?
- A3: The electric is at the existing control panel.
- Q4: What type of connections from the effluent to the UV Channel?
- A4: Ductile iron pipe from the clarifiers to the manhole above the UV system and ductile iron pipe from the manhole to the UV system.
- Q5: Will the contractor have toilet facilities available from the owner during the project?
- A5: No.
- Q6: It is my understanding that the owner will have to sign off on any DEP permits. Will the owner obtain the required permits or will that be required of the contractor?
- A6: It will be the contractor's responsibility to obtain any special permits with the DEP and Office of Environmental Health Services.

### Clarifications:

- C1: Please see Exhibit #1 for the pre-bid sign-in sheet.
- C2: It is the contractor's responsibility to dispose of all items removed to install the new UV Disinfection System.

**The bid opening remains 09/03/2013 at 1:30 pm. No additional questions will be accepted on this RFQ.**

10R61581

SIGN IN SHEET

Request for Proposal No.

PLEASE PRINT

Date: 4/16/2013

\* PLEASE BE SURE TO PRINT LEGIBLY - IF POSSIBLE, LEAVE A BUSINESS CARD

TELEPHONE & FAX NUMBERS

FIRM & REPRESENTATIVE NAME	MAILING ADDRESS	TELEPHONE & FAX NUMBERS
Company: <u>ORDERS CONSTRUCTION CO.</u> Rep: <u>BOB ORDERS</u> Email Address: <u>BOB@ORDERSCONSTRUCTION.COM</u>	<u>P.O. Box 1448</u> <u>ST. ALBANS, WV 25177</u>	PHONE <u>304-722-4237</u> TOLL FREE FAX <u>304-722-4230</u>
Company: <u>DANHILL CONSTRUCTION</u> Rep: <u>MIKE SIEMIALKO</u> Email Address: <u>rdanhill@hotmail.com</u>	<u>PO Box 685</u> <u>GAULEY BRIDGE, WV 25085</u>	PHONE <u>1-304-632-1600</u> TOLL FREE FAX <u>1-304-632-1501</u>
Company: _____ Rep: _____ Email Address: _____	_____ _____ _____	PHONE TOLL FREE FAX
Company: _____ Rep: _____ Email Address: _____	_____ _____ _____	PHONE TOLL FREE FAX
Company: _____ Rep: _____ Email Address: _____	_____ _____ _____	PHONE TOLL FREE FAX

000004

**ADDENDUM ACKNOWLEDGEMENT FORM**  
**SOLICITATION NO.: COR61581**

**Instructions:** Please acknowledge receipt of all addenda issued with this solicitation by completing this addendum acknowledgment form. Check the box next to each addendum received and sign below. Failure to acknowledge addenda may result in bid disqualification.

**Acknowledgment:** I hereby acknowledge receipt of the following addenda and have made the necessary revisions to my proposal, plans and/or specification, etc.

**Addendum Numbers Received:**

(Check the box next to each addendum received)

- |   |  |
|---|--|
| <input type="checkbox"/> Addendum No. 1 | <input type="checkbox"/> Addendum No. 6  |
| <input type="checkbox"/> Addendum No. 2 | <input type="checkbox"/> Addendum No. 7  |
| <input type="checkbox"/> Addendum No. 3 | <input type="checkbox"/> Addendum No. 8  |
| <input type="checkbox"/> Addendum No. 4 | <input type="checkbox"/> Addendum No. 9  |
| <input type="checkbox"/> Addendum No. 5 | <input type="checkbox"/> Addendum No. 10 |

I understand that failure to confirm the receipt of addenda may be cause for rejection of this bid. I further understand that that any verbal representation made or assumed to be made during any oral discussion held between Vendor's representatives and any state personnel is not binding. Only the information issued in writing and added to the specifications by an official addendum is binding.

---

Company

---

Authorized Signature

---

Date

NOTE: This addendum acknowledgement should be submitted with the bid to expedite document processing.