



State of West Virginia  
 Department of Administration  
 Purchasing Division  
 2019 Washington Street East  
 Post Office Box 50130  
 Charleston, WV 25305-0130

# Solicitation

NUMBER
DEP16302

PAGE
1

ADDRESS CORRESPONDENCE TO ATTENTION OF:
FRANK WHITTAKER 304-558-2316

RFQ COPY  
 TYPE NAME/ADDRESS HERE

VENDOR

SHIP TO

ENVIRONMENTAL PROTECTION  
 DEPT. OF  
 OFFICE OF SPECIAL RECLAMATION  
 105 S. RAILROAD STREET  
 PHILIPPI, WV  
 26416-9998      304-457-3219

DATE PRINTED
04/03/2014

BID OPENING DATE: 04/15/2014

BID OPENING TIME 1:30PM

LINE	QUANTITY	UOP	CAT. NO.	ITEM NUMBER	UNIT PRICE	AMOUNT
ADDENDUM NO. 02						
THIS ADDENDUM IS ISSUED TO MODIFY THE ORIGINAL SOLICITATION PER THE ATTACHED DOCUMENTATION.						
0001	1	JB		962-73		
RECLAMATION: RESTORATION OF LAND/WATER						
***** THIS IS THE END OF RFQ DEP16302 ***** TOTAL:						

SIGNATURE		TELEPHONE	DATE
TITLE	FEIN	ADDRESS CHANGES TO BE NOTED ABOVE	

WHEN RESPONDING TO SOLICITATION, INSERT NAME AND ADDRESS IN SPACE ABOVE LABELED 'VENDOR'

SOLICITATION NUMBER: DEP16302

Addendum Number: 02

---

The purpose of this addendum is to modify the solicitation identified as (“Solicitation”) to reflect the change(s) identified and described below.

**Applicable Addendum Category:**

- Modify bid opening date and time
- Modify specifications of product or service being sought
- Attachment of vendor questions and responses
- Attachment of pre-bid sign-in sheet
- Correction of error
- Other

**Description of Modification to Solicitation:**

This addendum is issued to provide the following:

1. To provide a list of questions from the vendors and answers to those questions.
2. To provide the mandatory pre-bid sign in sheets.
3. To change the bid opening date to April 15, 2014 at 1:30 PM, EST.

**Additional Documentation:** Documentation related to this Addendum (if any) has been included herewith as Attachment A and is specifically incorporated herein by reference.

**Terms and Conditions:**

1. All provisions of the Solicitation and other addenda not modified herein shall remain in full force and effect.
2. Vendor should acknowledge receipt of all addenda issued for this Solicitation by completing an Addendum Acknowledgment, a copy of which is included herewith. Failure to acknowledge addenda may result in bid disqualification. The addendum acknowledgement should be submitted with the bid to expedite document processing.

ATTACHMENT A

**Addendum #2 - Questions During Pre-Bid Conference  
For DEP16302  
Primrose Coal Co.  
Permit 7-81**

---

The following questions were identified at the Pre-Bid Conference (PBC) conducted on-site on March 20, 2014. The answers and clarifications provided herein take precedence over verbal answers at the PBC and previously provided specifications and descriptions provided in the Solicitation should there be any conflicts between the two.

- Q1.** Where is the borrow site for the Highwall Regrade area, Bid Item #6.0?
- A1.** There is no borrow area for the Highwall Regrade area, it is a regrade only of the existing area.
- Q2.** What is included in the Highwall Regrade lump sum bid item?
- A2.** The Highwall Regrade **Bid Item #6.0, Land Recalvation**, includes not only the regrading of the highwall area, but also the breaching of the perimeter collection ditch and the installation of the rock outlet spreaders at the breached ditch openings.
- Q3.** How many HDPE 24 diameter culvert pipes are there on the project?
- A3.** Bid Item # 8.1 is for five (5) each twenty (20) foot long sections of 24 inch diameter HDPE Double wall corrugated culvert pipe. There are also several sections of the same size and type of culvert included in the Lump Sum Bid Item, #18.0, Treatment Facility.
- Q4.** Is the V-ditch alongside the road part of the Road bid item?
- A4.** **Bid Item # 8.3, 1' V-Ditch**, is separate from the bid item for the construction of the new road, Bid Item # 8.0 or rehabilitation of existing roadways, Bid Item # 7.0.
- Q5.** How many landowners does the work area cover?
- A5.** Two (2) landowners are included in the work area. Please see Sheet 2 of the Plans for the Tax Maps.
- Q6.** Is there a drain pipe from the existing pond located above the wetlands area?
- A6.** No.

**Q7.** Is the road turnaround located near the outlet of the wetland area bid as part of the new road?

**A7.** Yes.

**Q8.** Is the open limestone channel from the wet land grouted or just rip-rapped?

**A8.** No, it is not grouted, just rip-rap only.

**Q9.** Where does the new road and main open limestone channel go?

**A9.** The new road and open limestone channel lead from the wetland area to the middle access road from the county road by the old lime doser treatment site. From there, only the open limestone channel continues on to Pond B.

**Q10.** What is the reason for the swale above the wetland area?

**A10.** The swale is to divert surface water away from the AMD coming up in the wetland area..

**Q11.** Is the seep water that is collected above the Treatment Facility supposed to be routed back to the start of the open limestone ditch near the cliff area?

**A11.** No, the seeps are located too low in elevation, they need to be routed directly into the open limestone channel below them.

**Q12.** Where are the elevations for the Treatment Facility ponds and ditches taken from?

**A12.** The invert of the existing HDPE double wall culvert pipe near the cliff is the local datum point for the 1000 foot elevation mark.

**Q13.** Is the Treatment Facility a lump sum bid item?

**A13.** Yes, all items within the fence around the Treatment Facility are included in the lump sum **Bid Item # 18.0, Treatment facility**. The fence is Bid Item # 13.0, and the new road, Bid Item # 8.0 stops at the gate to the Treatment Facility.

**Q14.** Is the 8 inch HDPE drain line from the Treatment Facility part of the lump sum Bid Item # 18.0?

A14. Yes.

Q15. Is the road around the Treatment Facility ponds covered by the new road construction bid item, or covered by the lump sum Treatment Facility bid item?

A15. The roads inside the Treatment Facility fence are part of the lump sum **Bid Item, #18.0, Treatment Facility.**

Q16. At the lower end of the open limestone channel from the wetland area, can the roadside ditch be eliminated for the access road to the Treatment Facility past the 24" diameter culvert across the road?

A16. Yes, the roadside ditch downhill of the 24" diameter culvert may be eliminated, as the culvert will divert all of the surface water away from the main open limestone channel.

Q17. What bid item should the costs for the removal of the old lime doser and storage building be included in?

A17. This should be included in **Bid Item # 4, Site Preparation.**

Q18. Are there any Texas Crossings at or near Ponds B and C?

A18. Yes, three; one near the inlet of Pond B, one near the outlet of Pond B, and one near the inlet of Pond C.

Q19. Is the water from Pond B run in an open ditch?

A19. Initially, the water will run through one section of 24" HDPE culvert, for flow measurement purposes, and then in an open limestone channel onto Pond C.

Q20. What work is to be done to Ponds B and C?

A20. Clear and grub around the two ponds. Cleaning of the sediment from the ponds is not part of this contract.

Q21. Must everything that is grubbed be burnt?

A21. It must be burnt or chipped. It can not be windrowed, stacked, or buried.

**Q22.** Can Smart Ditch be used in place of the open limestone channels?

**A22.** The limestone is to provide for passive treatment of the AMD. If Smart Ditch is used, the limestone is still necessary.

**Q23.** Does the road to Pond C receive stone?

**A23.** Yes, it is to be rehabilitated as shown on Sheet 5 of the Plans.

**Q24.** Can a contractor come back and look at the project site after the Pre-Bid Conference by himself?

**A24.** Yes.

**Q25.** Is there a new bid sheet that came out in an Addendum, as there was initially some confusion about the number of culverts on the bid sheet?

**A25.** No. Initially, an outdated bid sheet was used at the beginning of the Pre-Bid Conference by mistake.

REQUEST FOR QUOTATION NO: DEPL6302

**SIGN IN SHEET**

Primrose Coal Inc. 7-81

PLEASE PRINT

Date: March 20, 2014

\* PLEASE BE SURE TO PRINT LEGIBLY - IF POSSIBLE, LEAVE A BUSINESS CARD

FIRM & REPRESENTATIVE NAME	MAILING ADDRESS	TELEPHONE & FAX NUMBERS
Company: <u>Green Mountain Company</u> Rep: <u>David H. Bowman</u> Email Address: <u>DHB722 GOLDEN</u>	<u>511 50th ST</u> <u>Charleston WV</u> <u>25304</u>	PHONE <u>304-925-0257</u> TOLL FREE FAX <u>304-925-9230</u>
Company: <u>Williams Excavating LLC</u> Rep: <u>Joe Williams</u> Email Address: <u>jwilliams@williamsx.com</u>	<u>8801 CR 22A Bloomingdale</u> <u>OH, 43910</u>	PHONE <u>3046148887</u> TOLL FREE FAX
Company: <u>Mill Run Enterprises</u> Rep: Email Address:	<u>176 Casteel Road</u> <u>Hazleton W. Va.</u>	PHONE <u>304-379-2200</u> TOLL FREE FAX
Company: <u>All-CON, LLC</u> Rep: <u>David Idle</u> Email Address: <u>DIRLE CACI-UWV-LVM</u>	<u>124 PHILPOTT LANE</u> <u>BEMER WV 25813</u>	PHONE <u>3047310190</u> TOLL FREE FAX <u>3042554232</u>
Company: <u>M'Court &amp; Son Const.</u> Rep: <u>GARY LONG</u> Email Address: <u>glonga@wirefire.com</u>	<u>2790 Centralia Rd</u> <u>Sutton WV 26601</u>	PHONE <u>304 765-5288</u> TOLL FREE FAX <u>304 765-5293</u>



REQUEST FOR QUOTATION NO: DEP16302

**SIGN IN SHEET**

Primrose Coal Inc. 7-81

PLEASE PRINT

Date: March 20, 2014

\* PLEASE BE SURE TO PRINT LEGIBLY - IF POSSIBLE, LEAVE A BUSINESS CARD

FIRM & REPRESENTATIVE NAME	MAILING ADDRESS	TELEPHONE & FAX NUMBERS
Company: <u>EAGLE CONTRACTORS LLC</u> Rep: <u>BARRIE F FOSTER</u> Email Address: <u>cdent@gefinc.com</u>	<u>6491 Winfield Road</u> <u>Winfield WV 25213</u>	PHONE <u>304-552-7781</u> TOLL FREE FAX <u>304-755-3150</u>
Company: <u>EASTERN ARROW</u> Rep: <u>Ann Harrison</u> Email Address: <u>easternarrow@hotmail.com</u>	<u>PO Box 2108</u> <u>Charleston WV</u> <u>25301</u>	PHONE <u>304-416-0285</u> TOLL FREE FAX <u>0286</u>
Company: <u>Williams Excavating, LLC</u> Rep: <u>Joe Williams / Travis Tipton</u> Email Address: <u>wttiption@williamsx.com</u>	<u>8801 CR 22A</u> <u>Bloomingsdale, OH</u> <u>43910</u>	PHONE <u>740-937-2077</u> TOLL FREE FAX <u>740-937-2022</u>
Company: <u>BIG EAST Enterprises</u> Rep: <u>Spencer C Wooddell</u> Email Address: <u>wvdirtyshame@gmail.com</u>	<u>Rte 3 Box 1645</u> <u>Bridgeport, WV 26330</u>	PHONE <u>304 672-2067</u> TOLL FREE FAX
Company: <u>JF ALLEN CO</u> Rep: <u>JAMES ALLEN</u> Email Address: <u>JAMES.ALLEN@JFALLENCO.COM</u>	<u>PO Box 2049</u> <u>Beckham WV</u> <u>26201</u>	PHONE <u>304 472 8890</u> TOLL FREE FAX <u>304 472 8897</u>

600000

REQUEST FOR QUOTATION NO: DEPW302

**SIGN IN SHEET**

Primrose Coal Inc. 7-81

PLEASE PRINT

Date: 11 March 20, 2014

\* PLEASE BE SURE TO PRINT LEGIBLY - IF POSSIBLE, LEAVE A BUSINESS CARD

FIRM & REPRESENTATIVE NAME	MAILING ADDRESS	TELEPHONE & FAX NUMBERS
Company: <u>Breakaway Inc</u> Rep: <u>Doug Vincent</u> Email Address: <u>doug@breakaway.wv.com</u>	<u>1075 Old Turnpike Rd</u> <u>Sutton WV 26001</u>	PHONE <u>765-5317</u> TOLL FREE FAX <u>765-5389</u>
Company: <u>JL Pretzel Contracting</u> Rep: <u>Jamie Pretzel</u> Email Address: <u>cpretzel@aol.com</u>	<u>PO Box 240</u> <u>Breeton Mills WV 26025</u>	PHONE <u>304-379-7789</u> TOLL FREE FAX <u>304-379-7788</u>
Company: <u>Eagle Excavation Inc</u> Rep: <u>GEORGE FRESHOUR</u> Email Address: <u>None</u>	<u>PO BOX 218</u> <u>KEARNA WV</u> <u>25248</u>	PHONE <u>304 372-4328</u> TOLL FREE FAX <u>304 372-4378</u>
Company: <u>Barnes EXC. INC</u> Rep: <u>Robert Barnes</u> Email Address: <u>Barnes EXC@aol.com</u>	<u>P.O. Box 13384</u> <u>Sissonville</u> <u>WV 25360</u>	PHONE <u>304-984-1725</u> TOLL FREE FAX <u>304-984-0074</u>
Company: <u>WV DEP</u> Rep: <u>David McCoy</u> Email Address: _____	<del>_____</del> <del>_____</del> <del>_____</del>	<del>PHONE</del> <del>TOLL</del> <del>FREE</del> <del>FAX</del>

**ADDENDUM ACKNOWLEDGEMENT FORM**  
**SOLICITATION NO.: DEP16302**

**Instructions:** Please acknowledge receipt of all addenda issued with this solicitation by completing this addendum acknowledgment form. Check the box next to each addendum received and sign below. Failure to acknowledge addenda may result in bid disqualification.

**Acknowledgment:** I hereby acknowledge receipt of the following addenda and have made the necessary revisions to my proposal, plans and/or specification, etc.

**Addendum Numbers Received:**

(Check the box next to each addendum received)

- |   |  |
|---|--|
| <input type="checkbox"/> Addendum No. 1 | <input type="checkbox"/> Addendum No. 6  |
| <input type="checkbox"/> Addendum No. 2 | <input type="checkbox"/> Addendum No. 7  |
| <input type="checkbox"/> Addendum No. 3 | <input type="checkbox"/> Addendum No. 8  |
| <input type="checkbox"/> Addendum No. 4 | <input type="checkbox"/> Addendum No. 9  |
| <input type="checkbox"/> Addendum No. 5 | <input type="checkbox"/> Addendum No. 10 |

I understand that failure to confirm the receipt of addenda may be cause for rejection of this bid. I further understand that any verbal representation made or assumed to be made during any oral discussion held between Vendor's representatives and any state personnel is not binding. Only the information issued in writing and added to the specifications by an official addendum is binding.

\_\_\_\_\_  
Company

\_\_\_\_\_  
Authorized Signature

\_\_\_\_\_  
Date