



State of West Virginia
 Department of Administration
 Purchasing Division
 2019 Washington Street East
 Post Office Box 50130
 Charleston, WV 25305-0130

Solicitation

NUMBER
DEP16307

PAGE
1

ADDRESS CORRESPONDENCE TO ATTENTION OF
FRANK WHITTAKER 304-558-2316

RFQ COPY

TYPE NAME/ADDRESS HERE

VENDOR

SHIP TO

ENVIRONMENTAL PROTECTION
 DEPT. OF
 OFFICE OF SPECIAL RECLAMATION
 105 S. RAILROAD STREET
 PHILIPPI, WV
 26416-9998 304-457-3219

DATE PRINTED
03/24/2014

BID OPENING DATE: 04/01/2014

BID OPENING TIME 1:30PM

LINE	QUANTITY	UOP	CAT. NO.	ITEM NUMBER	UNIT PRICE	AMOUNT
ADDENDUM NO. 1						
THIS ADDENDUM IS ISSUED TO:						
1) EXTEND THE BID OPENING DATE AND TIME						
2) PROVIDE THE ATTACHED TECHNICAL QUESTIONS & ANSWERS						
3) PROVIDE THE ATTACHED MANDATORY PRE-BID SIGN IN SHEET						
***** END ADDENDUM NO. 1 *****						
0001	1	JB		962-73		
RECLAMATION: RESTORATION OF LAND						

SIGNATURE		TELEPHONE	DATE
TITLE	FEIN	ADDRESS CHANGES TO BE NOTED ABOVE	

WHEN RESPONDING TO SOLICITATION, INSERT NAME AND ADDRESS IN SPACE ABOVE LABELED 'VENDOR'

SOLICITATION NUMBER: DEP16307

Addendum Number: 01

The purpose of this addendum is to modify the solicitation identified as ("Solicitation") to reflect the change(s) identified and described below.

Applicable Addendum Category:

- | Modify bid opening date and time
- | Modify specifications of product or service being sought
- | Attachment of vendor questions and responses
- | Attachment of pre-bid sign-in sheet
- | Correction of error
- | Other

Description of Modification to Solicitation:

Bid opening date and time extended to: 04/01/2014 at 1:30 PM

Additional Documentation: Documentation related to this Addendum (if any) has been included herewith as Attachment A and is specifically incorporated herein by reference.

Terms and Conditions:

1. All provisions of the Solicitation and other addenda not modified herein shall remain in full force and effect.
2. Vendor should acknowledge receipt of all addenda issued for this Solicitation by completing an Addendum Acknowledgment, a copy of which is included herewith. Failure to acknowledge addenda may result in bid disqualification. The addendum acknowledgement should be submitted with the bid to expedite document processing.

ATTACHMENT A

Addendum #1 - Questions During Pre-Bid Conference
For DEP16307
ROBLEE COAL COMPANY
Permits U-1001-91 & O-1009-93

The following questions were identified at the Pre-Bid Conference (PBC) conducted on-site on March 6, 2014. The answers and clarifications provided herein take precedence over verbal answers at the PBC and previously provided specifications and descriptions provided in the Solicitation should there be any conflicts between the two.

Q1. Will the contractor be required to remove any super silt fence, and other sediment control measures?

A1. Yes, after the work is done and vegetation has been established, the contractor will need to remove silt fence, or other forms of silt control, in accordance with Technical Specification 5.5.

Q2. Is the topsoil cover considered incidental, or is it paid for?

A2. The topsoil cover is paid for under the Bid Item, "Unclassified Excavation".

Q3. How many landowners does the work area cover, and are they aware that material will be moved from one owner's property to another?

A3. Five (5) different landowners own portions of the work area, and they are aware that material will be moved from one area to another. All work is located on the former permitted mine sites, so the State of West Virginia has the right to move material to reclaim the permit areas.

Q4. If boulders are found in the borrow area, what size are they to be reduced to before placing them in the highwall fill area?

A4. Boulders are to be broken into a size less than two (2) feet in any dimension prior to burying in the highwall fill area, in accordance with Technical Specification 8.3.3.3.

Q5. If payment is by the cubic yard, will the contractor need to do cross sections of the work?

A5. Yes.

Q6. Is the scaling of refuse from the highwall and regrading the refuse on top of the refuse fill area incidental work?

A6. No, payment is per bid items **8.2** and **15.2**.

Q7. Is there any incidental backfill work?

A7. Yes, the backfill of the Site #2 portal area is incidental to the installation of the Wet Mine Seal. It comprises approximately 200 cubic yards.

Q8. What is the breakdown of the cut per permit baseline area?

A8. Approximately 175,000 cubic yards of material will be removed from the borrow area. Approximately 158,000 cubic yards of borrow supplemented by 9,300 cubic yards of high wall excavation will be required to backfill the highwall. Approximately 14,500 cubic yards will be moved to regrade around Pond 3 with 5,200 cubic yards of material available for borrow. Approximately 29,000 cubic yards of material will be moved atop the refuse pile. With approximately 20,000 cubic yards of borrow needed to soil cover the coal refuse area. And approximately 200 cubic yards will be moved on Site Two, all of which is considered incidental to construction of Ditch Number 20. These estimates shall in no way encumber the WVDEP to the quantities mentioned, as the Contractor shall be required to develop his own estimates to his own satisfaction prior to submitting his bid.

Q9. Where is the boundary between the two permits?

A9. The boundary between the two permits is located approximately below the outfall of Pond #3 and comes up across the old haulroad.

Q10. What is the compaction requirement for the backfill of the highwall area?

A10. Technical Specification 8.3.3.7 is revised to require a compaction to at least 90% of the Standard Proctor maximum dry density.

Q11. Is Pond #3 to be cleaned prior to commencing earth moving work?

A11. Yes, Sediment Ponds #1, 2, and 3 are to be cleaned-out to the lines and grades shown on the plans prior to commencing any major earthwork. They are to be recleaned if they reach the 60% cleanout level during the duration of the contract. Please see Technical Specification 8.3.2.4

Q12. What is the pH of the water in Pond #3? Will the contractor be required to treat the water?

A12. The pH of the water in Pond #3 is about 5. The contractor will be required to treat the water while working on the pond in accordance with Technical Specification 8.3.2.4.

Q13. Are the seeps above Pond #3 to be collected, via ditches, under drains, or other methods?

A13. No.

Q14. Where is the slip area near Pond #3?

A14. The slip area is located between Pond #3 and the old haul road near the permit boundary between the two permits. Please see sheet 11 of the Plans.

Q15. What is the work to be done at Site #2?

A15. The basic scope of work for Site #2, located off of Hacker's Creek Road, is the upgrade of the access road, installation of a Wet Mine Seal and a grouted riprap ditch.

Q16. Is the pond at Site #2 to be cleaned?

A16. No, it is a farm pond, and it is not to be cleaned.

Q17. Where are the limits of the permit around the Refuse Area?

A17. The permit limits are above the grouted riprap ditches to be installed under the contract. Please see sheets 11 and 12 of the Plans.

Q18. What work is to be done to the face of the Refuse Area above Pond #3?

A18. Grouted riprap ditches and Texas Crossings are to be constructed as shown on the Plans, and the bare "acid burnout" areas are to be covered with topsoil and revegetated in accordance with Technical Specification 8.3.4.7

Q19. Is there a WV DEP padlock on the access gate to Site #1?

A19. Yes.

Q20. How many compactions tests are required daily for the Highwall backfill area?

A20. Compaction testing shall be at a frequency of 1 lot per 5,000 cubic yards placed, with 1 lot per day per fill serving as a minimum. Please see Technical Specification 8.3.3.7.

Q21. Is there access to Pond #1?

A21. Yes, there is a road to the embankment of Pond #1, but there is no road around Pond #1. Please see sheet fourteen (14) of the Plans.

Q22. Are there control points for the Baselines?

A22. Yes, there are eight control points, two for each baseline.

REVISIONS

REVISED SPECIFICATIONS

Specification 8.3.3.7 has been changed to read:

8.3.3.7 Embankment fill and embankment subgrade materials shall be compacted to at least **90%** of Standard Proctor maximum dry density at a moisture content of not less than 2% below nor greater than 3% above optimum. Compaction testing shall be at a frequency of 1 lot per 5,000 cubic yards placed, with 1 lot per day per fill serving as a minimum. A lot consists of five (5) compaction tests in accordance with **Specification 3.3.3**. Testing frequency and locations shall be directed and approved by the Owner.

REQUEST FOR QUOTATION NO. DEPI6307

SIGN IN SHEET

Page 1 of 5

PLEASE PRINT

Date: March 6, 2014

* PLEASE BE SURE TO PRINT LEGIBLY - IF POSSIBLE, LEAVE A BUSINESS CARD

FIRM & REPRESENTATIVE NAME	MAILING ADDRESS	TELEPHONE & FAX NUMBERS
Company: <u>GREEN MOUNTAIN COMPANY</u> Rep: <u>DAVID H. BOWMAN</u> Email Address: <u>DHB722c@yahoo.com</u>	<u>511 50th ST</u> <u>CHARLESTON WV</u> <u>25364</u>	PHONE <u>304-925-0253</u> TOLL FREE <u>-</u> FAX <u>304-925-9230</u>
Company: <u>BARNES EXC. INC.</u> Rep: <u>ROBERT L. BARNES</u> Email Address: <u>BARNES EXC@AOL.COM</u>	<u>P.O. BOX 13384</u> <u>SISSONVILLE WV 25360</u>	PHONE <u>304-984-1725</u> TOLL FREE <u>0</u> FAX <u>304-984-0079</u>
Company: <u>MIKE ENYART & SON</u> Rep: <u>ERIC BROGAN</u> Email Address: <u>ERIC.BROGAN@aol.com</u>	<u>P.O. Box 9</u> <u>South Point Ohio</u>	PHONE <u>304-545-3929</u> TOLL FREE FAX
Company: <u>WFC Excavating</u> Rep: <u>MIKE COLE</u> Email Address: <u>mike.cole55@frontier.com</u>	<u>1221 Grafton Rd</u> <u>MORGANTOWN WV 26508</u>	PHONE <u>304 216-6305</u> TOLL FREE <u>3</u> FAX <u>304 296 3978</u>
Company: <u>EASTERN ARROW</u> Rep: <u>ANN WARDWELL</u> Email Address: <u>easternarrow@hotmail.com</u>	<u>PO Box #108</u> <u>CHARLESTON WV</u> <u>25364</u>	PHONE <u>304-514-0255</u> TOLL FREE FAX <u>0256</u>

000008

SIGN IN SHEET

PLEASE PRINT

Date: March 6, 2014

* PLEASE BE SURE TO PRINT LEGIBLY - IF POSSIBLE, LEAVE A BUSINESS CARD

FIRM & REPRESENTATIVE NAME	MAILING ADDRESS	TELEPHONE & FAX NUMBERS
Company: <u>McCourt & Son Const.</u> Rep: <u>GARY Long</u> Email Address: <u>glong@wirefire.com</u>	<u>2790 Centralia Rd</u> <u>Sutton WV 26601</u>	PHONE <u>304 765-5288</u> TOLL FREE FAX <u>304 765-5293</u>
Company: <u>COWGIRL UP INC</u> Rep: <u>DENNIS C. ELBON</u> Email Address: <u>DCE-COWGIRLUP@EARTHLINK.NET</u>	<u>PO Box 243</u> <u>SIMPSON, WV 26435</u>	PHONE <u>304 739-4397</u> TOLL FREE <u>304-626-1057</u> FAX <u>304-739-4401</u>
Company: <u>J.F. Allen Co</u> Rep: <u>Scott Braschert</u> Email Address: <u>JAMES.ALLEN@JFAllenCo.com</u>	<u>PO Box 2049</u> <u>Buckhannon WV 26201</u>	PHONE <u>304 472 8890</u> TOLL FREE FAX <u>304 472 8897</u>
Company: <u>BIG East Enterprises</u> Rep: <u>Spencer Woodell</u> Email Address: _____	<u>RT 3 Box 1645</u> <u>Bridgeport WVa 26330</u>	PHONE <u>304 672-2067</u> TOLL FREE FAX _____
Company: <u>GREEN RIVER GROUP</u> Rep: <u>DON CASTEEL</u> Email Address: <u>SCALVRETT grg@aol.com</u>	<u>PO BOX 18039</u> <u>MORGANTOWN WV 26507</u>	PHONE <u>304 594-3991</u> TOLL FREE FAX _____

SIGN IN SHEET

PLEASE PRINT

Date: March 6, 2014

* PLEASE BE SURE TO PRINT LEGIBLY - IF POSSIBLE, LEAVE A BUSINESS CARD

FIRM & REPRESENTATIVE NAME	MAILING ADDRESS	TELEPHONE & FAX NUMBERS
Company: <u>RBS INC</u> Rep: <u>JK ROSE</u>	<u>PO BOX 198</u> <u>MAXWENTON, WV</u>	PHONE <u>304-497-3800</u> TOLL FREE
Email Address: <u>LDIONCONCRETE@FRONTIER.NET</u>	<u>NET. NET</u> <u>24931</u>	FAX <u>304-497-3802</u>
Company: <u>ALL-CON, LLC</u> Rep: <u>DAVID DIRLE</u>	<u>124 PHILPOTT LANE</u> <u>BEAVER, WV 25813</u>	PHONE <u>304-731-0190</u> TOLL FREE
Email Address: <u>DIRLE@ACI-WV.COM</u>		FAX <u>304-255-4232</u>
Company: <u>Ryder Contracting Inc</u> Rep: <u>Thane A. Ryder</u>	<u>255 Beaver Creek road</u> <u>Marlinton WV 24954</u>	PHONE <u>304-799-4488</u> TOLL FREE
Email Address: <u>rydercontractinginc@citlink.net</u>		FAX <u>304-799-4132</u>
Company: <u>Aspen Corporation</u> Rep: <u>Richard Koger II</u>	<u>2400 Bitter Drive</u> <u>Danels WV 25832</u>	PHONE <u>304-887-0108</u> TOLL FREE
Email Address: <u>rkoger@aspen-golf.com</u>		FAX <u>304-763-4591</u>
Company: <u>Carpenter Reclamation</u> Rep: <u>Randy Carpenter</u>	<u>P.O. Box 13015</u> <u>Sissonville, WV 25360</u>	PHONE <u>304-984-1115</u> TOLL FREE
Email Address: <u>rcarpen103@aol.com</u>		FAX <u>304-984-2770</u>

REQUEST FOR QUOTATION NO. DEPI6307

SIGN IN SHEET

Page 4 of 5

PLEASE PRINT

Date: March 6, 2014

* PLEASE BE SURE TO PRINT LEGIBLY - IF POSSIBLE, LEAVE A BUSINESS CARD

FIRM & REPRESENTATIVE NAME	MAILING ADDRESS	TELEPHONE & FAX NUMBERS
Company: <u>WISEMAN EXCAVATING INC</u> Rep: <u>JOE WISEMAN</u> Email Address: <u>joewiseman6@gmail.com</u>	<u>515 WISEMAN FARM ROAD</u> <u>LIBERTY, WV 25124</u>	PHONE <u>304-586-3736</u> TOLL FREE FAX <u>304-586-3780</u>
Company: <u>Pineville Paving & Excavating Inc</u> Rep: <u>Tony Bradford</u> Email Address: <u>tonyppi@AOL.com</u>	<u>P.O. Box 1290 Pineville WV 24874</u>	PHONE <u>304-732-8303</u> TOLL FREE <u>☐</u> FAX <u>304-732-7855</u>
Company: <u>H.D Supply</u> Rep: <u>Frank Crislip</u> Email Address: <u>frank.crislip@hdsupply.com</u>	<u>8388 Water St</u> <u>Stone Wood, WV 26301</u>	PHONE <u>304-626-3090</u> TOLL FREE FAX <u>304-626-3093</u>
Company: <u>Doss Enterprises</u> Rep: <u>Rodney Somerville</u> Email Address: <u>rodneysomerville@dossenterprises.com</u>	<u>7522 US Hwy 19 N</u> <u>Jane Lew WV 26378</u>	PHONE <u>304-884-2325</u> TOLL FREE FAX <u>304-884-2328</u>
Company: <u>H.D Supply Co</u> Rep: <u>KEVIN M Amos</u> Email Address: <u>KEVIN_Amos@H.DSupply.com</u>	<u>H.D. Supply</u> <u>8388 Water St</u> <u>Stone Wood W. V 26301</u>	PHONE <u>304-677-2446</u> TOLL FREE FAX

000011

SIGN IN SHEET

PLEASE PRINT

Date: March 6, 2014

* PLEASE BE SURE TO PRINT LEGIBLY - IF POSSIBLE, LEAVE A BUSINESS CARD

FIRM & REPRESENTATIVE NAME	MAILING ADDRESS	TELEPHONE & FAX NUMBERS
Company: <u>North Central Contracting</u> Rep: <u>John Shelton</u> Email Address: <u>jshelton@northcentralcontracting.com</u>	<u>200 Chapel Brook Drive</u> <u>Bridgeport WV 26330</u>	PHONE <u>304-410-2035</u> TOLL FREE FAX
Company: <u>Breakaway Inc.</u> Rep: <u>Doug Vincent</u> Email Address: <u>doug@breakaway.wv.com</u>	<u>1075 Old Turnpike Rd</u> <u>Sutton WV 26601</u>	PHONE 765 <u>765-5317</u> TOLL FREE FAX <u>765-5389</u>
Company: <u>Collins Building & Contracting Inc.</u> Rep: <u>Roger Collins</u> Email Address: <u>collinsbuilding@Hughes.net</u>	<u>3404 Coaly Rd</u> <u>Flatwoods, WV</u> <u>26027</u>	PHONE <u>304-749-3927</u> TOLL FREE FAX <u>11</u>
Company: <u>Mountaineer Infrastructure LLC</u> Rep: <u>Matt Evans</u> Email Address: <u>MEVANS4@mailcity.com</u>	<u>2376 Lanaville Rd</u> <u>Dry Fork WV</u> <u>26263</u>	PHONE <u>304 866-4953</u> TOLL FREE FAX <u>866-4329</u>
Company: <u>EASTERN ARROW</u> Rep: <u>MIKE WARDWELL</u> Email Address: _____	<u>414 Charleston w/P</u>	PHONE <u>304414-0255</u> TOLL FREE FAX

- END - David McCoy WV DEP -

ADDENDUM ACKNOWLEDGEMENT FORM
SOLICITATION NO.: DEP16307

Instructions: Please acknowledge receipt of all addenda issued with this solicitation by completing this addendum acknowledgment form. Check the box next to each addendum received and sign below. Failure to acknowledge addenda may result in bid disqualification.

Acknowledgment: I hereby acknowledge receipt of the following addenda and have made the necessary revisions to my proposal, plans and/or specification, etc.

Addendum Numbers Received:

(Check the box next to each addendum received)

- | | |
|---|--|
| <input type="checkbox"/> Addendum No. 1 | <input type="checkbox"/> Addendum No. 6 |
| <input type="checkbox"/> Addendum No. 2 | <input type="checkbox"/> Addendum No. 7 |
| <input type="checkbox"/> Addendum No. 3 | <input type="checkbox"/> Addendum No. 8 |
| <input type="checkbox"/> Addendum No. 4 | <input type="checkbox"/> Addendum No. 9 |
| <input type="checkbox"/> Addendum No. 5 | <input type="checkbox"/> Addendum No. 10 |

I understand that failure to confirm the receipt of addenda may be cause for rejection of this bid. I further understand that any verbal representation made or assumed to be made during any oral discussion held between Vendor's representatives and any state personnel is not binding. Only the information issued in writing and added to the specifications by an official addendum is binding.

Company

Authorized Signature

Date