



State of West Virginia
 Department of Administration
 Purchasing Division
 2019 Washington Street East
 Post Office Box 50130
 Charleston, WV 25305-0130

Solicitation

NUMBER
DEP16387

PAGE
1

ADDRESS CORRESPONDENCE TO ATTENTION OF:
FRANK WHITTAKER
304-558-2316

RFQ COPY

TYPE NAME/ADDRESS HERE

VENDOR

SHIP TO

ENVIRONMENTAL PROTECTION
 DEPARTMENT OF
 OFFICE OF AML&R
 601 57TH STREET SE
 CHARLESTON, WV
 25304 304-926-0499

DATE PRINTED
11/19/2013

BID OPENING DATE: 12/05/2013

BID OPENING TIME 1:30PM

LINE	QUANTITY	UOP	CAT. NO.	ITEM NUMBER	UNIT PRICE	AMOUNT
				ADDENDUM NO. 1		
				THIS ADDENDUM IS ISSUED TO:		
				1) PROVIDE THE ATTACHED TECHNICAL QUESTIONS & ANSWERS		
				2) PROVIDE THE ATTACHED MANDATORY PRE-BID SIGN IN SHEET		
				3) PROVIDE THE ATTACHED ADDENDUM ACKNOWLEDGEMENT FORM		
				***** END ADDENDUM NO. 1 *****		

SIGNATURE	TELEPHONE	DATE
TITLE	FEIN	ADDRESS CHANGES TO BE NOTED ABOVE

WHEN RESPONDING TO SOLICITATION, INSERT NAME AND ADDRESS IN SPACE ABOVE LABELED 'VENDOR'

SOLICITATION NUMBER: DEP16387

Addendum Number: 01

The purpose of this addendum is to modify the solicitation identified as (“Solicitation”) to reflect the change(s) identified and described below.

Applicable Addendum Category:

- Modify bid opening date and time
- Modify specifications of product or service being sought
- Attachment of vendor questions and responses
- Attachment of pre-bid sign-in sheet
- Correction of error
- Other

Description of Modification to Solicitation:

Additional Documentation: Documentation related to this Addendum (if any) has been included herewith as Attachment A and is specifically incorporated herein by reference.

Terms and Conditions:

1. All provisions of the Solicitation and other addenda not modified herein shall remain in full force and effect.
2. Vendor should acknowledge receipt of all addenda issued for this Solicitation by completing an Addendum Acknowledgment, a copy of which is included herewith. Failure to acknowledge addenda may result in bid disqualification. The addendum acknowledgement should be submitted with the bid to expedite document processing.

DEP16387
Northfork (Suiter) Drainage
Addendum # 1

Item 1: The contractor will have 180 days from the date of the Notice to Proceed to complete construction activities on the project. The \$250 per day liquated damage clause will be in effect after the 180 days. However, the total performance period will be 365 days from the date of the Notice to Proceed for invoicing purposes.

Item 2: Q: Can the block foundations/debris be buried on site?

A: Yes, in accordance with Section 13.0 of the Specifications. This work shall consist of complete demolition, removal, and disposal of portal canopies, masonry walls, concrete piers, concrete pad, culverts, tank remains, foundations, tires, appliances, scrap metal, scrap vehicles, trash, debris, etc., per the Specifications and designated on the Drawings for removal and/or as designated by WVDEP. It shall include salvaging and disposing of the resulting materials in a manner hereinafter prescribed and in accordance with all applicable state and federal regulations. Masonry buildings and structure remains shall be completely dismantled. Concrete foundations, concrete piers, masonry walls or similar structures encountered shall be removed below the existing or re-graded ground surface. Scrap vehicles, scrap metal, appliances, tires, trash and other debris shall be removed from the site in their entirety or as approved by the WVDEP. Masonry and concrete rubble material may be buried on site or used as erosion protection if approved by WVDEP. All material designated by WVDEP for removal from the site shall be disposed of by the Contractor in a legal manner at his own expense outside the work limits in an approved landfill, as approved by the WVDEP.

Item 3: Q: What size stone is used in the stabilized construction entrances?

A: Stone shall be 2-4 inch for low volume entrances and 4-6 inch for heavy use or material delivery entrances. A geotextile fabric under the pad will be required and a culvert or mountable berm will be needed to divert surface water from flowing onto the construction entrance.

Item 4: Q: Do we have to provide a water supply during construction of the cistern?

A: Please refer to Section 1.1 of the Specifications. Mobilization and Demobilization shall also include providing a continuous water supply to Mr. Adams that is currently using a cistern connected to a draining portal as their water supply. The water supply shall be of a quantity and quality equal to or better than their current water supply from the portal. The water supply provided by the Contractor shall be potable. At a minimum, the Contractor may be required to provide a holding tank on site and pump and/or haul water to provide a continuous water supply to Mr. Adams. The water supply to Mr. Adams will be maintained until construction of the cistern and appurtenant structures is completed or as directed by the WVDEP.

Item 5: Contractor is reminded that he/she is responsible for the repair of any damage caused to existing water lines, septic tanks, or other personal property within the limits of construction. Costs associated with repairs will be the sole responsibility of the Contractor.

Item 6: As noted on Plan Sheet 6, the Contractor is to clean and provide channel protection, where required, along existing Channel A. All loose debris that could potentially block the existing culvert near the outlet end is to be removed from the channel. The intent is to clean the top and bottom ends of the channel with an excavator. The length of channel that cannot be reached with an excavator should be worked/cleaned by hand.

SIGN IN SHEET

PLEASE PRINT

Date: 11-07-13

* PLEASE BE SURE TO PRINT LEGIBLY - IF POSSIBLE, LEAVE A BUSINESS CARD

FIRM & REPRESENTATIVE NAME	MAILING ADDRESS	TELEPHONE & FAX NUMBERS
Company: <u>A - A ENERGY, INC</u> Rep: <u>John Wimmer</u> Email Address: <u>WFWaddair@hotmail.com</u>	<u>151 Stewart Street</u> <u>Welch West Virginia</u>	PHONE <u>304-320-8961</u> TOLL FREE FAX <u>304-520⁴³⁶ 5111</u>
Company: <u>TEAS TREEM ARIZONA</u> Rep: <u>Ann Klavoren</u> Email Address: <u>easternarrow@hotmail.com</u>	<u>PO BOX 4108</u> <u>CHARLESTON WV</u> <u>25364</u>	PHONE <u>304-414-0255</u> TOLL FREE FAX <u>0256</u>
Company: <u>GREEN MOUNTAIN COMPANY</u> Rep: <u>DAVID H. BOWMAN</u> Email Address: <u>DHB 722C Yukon, WV</u>	<u>511 50th ST</u> <u>Charleston WV</u> <u>25304</u>	PHONE <u>304-925-0253</u> TOLL FREE FAX <u>304-925-9230</u>
Company: <u>Aspen Corporation</u> Rep: <u>Richard Koger II</u> Email Address: <u>rkoger@aspen-golf.com</u>	<u>2400 Ritter Dr.</u> <u>Daniels WV 25832</u>	PHONE <u>304-887-0108</u> TOLL FREE FAX <u>304-763-4591</u>
Company: <u>W.E.L. INC</u> Rep: <u>MIKE WALK - RAY BELL</u> Email Address: <u>Ray.Bell Wel Inc</u>	<u>101 OLD Princeton Rd</u> <u>Bluefield, WV 24701</u>	PHONE <u>304-325-9797</u> TOLL FREE FAX <u>304-327-9801</u>

NORTHFORK

SIGN IN SHEET

REQUEST FOR QUOTATION NO. DEP16387

PLEASE PRINT

Date: 11-07-13

* PLEASE BE SURE TO PRINT LEGIBLY - IF POSSIBLE, LEAVE A BUSINESS CARD

FIRM & REPRESENTATIVE NAME	MAILING ADDRESS	TELEPHONE & FAX NUMBERS
Company: <u>COWSIRK WP INC</u>	<u>PO Box 243</u>	PHONE <u>304-739-4397</u>
Rep: <u>DENNIS C. ELSON</u>	<u>SIMPSON WV</u>	TOLL FREE
Email Address: <u>DCS_CONFIG44@EARTHINK.NET</u>	<u>26435</u>	FAX <u>304-626-1051</u> <u>304-739-4401</u>
Company: <u>GOPHER LAND SERVICES</u>	<u>123 BEAVER PLAZA</u>	PHONE <u>304-222-5502</u>
Rep: <u>MARTY COLE</u>	<u>SUITE 200</u>	TOLL FREE
Email Address: <u>ralphmcole@gmail.com</u>	<u>15 BEAVER, WV 25913</u>	FAX <u>866-525-6822</u>
Company: <u>DCI Shires</u>	<u>PO Box 1259</u>	PHONE <u>304-323-1996</u>
Rep: <u>RANNY F CLINE</u>	<u>Bluefield, WV 24701</u>	TOLL FREE
Email Address: <u>Robert Deeb@DCIshires</u>		FAX
Company: <u>ALL-CON, LLC</u>	<u>124 PHILPOTT LANE</u>	PHONE <u>304-731-0190</u>
Rep: <u>DAVID IRLE</u>	<u>BEAVER WV 25813</u>	TOLL FREE
Email Address: <u>DIRLE@ACI-WV.COM</u>		FAX <u>304-255-4232</u>
Company: <u>BUILDING + UTILITY SYSTEMS LLC</u>	<u>RT. 3 PO Box 160</u>	PHONE <u>304-466-3412</u>
Rep: <u>BILL WHITTAKER</u>	<u>JUMPING BRANCH WV 25969</u>	TOLL FREE
Email Address: <u>BUILDINGUTILITY@YAHOO.COM</u>		FAX <u>304-466-3746</u>

SIGN IN SHEET

REQUEST FOR QUOTATION NO. DEP16387

PLEASE PRINT

Date: 11-07-13

*** PLEASE BE SURE TO PRINT LEGIBLY - IF POSSIBLE, LEAVE A BUSINESS CARD**

FIRM & REPRESENTATIVE NAME	MAILING ADDRESS	TELEPHONE & FAX NUMBERS
Company: <u>Carpenter Reclamation</u>	<u>PO BX 13015</u>	PHONE <u>984-1115</u>
Rep: <u>Randy Carpenter</u>	<u>Siersonville, WV</u>	TOLL FREE
Email Address: <u>Rcarpen13@aol.com</u>		FAX <u>984-2770</u>
Company: <u>CAM EXCAVATION</u>	<u>661 Piney Branch Place</u>	PHONE <u>304 308 3293</u>
Rep: <u>James Bishop</u>	<u>Princeton WV 24739.</u>	TOLL FREE
Email Address: <u>CAMEXCAVATION@gmail.com</u>		FAX <u>304 487 2180</u>
Company: <u>NEMESIS Contracting LLC</u>	<u>44446 Pond Fork Rd</u>	PHONE <u>(304)247 6934</u>
Rep: <u>DAVE FARMER</u>	<u>Wharton WV 25208</u>	TOLL FREE
Email Address: <u>info@NEMESIScontracting.com</u>		FAX
Company: _____	_____	PHONE _____
Rep: _____	_____	TOLL FREE _____
Email Address: _____	_____	FAX _____
Company: _____	_____	PHONE _____
Rep: _____	_____	TOLL FREE _____
Email Address: _____	_____	FAX _____

ADDENDUM ACKNOWLEDGEMENT FORM
SOLICITATION NO.: DEP16387

Instructions: Please acknowledge receipt of all addenda issued with this solicitation by completing this addendum acknowledgment form. Check the box next to each addendum received and sign below. Failure to acknowledge addenda may result in bid disqualification.

Acknowledgment: I hereby acknowledge receipt of the following addenda and have made the necessary revisions to my proposal, plans and/or specification, etc.

Addendum Numbers Received:

(Check the box next to each addendum received)

- | | |
|---|--|
| <input type="checkbox"/> Addendum No. 1 | <input type="checkbox"/> Addendum No. 6 |
| <input type="checkbox"/> Addendum No. 2 | <input type="checkbox"/> Addendum No. 7 |
| <input type="checkbox"/> Addendum No. 3 | <input type="checkbox"/> Addendum No. 8 |
| <input type="checkbox"/> Addendum No. 4 | <input type="checkbox"/> Addendum No. 9 |
| <input type="checkbox"/> Addendum No. 5 | <input type="checkbox"/> Addendum No. 10 |

I understand that failure to confirm the receipt of addenda may be cause for rejection of this bid. I further understand that any verbal representation made or assumed to be made during any oral discussion held between Vendor's representatives and any state personnel is not binding. Only the information issued in writing and added to the specifications by an official addendum is binding.

Company

Authorized Signature

Date

NOTE: This addendum acknowledgement should be submitted with the bid to expedite document processing.
 Revised 6/8/2012