



State of West Virginia
 Department of Administration
 Purchasing Division
 2019 Washington Street East
 Post Office Box 50130
 Charleston, WV 25305-0130

Solicitation

NUMBER
DNR214097

PAGE
1

ADDRESS CORRESPONDENCE TO ATTENTION OF:
DEAN WINGERD
304-558-0468

RFQ COPY

TYPE NAME/ADDRESS HERE

V
E
N
D
O
R

S
H
I
P
T
O

DIVISION OF NATURAL RESOURCES
 TYGART LAKE STATE PARK
 ATTN: PARK SUPERINTENDENT
 1240 PAUL E MALONE RD
 GRAFTON, WV
 26354 304-265-3383

DATE PRINTED
03/25/2014

BID OPENING DATE: 04/03/2014

BID OPENING TIME 1:30PM

LINE	QUANTITY	UOP	CAT NO.	ITEM NUMBER	UNIT PRICE	AMOUNT
ADDENDUM NO. 2						
ADDENDUM IS ISSUED:						
1. TO PROVIDE A COPY OF VENDOR QUESTIONS AND RESPONSES. QUESTION AND ANSWER PAGES ARE ATTACHED.						
2. TO PROVIDE ADDENDUM ACKNOWLEDGMENT. THIS DOCUMENT SHOULD BE SIGNED AND RETURNED WITH YOUR BID. FAILURE TO SIGN AND RETURN MAY RESULT IN THE DISQUALIFICATION OF YOUR BID.						
***** END OF ADDENDUM NO.2 *****						

SIGNATURE		TELEPHONE	DATE
TITLE	FEIN	ADDRESS CHANGES TO BE NOTED ABOVE	

WHEN RESPONDING TO SOLICITATION, INSERT NAME AND ADDRESS IN SPACE ABOVE LABELED 'VENDOR'

SOLICITATION NUMBER: DNR214097
Addendum Number: 2

The purpose of this addendum is to modify the solicitation identified as (“Solicitation”) to reflect the change(s) identified and described below.

Applicable Addendum Category:

- Modify bid opening date and time
- Modify specifications of product or service being sought
- Attachment of vendor questions and responses
- Attachment of pre-bid sign-in sheet
- Correction of error
- Other

Description of Modification to Solicitation:

1. To provide questions and responses for the above solicitation.
2. To provide Addendum Acknowledgment form.

Additional Documentation: Documentation related to this Addendum (if any) has been included herewith as Attachment A and is specifically incorporated herein by reference.

Terms and Conditions:

1. All provisions of the Solicitation and other addenda not modified herein shall remain in full force and effect.
2. Vendor should acknowledge receipt of all addenda issued for this Solicitation by completing an Addendum Acknowledgment, a copy of which is included herewith. Failure to acknowledge addenda may result in bid disqualification. The addendum acknowledgement should be submitted with the bid to expedite document processing.

ATTACHMENT A

ADDENDUM #2
Tygart Lake State Park Lodge: Kitchen HVAC Renovation
DNR 214097
24 Mar 2014

This Addendum forms a part of the Contract Documents and modifies the original bidding Documents as noted below. This Addendum consists of the following: Bidder Questions and Answers, and Technical Clarifications.

BIDDER QUESTIONS & ANSWERS:

1. Are you wanting a full tapered roof system on this job or just at edge? For a 20 year warranty it needs a 1/4" per ft. slope.

ANSWER: The primary EPDM roof is to be sloped at 1/4" per ft. with cants sloped as shown on the plans. Both roof access doors shall be demolished and replaced to accommodate raising both thresholds. The new opening shall be sized to allow 6" clearance between threshold and adjacent roof. Provide new insulated hollow metal door and frame, width to match existing, and height to be field verified. Paint new door to match existing finishes. Provide new door hardware to match existing hardware operation. Adjust location of interface from asphalt to EPDM roofing to accommodate new roof pitch.

TECHNICAL CLARIFICATIONS:

1. There will be no soffit replacement required.
2. Fascia material will be 2" x 8" pressure treated wood, painted with two coats of Sherwin Williams Deck Scapes[®] exterior acrylic solid color deck stain specifically designed for application on pressure treated wood. Color to be selected by owner.

ACKNOWLEDGEMENT:

The questions, answers and comments detailed herein are part of the project documents for this project and are to be acknowledged as ADDENDUM #2. Submitted this 24th day of March, 2014, by Miller Engineering.



President
Miller Engineering, Inc

Cc: Brad Leslie PE

ADDENDUM ACKNOWLEDGEMENT FORM
SOLICITATION NO.: DNR214097

Instructions: Please acknowledge receipt of all addenda issued with this solicitation by completing this addendum acknowledgment form. Check the box next to each addendum received and sign below. Failure to acknowledge addenda may result in bid disqualification.

Acknowledgment: I hereby acknowledge receipt of the following addenda and have made the necessary revisions to my proposal, plans and/or specification, etc.

Addendum Numbers Received:

(Check the box next to each addendum received)

- | | |
|---|--|
| <input type="checkbox"/> Addendum No. 1 | <input type="checkbox"/> Addendum No. 6 |
| <input type="checkbox"/> Addendum No. 2 | <input type="checkbox"/> Addendum No. 7 |
| <input type="checkbox"/> Addendum No. 3 | <input type="checkbox"/> Addendum No. 8 |
| <input type="checkbox"/> Addendum No. 4 | <input type="checkbox"/> Addendum No. 9 |
| <input type="checkbox"/> Addendum No. 5 | <input type="checkbox"/> Addendum No. 10 |

I understand that failure to confirm the receipt of addenda may be cause for rejection of this bid. I further understand that any verbal representation made or assumed to be made during any oral discussion held between Vendor's representatives and any state personnel is not binding. Only the information issued in writing and added to the specifications by an official addendum is binding.

Company

Authorized Signature

Date

NOTE: This addendum acknowledgment should be submitted with the bid to expedite document processing.
 Revised 6/8/2012