



State of West Virginia  
 Department of Administration  
 Purchasing Division  
 2019 Washington Street East  
 Post Office Box 50130  
 Charleston, WV 25305-0130

# Solicitation

NUMBER
ISCN0105

PAGE
1

ADDRESS CORRESPONDENCE TO ATTENTION OF:
KRISTA FERRELL 304-558-2596

RFQ COPY  
 TYPE NAME/ADDRESS HERE

VENDOR

SHIP TO

DEPARTMENT OF ADMINISTRATION  
 IS&C - DATA CENTER MANAGER  
 BUILDING 6, ROOM B110  
 1900 KANAWHA BOULEVARD, EAST  
 CHARLESTON, WV  
 25305-0135 304-558-5914

DATE PRINTED
08/07/2013

BID OPENING DATE: 08/15/2013 BID OPENING TIME 1:30PM

LINE	QUANTITY	UOP	CAT NO.	ITEM NUMBER	UNIT PRICE	AMOUNT
ADDENDUM NO. 1						
THIS ADDENDUM IS ISSUED TO AMEND THE ORIGINAL SOLICITATION (ISCN0105) PER THE ATTACHED DOCUMENTATION.						
0001	1	EA	205-43	PERIPHERAL DEVICES AND ACCESSORIES, COMPUTER SYSTEM		
***** THIS IS THE END OF RFQ ISCN0105 ***** TOTAL:						

SIGNATURE		TELEPHONE	DATE
TITLE	FEIN	ADDRESS CHANGES TO BE NOTED ABOVE	

WHEN RESPONDING TO SOLICITATION, INSERT NAME AND ADDRESS IN SPACE ABOVE LABELED 'VENDOR'

**SOLICITATION NUMBER: ISCN0105**  
**Addendum Number: 1**

---

The purpose of this addendum is to modify the solicitation identified as (“Solicitation”) to reflect the change(s) identified and described below.

**Applicable Addendum Category:**

- | Modify bid opening date and time
- | Modify specifications of product or service being sought
- | Attachment of vendor questions and responses
- | Attachment of pre-bid sign-in sheet
- | Correction of error
- | Other

**Description of Modification to Solicitation:**

Bid Opening date is extended to 08/15/2013. Bid Opening Time remains 1:30 PM EST.

**Additional Documentation:** Documentation related to this Addendum (if any) has been included herewith as Attachment A and is specifically incorporated herein by reference.

**Terms and Conditions:**

1. All provisions of the Solicitation and other addenda not modified herein shall remain in full force and effect.
2. Vendor should acknowledge receipt of all addenda issued for this Solicitation by completing an Addendum Acknowledgment, a copy of which is included herewith. Failure to acknowledge addenda may result in bid disqualification. The addendum acknowledgement should be submitted with the bid to expedite document processing.

# ATTACHMENT A

## Technical Question Responses for ISN0105

### RFQ Description:

Purchase of a power conditioning and distribution unit for its central data center.

---

Questions Received July 29, 2013

1. Section # 3.1.1.4 does transformer need to be rated as K20 or standard transformer?

Standard

2. Section #3.1.1.1 note factory special required for three 42 pole breaker panel

The delivered unit should consist of three breaker panels so factory special is required

3. Section #3.1.1.6 confirm color is IBM ZP-0430 off white?

We prefer the off white but color is not an issue.

4. Section #3.1.1.7 is the vendor providing the plug in breakers and cables or is the owner providing ?

We will be providing the plug-in breakers and cable as we need them.

5. And what brand of plug in breakers will be used ( GE or Square D) ?

We will use GE plug-in breakers.

6. Need confirming height of floor pedestal for units? or is one not needed?

A floor pedestal is not needed.

7. Section 3.1.1.12 startup services is it need 7x 24 or 5x8?

7 x 24 service

8. Maintenance service what is required one PM only per year for the three-year period with complete coverage for any failures?

One PM per year with complete coverage of any failures is our expectation.

\*\*\*\*\*End of Questions Received\*\*\*\*\*

**ADDENDUM ACKNOWLEDGEMENT FORM**  
**SOLICITATION NO.: ISCN0105**

**Instructions:** Please acknowledge receipt of all addenda issued with this solicitation by completing this addendum acknowledgment form. Check the box next to each addendum received and sign below. Failure to acknowledge addenda may result in bid disqualification.

**Acknowledgment:** I hereby acknowledge receipt of the following addenda and have made the necessary revisions to my proposal, plans and/or specification, etc.

**Addendum Numbers Received:**

(Check the box next to each addendum received)

- |   |  |
|---|--|
| <input type="checkbox"/> Addendum No. 1 | <input type="checkbox"/> Addendum No. 6  |
| <input type="checkbox"/> Addendum No. 2 | <input type="checkbox"/> Addendum No. 7  |
| <input type="checkbox"/> Addendum No. 3 | <input type="checkbox"/> Addendum No. 8  |
| <input type="checkbox"/> Addendum No. 4 | <input type="checkbox"/> Addendum No. 9  |
| <input type="checkbox"/> Addendum No. 5 | <input type="checkbox"/> Addendum No. 10 |

I understand that failure to confirm the receipt of addenda may be cause for rejection of this bid. I further understand that any verbal representation made or assumed to be made during any oral discussion held between Vendor’s representatives and any state personnel is not binding. Only the information issued in writing and added to the specifications by an official addendum is binding.

\_\_\_\_\_  
Company

\_\_\_\_\_  
Authorized Signature

\_\_\_\_\_  
Date

NOTE: This addendum acknowledgement should be submitted with the bid to expedite document processing.  
Revised 6/8/2012