



State of West Virginia
Department of Administration
Purchasing Division
2019 Washington Street East
Post Office Box 50130
Charleston, WV 25305-0130

Solicitation

NUMBER

LSH14035

PAGE

1

ADDRESS CORRESPONDENCE TO ATTENTION OF:

ROBERTA WAGNER
304-558-0067

RFQ COPY

TYPE NAME/ADDRESS HERE

V
E
N
D
O
R

S
H
I
P
T
O

HEALTH AND HUMAN RESOURCES
BHMF
LAKIN HOSPITAL
11522 OHIO RIVER ROAD
WEST COLUMBIA, WV
25287 304-675-0860

DATE PRINTED

09/05/2013

BID OPENING DATE: 09/17/2013

BID OPENING TIME 1:30PM

LINE	QUANTITY	UOP	CAT. NO.	ITEM NUMBER	UNIT PRICE	AMOUNT
ADDENDUM NO. 5						
ADDENDUM IS ISSUED:						
1. TO PROVIDE A CORRECTED RESPONSE TO QUESTION # 2 OF THE QUESTIONS & ANSWERS RECEIVED FOR ADDENDUM NO. 3. PLEASE SEE ATTACHED FOR THE CORRECTED RESPONSE.						
2. TO PROVIDE ADDENDUM ACKNOWLEDGEMENT. THIS DOCUMENT SHOULD BE SIGNED AND RETURNED WITH YOUR BID. FAILURE TO SIGN AND RETURN MAY RESULT IN THE DISQUALIFICATION OF YOUR BID.						
***** END OF ADDENDUM NO. 5 *****						
0001	1	LS		770-93		
FULLY ADHERED MEMBRANE ROOFING SYSTEM					VENDOR IS	
***** THIS IS THE END OF RFQ LSH14035 ***** TOTAL:						

SIGNATURE

TELEPHONE

DATE

TITLE

FEIN

ADDRESS CHANGES TO BE NOTED ABOVE

WHEN RESPONDING TO SOLICITATION, INSERT NAME AND ADDRESS IN SPACE ABOVE LABELED 'VENDOR'

SOLICITATION NUMBER: LSH14035**Addendum Number: 5**

The purpose of this addendum is to modify the solicitation identified as ("Solicitation") to reflect the change(s) identified and described below.

Applicable Addendum Category:

- ☐ Modify bid opening date and time
- ☒ Modify specifications of product or service being sought
- ☐ Attachment of vendor questions and responses
- ☐ Attachment of pre-bid sign-in sheet
- ☒ Correction of error
- ☒ Other

Description of Modification to Solicitation:

1. To provide corrections made to Addendum No. 3, Question # 2.
2. To provide Addendum Acknowledgement.

Additional Documentation: Documentation related to this Addendum (if any) has been included herewith as Attachment A and is specifically incorporated herein by reference.

Terms and Conditions:

1. All provisions of the Solicitation and other addenda not modified herein shall remain in full force and effect.
2. Vendor should acknowledge receipt of all addenda issued for this Solicitation by completing an Addendum Acknowledgment, a copy of which is included herewith. Failure to acknowledge addenda may result in bid disqualification. The addendum acknowledgement should be submitted with the bid to expedite document processing.

ATTACHMENT A

Addendum #5 for LSH14035

1. Question: The original specification was for 2 layers of 2" insulation. The response to question 6 in addendum 2 calls for insulation to be tapered at $\frac{1}{4}$ " slope per foot. Typically, a minimum thickness at the roof drains is specified as well. Can a minimum thickness of tapered insulation at the drains be provided? Another way of doing this is to specify an average R-value for the tapered insulation system. As the original specification was for 2 layers of 2", which is an R-24.2, you could specify that the average R-value of the insulation system is to be R-24.2. Either a minimum thickness or an average R-value is required to supply the tapered insulation system.

Answer: Install a 2.5" minimum thickness, $\frac{1}{8}$ " slope per foot, fully tapered insulation system over the entire roof area. Average R-value of tapered insulation system shall be R-25. Add wood blocking, as necessary, at perimeters to maintain a constant perimeter edge height equal to or above the maximum height of tapered insulation.

ADDENDUM ACKNOWLEDGEMENT FORM
SOLICITATION NO.: LSH14035

Instructions: Please acknowledge receipt of all addenda issued with this solicitation by completing this addendum acknowledgment form. Check the box next to each addendum received and sign below. Failure to acknowledge addenda may result in bid disqualification.

Acknowledgment: I hereby acknowledge receipt of the following addenda and have made the necessary revisions to my proposal, plans and/or specification, etc.

Addendum Numbers Received:

(Check the box next to each addendum received)

<input type="checkbox"/> Addendum No. 1	<input type="checkbox"/> Addendum No. 6
<input type="checkbox"/> Addendum No. 2	<input type="checkbox"/> Addendum No. 7
<input type="checkbox"/> Addendum No. 3	<input type="checkbox"/> Addendum No. 8
<input type="checkbox"/> Addendum No. 4	<input type="checkbox"/> Addendum No. 9
<input type="checkbox"/> Addendum No. 5	<input type="checkbox"/> Addendum No. 10

I understand that failure to confirm the receipt of addenda may be cause for rejection of this bid. I further understand that any verbal representation made or assumed to be made during any oral discussion held between Vendor's representatives and any state personnel is not binding. Only the information issued in writing and added to the specifications by an official addendum is binding.

Company

Authorized Signature

Date

NOTE: This addendum acknowledgement should be submitted with the bid to expedite document processing.

Revised 6/8/2012