



State of West Virginia
 Department of Administration
 Purchasing Division
 2019 Washington Street East
 Post Office Box 50130
 Charleston, WV 25305-0130

Solicitation

NUMBER
MMB14039

PAGE
1

ADDRESS CORRESPONDENCE TO ATTENTION OF
ROBERTA WAGNER 304-558-0067

RFQ COPY

TYPE NAME/ADDRESS HERE

VENDOR

SHIP TO

HEALTH AND HUMAN RESOURCES
 MILDRED MITCHELL-BATEMAN
 HOSPITAL
 1530 NORWAY AVENUE
 HUNTINGTON, WV
 25705 304-525-7801

DATE PRINTED
09/17/2013

BID OPENING DATE: 10/01/2013

BID OPENING TIME 1:30PM

LINE	QUANTITY	UOP	CAT NO.	ITEM NUMBER	UNIT PRICE	AMOUNT
				ADDENDUM NO. 1		
				ADDENDUM IS ISSUED:		
				1. TO PROVIDE RESPONSES TO VENDORS' QUESTIONS REGARDING THE ABOVE SOLICITATION.		
				2. TO PROVIDE VENDORS A COPY OF THE MANDATORY PRE-BID MEETING SIGN-IN SHEET.		
				3. TO PROVIDE ADDENDUM ACKNOWLEDGEMENT. THIS DOCUMENT SHOULD BE SIGNED AND RETURNED WITH YOUR BID. FAILURE TO SIGN AND RETURN MAY RESULT IN THE DISQUALIFICATION OF YOUR BID.		
				***** END OF ADDENDUM NO. 1 *****		

SIGNATURE		TELEPHONE	DATE
TITLE	FEIN	ADDRESS CHANGES TO BE NOTED ABOVE	

WHEN RESPONDING TO SOLICITATION, INSERT NAME AND ADDRESS IN SPACE ABOVE LABELED 'VENDOR'



State of West Virginia
 Department of Administration
 Purchasing Division
 2019 Washington Street East
 Post Office Box 50130
 Charleston, WV 25305-0130

Solicitation

NUMBER
MMB14039

PAGE
2

ADDRESS CORRESPONDENCE TO ATTENTION OF:
ROBERTA WAGNER
304-558-0067

RFQ COPY

TYPE NAME/ADDRESS HERE

VENDOR

SHIP TO

HEALTH AND HUMAN RESOURCES
 MILDRED MITCHELL-BATEMAN
 HOSPITAL
 1530 NORWAY AVENUE
 HUNTINGTON, WV
 25705 304-525-7801

DATE PRINTED
09/17/2013

BID OPENING DATE: 10/01/2013

BID OPENING TIME 1:30PM

LINE	QUANTITY	UOP	CAT. NO.	ITEM NUMBER	UNIT PRICE	AMOUNT
0001	1	LS		910-65		
				LUMP SUM BID FOR MATERIAL AND SUPPLIES		
0002	1	LS		910-65		
				LUMP SUM BID FOR LABOR - PREVAILING WAGES		
***** THIS IS THE END OF RFQ MMB14039 ***** TOTAL:						

SIGNATURE		TELEPHONE	DATE
TITLE	FEIN	ADDRESS CHANGES TO BE NOTED ABOVE	

WHEN RESPONDING TO SOLICITATION, INSERT NAME AND ADDRESS IN SPACE ABOVE LABELED 'VENDOR'

SOLICITATION NUMBER: MMB14039**Addendum Number: 1**

The purpose of this addendum is to modify the solicitation identified as ("Solicitation") to reflect the change(s) identified and described below.

Applicable Addendum Category:

- | Modify bid opening date and time
- | Modify specifications of product or service being sought
- | Attachment of vendor questions and responses
- | Attachment of pre-bid sign-in sheet
- | Correction of error
- | Other

Description of Modification to Solicitation:

1. To provide responses to Vendors' questions.
2. To provide Vendors a copy of the mandatory pre-bid sign-in sheet.
3. To provide Addendum Acknowledgement.

Additional Documentation: Documentation related to this Addendum (if any) has been included herewith as Attachment A and is specifically incorporated herein by reference.

Terms and Conditions:

1. All provisions of the Solicitation and other addenda not modified herein shall remain in full force and effect.
2. Vendor should acknowledge receipt of all addenda issued for this Solicitation by completing an Addendum Acknowledgment, a copy of which is included herewith. Failure to acknowledge addenda may result in bid disqualification. The addendum acknowledgement should be submitted with the bid to expedite document processing.

ATTACHMENT A

Addendum #1 MMB14039

To respond to questions submitted by vendor.

Question #1:

Is it the owner's intent to remove and replace all caulking around the exterior perimeters of all windows (in specified work areas, but not including west elevations) typical of both buildings 3 and 5 or to only replace the caulking at windows specifically identified by note M16?

Answer #1:

Remove and replace all caulking around exterior perimeter of all windows (in specified work areas only, but not including west elevations) typical of buildings 3 and building

Question #2:

Is it the owner's intent to brush, clean and paint all exposed lintel with approved paint at all windows (in specified work areas, but not including west elevations) typical of both buildings 3 and 5 or to only repaint window lintels specifically identified by note P#?

Answer #2:

Brush, clean and paint all exposed lintel with approved paint all windows (in specified work areas, but not including west elevation) typical of both buildings 3 and building 5.

Question #3:

At the pre-bid conference, Note M18 caulk transition from top of exposed lintel to bottom of first course of brick (typical, all windows included) was discussed as to be an incorrect repair. It was further discussed that pointing the transition with brick mortar and installing weep holes would be a better solution to the problem. Please confirm what it is we should estimate and include in our bid.

Answer #3:

Cut out/remove mortar at all lintel bearing locations (approx. 8" on each side of window head) Tuck-point to match existing and caulk perimeter of window with approved caulk. Typical

Question #4:

Drawing Note M17 describes and 8" application of caulking on both sides of lintels. Specifications Note M17 describes a 12" application of caulking on both sides of all lintels. Please confirm what it is we should estimate and include in our bid.

Answer #4:

Cut out/remove mortar at all lintel bearing locations (approx. 8" on each side of window head) Tuck-point to match existing and caulk perimeter of window with approved caulk. Typical

SIGN IN SHEET

Page 1 of 1


Request for Proposal No. MMB14039

PLEASE PRINT

Date: 09/10/2013

* PLEASE BE SURE TO PRINT LEGIBLY - IF POSSIBLE, LEAVE A BUSINESS CARD

FIRM & REPRESENTATIVE NAME	MAILING ADDRESS	TELEPHONE & FAX NUMBERS
Company: <u>Wilson Restoration Inc.</u> Rep: <u>Michael Lowe</u> Email Address: <u>m/lowewilres@yahoo.com</u>	<u>PO Box 14250</u> <u>Pgh., PA 15239</u>	PHONE <u>412-793-4400</u> TOLL FREE FAX <u>412-793-1301</u>
Company: <u>Metro Masonry, Inc.</u> Rep: <u>Jamie Rutledge</u> Email Address: <u>GMartin@MetroMasonry.org</u>	<u>5050 A State Route 10</u> <u>Barboursville, WV 25504</u> <u>BGriffith@MetroMasonry.org</u>	PHONE <u>304-736-8655</u> TOLL FREE FAX <u>304-736-0764</u>
Company: <u>HAGER CONSTRUCTION LLC</u> Rep: <u>BRUCE GOLD</u> Email Address: <u>rb1gold@cs.com</u>	<u>5192 BRALEY RD</u> <u>HUNTINGTON WV 25705</u>	PHONE <u>304 302 7885</u> TOLL FREE FAX <u>304 302 7895</u>
Company: <u>GRACIANO CORPORATION</u> Rep: <u>DONALD McDEVITT</u> Email Address: <u>dmcdevitt@graciano.com</u>	<u>209 Sigma DR.</u> <u>Pittsburgh PA.</u> <u>15238</u>	PHONE <u>412-963-8400 x 10151</u> TOLL FREE <u>1-800-523-5076</u> FAX <u>412-963-6284</u>
Company: _____ Rep: _____ Email Address: _____	_____ _____ _____	PHONE TOLL FREE FAX



ADDENDUM ACKNOWLEDGEMENT FORM
SOLICITATION NO.: MMB14039

Instructions: Please acknowledge receipt of all addenda issued with this solicitation by completing this addendum acknowledgment form. Check the box next to each addendum received and sign below. Failure to acknowledge addenda may result in bid disqualification.

Acknowledgment: I hereby acknowledge receipt of the following addenda and have made the necessary revisions to my proposal, plans and/or specification, etc.

Addendum Numbers Received:

(Check the box next to each addendum received)

- | | |
|---|--|
| <input type="checkbox"/> Addendum No. 1 | <input type="checkbox"/> Addendum No. 6 |
| <input type="checkbox"/> Addendum No. 2 | <input type="checkbox"/> Addendum No. 7 |
| <input type="checkbox"/> Addendum No. 3 | <input type="checkbox"/> Addendum No. 8 |
| <input type="checkbox"/> Addendum No. 4 | <input type="checkbox"/> Addendum No. 9 |
| <input type="checkbox"/> Addendum No. 5 | <input type="checkbox"/> Addendum No. 10 |

I understand that failure to confirm the receipt of addenda may be cause for rejection of this bid. I further understand that any verbal representation made or assumed to be made during any oral discussion held between Vendor's representatives and any state personnel is not binding. Only the information issued in writing and added to the specifications by an official addendum is binding.

Company

Authorized Signature

Date

NOTE: This addendum acknowledgement should be submitted with the bid to expedite document processing.
 Revised 6/8/2012