

From: **Whittaker, Frank M** <frank.m.whittaker@wv.gov>
Date: Mon, Dec 13, 2021 at 2:51 PM
Subject: Re: Emergency Repair Request
To: Chambers Smith, Jessica <jessica.chamberssmith@wv.gov>
Cc: Totten, Mark L <mark.l.totten@wv.gov>, Hager III, Joseph E <joseph.e.hageriii@wv.gov>, Linda Harper <linda.b.harper@wv.gov>

Jessica,

Your request for emergency repair of the leachate storage tank at Petersburg Landfill is approved. Please follow all Purchasing Division Procedures outlined in the handbook and provide all supporting documentation to this office within 30 days of this approval for processing.

As always, let us know if you have any questions or concerns.

Frank

On Mon, Dec 13, 2021 at 2:33 PM Chambers Smith, Jessica <jessica.chamberssmith@wv.gov> wrote:
Frank,

Please see the attached request for emergency approval.

Please note that we did get a ruling from Labor regarding the repair (see below) and per Labor it would only be considered construction if the tank was replaced. I have confirmed with the division that the tank will not be replaced.

Please feel free to contact me if you have any questions or concerns.

Sincerely,

Jessica Chambers-Smith, DEP Procurement Manager

Administrative Services - Business Operations Office

WV Dept. of Environmental Protection

601 57th Street S.E.

Charleston, WV 25304

Phone (304) 926-0499 x 41140

Fax (304) 926-0452

Jessica.chamberssmith@wv.gov

----- Forwarded message -----

From: **Casto, Terri C** <terri.c.casto@wv.gov>
Date: Mon, Dec 13, 2021 at 2:28 PM
Subject: Fwd: Emergency Repair Request
To: Jessica S Chambers <jessica.chamberssmith@wv.gov>



Terri C. Casto
Procurement Specialist Senior
West Virginia Department of Environmental Protection
Phone: 304-414-1143 ext. 41143
601 57th Street SE, Charleston, WV 25304
www.dep.wv.gov

----- Forwarded message -----

From: **Licensing, Labor** <licensing@wv.gov>
Date: Mon, Dec 13, 2021 at 2:06 PM
Subject: Re: Emergency Repair Request
To: Casto, Terri C <terri.c.casto@wv.gov>

Ms. Casto,

A license will not be required for the repair. If the tank needs replaced then a license will be required.

Thank you.

On Mon, Dec 13, 2021 at 1:51 PM Casto, Terri C <terri.c.casto@wv.gov> wrote:
we are trying to determine if this would qualify as construction or not. Could you please advise?



Terri C. Casto
Procurement Specialist Senior
West Virginia Department of Environmental Protection
Phone: 304-414-1143 ext. 41143
601 57th Street SE, Charleston, WV 25304
www.dep.wv.gov



APPROVED
12/13/21
[Signature]

west virginia department of environmental protection

Division of Land Restoration
Landfill Closure Assistance Program
601 57th Street, SE
Charleston WV 25304
Phone: 304-926-0499

Harold D. Ward, Cabinet Secretary
dep.wv.gov

To: B.J. Chestnut, Assistant Chief
DEP Administrative Services

From: David B. McCoy, Engineer-Chief
Division of Land Restoration

**David
McCoy**

Digitally signed by: David McCoy
DN: CN = David McCoy, email =
david.b.mccoy@wv.gov, C = US, O =
WV DEP, OU = Div. Land
Restoration
Date: 2021.12.13 09:16:44 -05'00'

Date: December 13, 2021

RE: Petersburg Landfill Leachate Tank Repair

The existing bolted steel storage tank for landfill leachate water is leaking from a bolted seam in the floor, which is the primary containment for leachate. The secondary containment lined area sump has a valve that has failed in the open position, which is allowing the leachate to discharge into the immediate field and drainage leading to the South Branch of Potomac River which will be detrimental to humans and wildlife. The repairs to the steel tank and overflow valve are needed for the leachate to be retained for safe transfer and treatment to the local wastewater plant.

The WVDEP Landfill Closure Assistance Program (LCAP) requests to issue an emergency contract to repair the tank and valve. The estimated cost is approximately \$40,000.00.

Cc: Cathy Guynn, Program Manager